

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P919815

Luminaire Tested: DFN2DIP-PN4F0-120D070US935-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P919815
REPORT IS A COMBINATION OF REPORTS P901200 AND P898053
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN4F0-120D070US935-RLLONL
Description: 4 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14748.9 lumens
Efficiency: N/A
Efficacy: 82.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.74' x L: 3.94' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 178.8
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9781
Total Harmonic Distortion (THDi): 0.075
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P919815

CATALOG NUMBER: DFN2DIP-PN4F0-120D070US935-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P919815

CATALOG NUMBER: DFN2DIP-PN4F0-120D070US935-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	109	109	109	109	102	102	102	102	89	89	89		76	76	76		65
1	101	96	93	89	94	90	87	84	79	76	74		68	66	65		58
2	92	85	79	74	86	80	74	70	70	66	62		60	58	55		52
3	84	75	68	62	79	71	64	59	62	57	53		54	50	47		47
4	77	67	59	53	72	63	56	51	55	50	46		48	44	41		42
5	71	60	52	46	67	56	49	44	50	44	40		44	39	36		38
6	66	54	46	40	62	51	44	39	45	39	35		40	35	32		35
7	61	49	41	36	57	46	39	34	41	35	31		36	32	28		32
8	57	45	37	32	53	42	35	31	38	32	28		34	29	26		30
9	53	41	34	29	50	39	32	27	35	29	25		31	26	23		27
10	50	38	31	26	47	36	29	25	32	27	23		29	24	21		25

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3117	3117	3117
5°	3122	3068	3088
10°	3091	3008	2988
15°	3049	2909	2833
20°	2992	2773	2643
25°	2935	2619	2459
30°	2857	2462	2226
35°	2781	2293	2021
40°	2704	2118	1786
45°	2614	1924	1573
50°	2522	1728	1366
55°	2425	1518	1166
60°	2313	1299	960
65°	2184	1076	865
70°	2028	868	783
75°	1831	767	714
80°	1547	644	621
85°	1078	433	471

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2614 cd/sqm

TEST NUMBER: P919815

CATALOG NUMBER: DFN2DIP-PN4F0-120D070US935-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	400.2	2.7
10°-20°	1098.7	7.4
20°-30°	1542.5	10.5
30°-40°	1681.4	11.4
40°-50°	1545.4	10.5
50°-60°	1213.7	8.2
60°-70°	790.0	5.4
70°-80°	406.7	2.8
80°-90°	107.4	0.7
90°-100°	67.1	0.5
100°-110°	250.0	1.7
110°-120°	663.1	4.5
120°-130°	1099.8	7.5
130°-140°	1168.3	7.9
140°-150°	1085.8	7.4
150°-160°	872.9	5.9
160°-170°	562.5	3.8
170°-180°	193.6	1.3
0°-30°	3041.3	20.6
0°-40°	4722.7	32.0
0°-60°	7481.7	50.7
0°-90°	8785.8	59.6
90°-120°	980.2	6.6
90°-150°	4334.1	29.4
90°-180°	5963.0	40.4
0°-180°	14748.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4270	4270	4270	4270	4270	
5°	4270	4251	4200	4235	4224	405
15°	4062	4019	3888	3814	3776	1144
25°	3687	3563	3308	3150	3091	1696
35°	3177	2980	2640	2396	2311	1988
45°	2597	2338	1932	1658	1565	2006
55°	1975	1673	1256	1024	951	1764
65°	1333	1020	672	541	529	1322
75°	711	440	309	282	278	752
85°	166	85	73	73	73	191
90°	1	18	29	37	40	14
95°	96	47	57	65	63	113
105°	448	492	90	106	112	478
115°	846	871	908	227	121	833
125°	1196	1216	1244	1254	1258	1067
135°	1481	1504	1517	1532	1529	1144
145°	1718	1716	1741	1751	1744	1074
155°	1891	1878	1896	1904	1893	872
165°	1993	1984	1988	1999	1988	563
175°	2038	2028	2031	2041	2027	194
180°	2034	2034	2034	2034	2034	

TEST NUMBER: P919815

CATALOG NUMBER: DFN2DIP-PN4F0-120D070US935-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4270.2	4270.2	4270.2	4270.2	4270.2
2.5°	4289.5	4270.2	4227.6	4266.5	4258.7
5°	4270.2	4250.9	4200.5	4235.3	4223.9
7.5°	4235.3	4212.3	4158.3	4173.4	4154.1
10°	4189.0	4162.0	4084.8	4073.0	4050.0
12.5°	4131.2	4096.4	3991.8	3968.9	3926.2
15°	4061.5	4018.9	3887.7	3814.2	3775.7
17.5°	3980.3	3918.4	3756.0	3671.2	3609.3
20°	3887.7	3810.2	3617.1	3520.7	3435.4
22.5°	3787.2	3698.2	3474.0	3342.7	3285.0
25°	3686.8	3562.9	3307.9	3149.6	3091.4
27.5°	3567.0	3435.4	3153.3	2971.7	2882.7
30°	3439.5	3292.4	2983.2	2786.4	2681.8
32.5°	3315.7	3137.7	2821.2	2589.2	2492.4
35°	3176.7	2979.5	2639.6	2396.1	2310.7
37.5°	3041.4	2828.6	2469.4	2202.5	2106.2
40°	2898.3	2666.7	2291.5	2017.2	1916.8
42.5°	2751.5	2504.3	2114.0	1827.8	1731.5
45°	2596.9	2337.9	1932.3	1657.7	1564.9
47.5°	2450.1	2175.9	1758.5	1483.8	1398.9
50°	2287.8	2013.5	1588.4	1321.5	1240.7
52.5°	2129.2	1839.3	1426.0	1171.0	1097.6
55°	1974.6	1673.3	1255.9	1024.2	950.8
57.5°	1816.3	1507.2	1105.3	888.9	827.0
60°	1654.0	1344.8	946.7	749.9	688.0
62.5°	1495.7	1186.5	811.4	626.1	595.3
65°	1333.3	1020.1	672.4	541.2	529.3
67.5°	1178.8	865.5	541.2	475.2	463.7
70°	1016.4	715.1	448.1	409.6	394.0
72.5°	861.9	575.7	374.7	344.0	336.2
75°	710.9	440.3	309.2	282.1	278.4
77.5°	560.5	312.8	243.6	228.0	220.2
80°	421.1	224.3	185.3	170.1	170.1
82.5°	293.6	150.8	127.5	119.7	119.7
85°	166.1	84.9	73.4	73.4	73.4
87.5°	61.9	30.7	30.7	27.0	27.0
90°	1.4	17.7	29.4	36.9	39.7
92.5°	36.9	30.9	35.3	38.3	39.7
95°	95.6	47.0	57.3	64.8	63.3
97.5°	172.1	51.6	75.0	79.6	80.9
100°	260.6	58.9	83.9	95.6	98.6
102.5°	357.6	354.8	86.9	103.0	107.5
105°	447.5	491.6	89.8	105.9	111.8
107.5°	551.9	588.7	92.8	108.9	114.9
110°	652.1	682.9	257.6	110.5	116.2



TEST NUMBER: P919815

CATALOG NUMBER: DFN2DIP-PN4F0-120D070US935-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	746.3	772.7	747.7	113.2	117.8
115°	846.3	871.2	908.1	226.7	120.8
117.5°	933.1	962.5	987.7	777.1	391.5
120°	1030.3	1052.3	1078.9	1096.6	897.8
122.5°	1112.6	1136.2	1165.8	1174.5	1176.0
125°	1196.5	1215.7	1243.7	1254.0	1258.3
127.5°	1273.1	1293.6	1315.9	1330.6	1332.0
130°	1345.2	1368.8	1384.9	1401.2	1399.8
132.5°	1418.8	1438.0	1454.1	1467.4	1466.0
135°	1480.7	1504.2	1517.4	1532.2	1529.3
137.5°	1545.3	1563.1	1577.9	1592.6	1588.2
140°	1608.6	1620.5	1636.6	1649.8	1642.5
142.5°	1661.7	1672.1	1691.1	1702.8	1695.5
145°	1717.7	1716.1	1741.1	1751.4	1744.1
147.5°	1766.1	1761.8	1786.7	1794.1	1788.3
150°	1813.3	1803.0	1826.6	1835.3	1828.0
152.5°	1853.0	1841.2	1863.3	1872.2	1861.9
155°	1891.3	1878.1	1895.7	1904.5	1892.8
157.5°	1922.2	1910.5	1923.7	1934.1	1922.2
160°	1948.8	1939.8	1948.8	1957.5	1947.1
162.5°	1972.2	1963.4	1970.7	1981.1	1967.8
165°	1992.8	1984.1	1988.4	1998.7	1988.4
167.5°	2009.1	2000.1	2004.7	2015.0	2001.7
170°	2022.3	2013.4	2016.4	2026.7	2013.4
172.5°	2031.1	2022.3	2025.3	2035.6	2022.3
175°	2038.4	2028.1	2031.1	2041.3	2026.7
177.5°	2041.3	2031.1	2032.6	2043.0	2029.6
180°	2034.0	2034.0	2034.0	2034.0	2034.0

TEST NUMBER: P919815

CATALOG NUMBER: DFN2DIP-PN4F0-120D070US935-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.95	12.87	12.83	13.76	14.89	7.92	8.83	8.80	9.73	10.86
	3H	13.64	14.46	14.53	15.36	16.52	9.11	9.93	10.00	10.84	11.99
	4H	14.25	15.03	15.16	15.94	17.10	9.57	10.34	10.48	11.25	12.42
	6H	14.68	15.39	15.60	16.31	17.49	9.90	10.61	10.81	11.52	12.70
	8H	14.81	15.49	15.74	16.42	17.60	9.99	10.66	10.91	11.60	12.78
	12H	14.88	15.52	15.81	16.45	17.65	10.04	10.68	10.97	11.60	12.81
4H	2H	11.98	12.75	12.89	13.66	14.83	8.53	9.30	9.44	10.21	11.37
	3H	13.82	14.46	14.74	15.40	16.58	9.88	10.53	10.81	11.47	12.65
	4H	14.52	15.10	15.45	16.04	17.25	10.44	11.02	11.37	11.96	13.16
	6H	15.04	15.55	15.99	16.50	17.71	10.86	11.36	11.81	12.32	13.53
	8H	15.22	15.69	16.17	16.64	17.86	10.99	11.46	11.94	12.41	13.64
	12H	15.32	15.74	16.29	16.71	17.94	11.06	11.48	12.03	12.46	13.68
8H	4H	14.49	14.96	15.44	15.92	17.14	10.72	11.19	11.67	12.15	13.37
	6H	15.07	15.45	16.04	16.45	17.67	11.25	11.64	12.22	12.63	13.85
	8H	15.29	15.63	16.27	16.61	17.85	11.44	11.78	12.42	12.77	14.00
	12H	15.43	15.73	16.41	16.71	17.99	11.56	11.87	12.55	12.84	14.13
12H	4H	14.45	14.87	15.42	15.84	17.07	10.73	11.16	11.70	12.13	13.35
	6H	15.04	15.39	16.02	16.37	17.61	11.30	11.64	12.28	12.62	13.86
	8H	15.27	15.57	16.25	16.55	17.83	11.51	11.81	12.50	12.79	14.08