

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P925029

Luminaire Tested: DFN2DIP-PN4F0-050D100US950-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P925029
REPORT IS A COMBINATION OF REPORTS P901239 AND P898053
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN4F0-050D100US950-FLLONL
Description: 4 foot, Pentagon Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14166.9 lumens
Efficiency: N/A
Efficacy: 119.0 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.74' x L: 3.94' x H: 0.1')
CIE Type: Semi-Indirect

Input Watts (W): 119
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9951
Total Harmonic Distortion (THDi): 0.07
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P925029

CATALOG NUMBER: DFN2DIP-PN4F0-050D100US950-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P925029

CATALOG NUMBER: DFN2DIP-PN4F0-050D100US950-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	103	103	103	103	93	93	93	93	74	74	74		57	57	57		41
1	94	90	86	83	85	81	78	75	65	63	61		50	48	47		36
2	86	78	72	67	77	71	66	62	57	53	50		44	41	39		32
3	78	69	62	56	70	62	56	51	50	46	42		39	36	33		28
4	71	61	53	47	64	55	49	43	44	40	36		34	31	28		25
5	65	54	46	40	59	49	42	37	40	35	31		31	27	25		23
6	60	48	41	35	54	44	37	32	36	31	27		28	24	21		20
7	56	44	36	30	50	40	33	28	32	27	23		25	22	19		19
8	51	39	32	27	46	36	29	25	29	24	21		23	19	17		17
9	48	36	29	24	43	33	26	22	27	22	19		21	18	15		16
10	45	33	26	21	40	30	24	20	25	20	17		19	16	14		15

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1355	1355	1355
5°	1357	1336	1345
10°	1346	1318	1327
15°	1326	1297	1299
20°	1299	1267	1270
25°	1273	1231	1237
30°	1239	1198	1194
35°	1208	1158	1149
40°	1169	1118	1106
45°	1130	1079	1062
50°	1088	1037	1012
55°	1043	988	965
60°	993	931	912
65°	939	871	849
70°	869	799	781
75°	772	712	719
80°	656	602	599
85°	474	410	401

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 90°

Luminance: 1717 cd/sqm

TEST NUMBER: P925029

CATALOG NUMBER: DFN2DIP-PN4F0-050D100US950-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	174.7	1.2
10°-20°	491.5	3.5
20°-30°	722.3	5.1
30°-40°	838.9	5.9
40°-50°	837.9	5.9
50°-60°	730.6	5.2
60°-70°	540.1	3.8
70°-80°	305.6	2.2
80°-90°	86.3	0.6
90°-100°	106.2	0.7
100°-110°	395.8	2.8
110°-120°	1049.6	7.4
120°-130°	1740.9	12.3
130°-140°	1849.2	13.1
140°-150°	1718.7	12.1
150°-160°	1381.8	9.8
160°-170°	890.4	6.3
170°-180°	306.5	2.2
0°-30°	1388.5	9.8
0°-40°	2227.5	15.7
0°-60°	3796.0	26.8
0°-90°	4728.0	33.4
90°-120°	1551.6	11.0
90°-150°	6860.4	48.4
90°-180°	9439.0	66.6
0°-180°	14166.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1856	1856	1856	1856	1856	
5°	1856	1849	1829	1844	1840	176
15°	1767	1756	1733	1740	1731	498
25°	1599	1585	1554	1558	1554	736
35°	1380	1362	1333	1322	1314	862
45°	1123	1110	1083	1064	1057	866
55°	850	839	817	796	787	760
65°	573	562	544	528	519	567
75°	300	296	287	277	280	320
85°	73	71	70	64	62	82
90°	2	28	46	58	63	13
95°	151	74	91	103	100	179
105°	708	778	142	168	177	757
115°	1340	1379	1438	359	191	1319
125°	1894	1924	1969	1985	1992	1689
135°	2344	2381	2402	2425	2421	1810
145°	2719	2716	2756	2772	2761	1700
155°	2994	2973	3001	3015	2996	1380
165°	3154	3140	3147	3164	3147	891
175°	3226	3210	3215	3231	3208	307
180°	3220	3220	3220	3220	3220	

TEST NUMBER: P925029

CATALOG NUMBER: DFN2DIP-PN4F0-050D100US950-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1856.0	1856.0	1856.0	1856.0	1856.0
2.5°	1866.8	1857.9	1838.3	1856.0	1852.7
5°	1856.0	1849.0	1829.3	1843.5	1840.2
7.5°	1843.5	1832.9	1813.3	1827.7	1824.0
10°	1824.0	1811.6	1790.2	1804.3	1799.1
12.5°	1797.1	1786.6	1765.2	1774.1	1770.4
15°	1766.8	1756.2	1732.9	1740.2	1731.2
17.5°	1729.3	1718.7	1695.4	1704.3	1695.4
20°	1688.3	1677.7	1652.7	1658.0	1651.0
22.5°	1647.4	1631.2	1608.0	1608.0	1604.3
25°	1599.1	1584.9	1554.5	1558.0	1554.5
27.5°	1545.5	1533.0	1509.9	1504.6	1495.7
30°	1492.1	1477.7	1451.0	1445.7	1438.5
32.5°	1434.9	1424.3	1395.7	1384.9	1377.8
35°	1379.6	1361.8	1333.2	1322.4	1313.6
37.5°	1317.1	1301.1	1272.4	1259.9	1251.1
40°	1253.0	1238.6	1210.0	1194.0	1186.9
42.5°	1190.5	1176.1	1147.7	1129.6	1119.0
45°	1122.7	1110.2	1083.3	1063.8	1056.6
47.5°	1056.6	1044.1	1015.5	995.8	985.2
50°	986.9	978.0	953.0	928.1	919.1
52.5°	919.1	906.6	883.5	863.8	851.3
55°	849.6	838.9	817.4	796.0	787.1
57.5°	779.9	771.0	747.7	726.4	719.1
60°	710.3	703.3	678.3	658.5	653.3
62.5°	642.5	630.0	612.2	594.3	587.2
65°	573.0	562.2	544.4	528.3	519.4
67.5°	501.6	492.6	476.6	464.1	456.9
70°	435.5	428.3	412.2	399.7	392.8
72.5°	367.8	360.5	351.6	339.1	333.8
75°	299.7	296.3	287.2	276.7	280.3
77.5°	239.2	231.9	228.4	223.0	217.8
80°	178.6	176.7	173.1	167.8	164.2
82.5°	121.3	121.3	119.6	112.5	112.5
85°	73.1	71.4	69.6	64.2	62.5
87.5°	32.1	28.6	25.0	19.7	17.8
90°	2.2	28.0	46.5	58.4	62.8
92.5°	58.4	48.9	55.9	60.6	62.8
95°	151.3	74.4	90.7	102.7	100.2
97.5°	272.5	81.6	118.7	125.8	128.1
100°	412.5	93.2	132.8	151.3	156.1
102.5°	566.0	561.6	137.5	162.9	170.1
105°	708.2	778.2	142.2	167.6	177.1
107.5°	873.7	931.8	146.9	172.4	181.7
110°	1032.1	1080.9	407.7	174.9	183.9

TEST NUMBER: P925029

CATALOG NUMBER: DFN2DIP-PN4F0-050D100US950-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1181.2	1223.0	1183.5	179.3	186.5
115°	1339.5	1379.1	1437.5	358.8	191.2
117.5°	1477.0	1523.5	1563.3	1230.0	619.7
120°	1630.9	1665.7	1707.8	1735.7	1421.2
122.5°	1761.2	1798.5	1845.2	1859.1	1861.5
125°	1894.0	1924.4	1968.7	1985.0	1991.9
127.5°	2015.1	2047.8	2082.9	2106.1	2108.3
130°	2129.3	2166.7	2192.2	2217.9	2215.7
132.5°	2245.8	2276.2	2301.7	2322.7	2320.5
135°	2343.8	2381.1	2401.9	2425.4	2420.7
137.5°	2446.2	2474.1	2497.6	2520.8	2513.9
140°	2546.2	2565.1	2590.5	2611.6	2599.9
142.5°	2630.4	2646.7	2676.8	2695.3	2683.8
145°	2718.9	2716.4	2756.0	2772.3	2760.7
147.5°	2795.5	2788.6	2828.1	2839.8	2830.7
150°	2870.2	2853.9	2891.3	2905.1	2893.5
152.5°	2933.0	2914.5	2949.4	2963.4	2947.1
155°	2993.7	2972.9	3000.8	3014.6	2996.1
157.5°	3042.6	3024.1	3045.1	3061.4	3042.6
160°	3084.7	3070.5	3084.7	3098.5	3082.2
162.5°	3121.7	3107.8	3119.5	3135.8	3114.8
165°	3154.3	3140.5	3147.4	3163.8	3147.4
167.5°	3180.1	3165.9	3173.2	3189.5	3168.4
170°	3201.1	3187.0	3191.7	3208.0	3187.0
172.5°	3214.9	3201.1	3205.8	3222.1	3201.1
175°	3226.5	3210.2	3214.9	3231.3	3208.0
177.5°	3231.3	3214.9	3217.5	3233.8	3212.7
180°	3219.7	3219.7	3219.7	3219.7	3219.7

TEST NUMBER: P925029

CATALOG NUMBER: DFN2DIP-PN4F0-050D100US950-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	6.56	7.29	7.65	8.38	9.87	6.12	6.85	7.21	7.94	9.43
	3H	8.21	8.87	9.31	9.96	11.47	7.73	8.38	8.83	9.48	10.99
	4H	8.80	9.42	9.90	10.51	12.03	8.31	8.93	9.42	10.03	11.54
	6H	9.19	9.76	10.31	10.86	12.39	8.70	9.27	9.82	10.37	11.90
	8H	9.29	9.84	10.41	10.95	12.47	8.80	9.35	9.92	10.46	11.98
	12H	9.34	9.86	10.46	10.96	12.51	8.84	9.36	9.96	10.47	12.01
4H	2H	7.01	7.63	8.12	8.72	10.24	6.66	7.28	7.77	8.37	9.89
	3H	8.86	9.38	9.98	10.50	12.03	8.46	8.98	9.58	10.10	11.63
	4H	9.57	10.05	10.70	11.16	12.71	9.16	9.63	10.28	10.75	12.29
	6H	10.08	10.49	11.22	11.63	13.17	9.66	10.07	10.79	11.20	12.74
	8H	10.23	10.61	11.36	11.74	13.30	9.80	10.19	10.94	11.31	12.87
	12H	10.30	10.65	11.45	11.79	13.34	9.86	10.21	11.01	11.35	12.91
8H	4H	9.76	10.14	10.89	11.27	12.82	9.39	9.77	10.52	10.90	12.45
	6H	10.39	10.70	11.54	11.87	13.42	10.01	10.33	11.17	11.50	13.05
	8H	10.61	10.89	11.77	12.03	13.61	10.23	10.50	11.39	11.65	13.22
	12H	10.74	10.98	11.90	12.13	13.73	10.34	10.58	11.50	11.72	13.33
12H	4H	9.74	10.08	10.89	11.22	12.78	9.38	9.72	10.53	10.86	12.42
	6H	10.42	10.69	11.58	11.84	13.41	10.05	10.33	11.21	11.48	13.05
	8H	10.66	10.90	11.82	12.04	13.65	10.28	10.53	11.45	11.67	13.28

END OF REPORT