

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P925259

Luminaire Tested: DFN2DIP-PN4F0-120D040US950-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P925259
REPORT IS A COMBINATION OF REPORTS P901146 AND P898053
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN4F0-120D040US950-RLLONL
Description: 4 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 13508.6 lumens
Efficiency: N/A
Efficacy: 86.3 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.74' x L: 3.94' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 156.6
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9781
Total Harmonic Distortion (THDi): 0.075
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P925259

CATALOG NUMBER: DFN2DIP-PN4F0-120D040US950-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P925259

CATALOG NUMBER: DFN2DIP-PN4F0-120D040US950-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	112	112	112	112	107	107	107	107	96	96	96		86	86	86		76
1	103	99	95	92	98	94	91	88	85	82	80		76	75	73		69
2	95	87	81	76	90	83	78	73	75	71	68		68	65	62		61
3	87	78	70	65	82	74	67	62	67	62	58		61	57	53		55
4	80	69	61	55	76	66	59	54	60	54	50		55	50	46		50
5	74	62	54	48	70	59	52	47	54	48	44		50	45	41		45
6	68	56	48	42	65	54	46	41	49	43	39		45	40	36		41
7	63	51	43	38	60	49	42	36	45	39	34		41	36	32		38
8	59	47	39	34	56	45	38	33	41	35	31		38	33	29		35
9	55	43	35	30	52	41	34	30	38	32	28		35	30	26		32
10	52	40	32	28	49	38	31	27	35	29	25		33	28	24		30

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3454	3454	3454
5°	3459	3399	3421
10°	3425	3333	3311
15°	3378	3223	3139
20°	3316	3072	2928
25°	3252	2902	2725
30°	3166	2728	2467
35°	3082	2541	2240
40°	2996	2347	1979
45°	2897	2132	1743
50°	2794	1915	1513
55°	2687	1682	1291
60°	2563	1439	1064
65°	2420	1193	958
70°	2247	962	868
75°	2029	849	791
80°	1714	714	688
85°	1194	479	522

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2897 cd/sqm

TEST NUMBER: P925259

CATALOG NUMBER: DFN2DIP-PN4F0-120D040US950-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	443.4	3.3
10°-20°	1217.3	9.0
20°-30°	1709.1	12.7
30°-40°	1863.0	13.8
40°-50°	1712.3	12.7
50°-60°	1344.7	10.0
60°-70°	875.3	6.5
70°-80°	450.6	3.3
80°-90°	117.3	0.9
90°-100°	42.5	0.3
100°-110°	158.3	1.2
110°-120°	419.9	3.1
120°-130°	696.4	5.2
130°-140°	739.7	5.5
140°-150°	687.5	5.1
150°-160°	552.7	4.1
160°-170°	356.1	2.6
170°-180°	122.6	0.9
0°-30°	3369.8	24.9
0°-40°	5232.8	38.7
0°-60°	8289.9	61.4
0°-90°	9733.1	72.1
90°-120°	620.6	4.6
90°-150°	2744.1	20.3
90°-180°	3776.0	28.0
0°-180°	13508.6	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4732	4732	4732	4732	4732	
5°	4732	4710	4654	4693	4680	449
15°	4500	4453	4308	4226	4184	1268
25°	4085	3948	3665	3490	3425	1879
35°	3520	3301	2925	2655	2560	2203
45°	2878	2590	2141	1837	1734	2222
55°	2188	1854	1392	1135	1054	1955
65°	1477	1130	745	600	586	1465
75°	788	488	343	312	308	833
85°	184	94	81	81	81	211
90°	1	11	19	23	25	13
95°	60	30	36	41	40	72
105°	283	311	57	67	71	303
115°	536	552	575	144	76	527
125°	758	770	787	794	797	676
135°	938	952	961	970	968	724
145°	1088	1087	1102	1109	1104	680
155°	1198	1189	1200	1206	1198	552
165°	1262	1256	1259	1266	1259	356
175°	1291	1284	1286	1292	1283	123
180°	1288	1288	1288	1288	1288	

TEST NUMBER: P925259

CATALOG NUMBER: DFN2DIP-PN4F0-120D040US950-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4731.5	4731.5	4731.5	4731.5	4731.5
2.5°	4752.8	4731.5	4684.2	4727.4	4718.7
5°	4731.5	4710.1	4654.2	4692.8	4680.1
7.5°	4692.8	4667.3	4607.4	4624.2	4602.9
10°	4641.5	4611.5	4526.1	4512.9	4487.5
12.5°	4577.4	4538.8	4422.9	4397.6	4350.3
15°	4500.2	4453.0	4307.6	4226.2	4183.6
17.5°	4410.2	4341.7	4161.7	4067.8	3999.2
20°	4307.6	4221.7	4007.8	3901.0	3806.5
22.5°	4196.3	4097.7	3849.2	3703.8	3639.8
25°	4085.0	3947.7	3665.2	3489.8	3425.3
27.5°	3952.3	3806.5	3493.9	3292.7	3194.1
30°	3811.0	3648.0	3305.4	3087.3	2971.5
32.5°	3673.9	3476.7	3126.0	2868.9	2761.6
35°	3519.9	3301.3	2924.7	2654.9	2560.3
37.5°	3369.9	3134.2	2736.2	2440.4	2333.7
40°	3211.4	2954.7	2539.1	2235.1	2123.8
42.5°	3048.7	2774.8	2342.4	2025.2	1918.5
45°	2877.5	2590.4	2141.1	1836.7	1734.0
47.5°	2714.8	2410.9	1948.4	1644.1	1550.1
50°	2535.0	2231.0	1759.9	1464.2	1374.7
52.5°	2359.1	2037.9	1580.0	1297.4	1216.2
55°	2187.9	1854.0	1391.5	1134.8	1053.5
57.5°	2012.5	1670.0	1224.7	984.9	916.3
60°	1832.6	1490.1	1048.9	830.9	762.3
62.5°	1657.3	1314.7	899.0	693.7	659.6
65°	1477.4	1130.3	745.1	599.7	586.5
67.5°	1306.1	959.0	599.7	526.5	513.8
70°	1126.2	792.3	496.6	453.8	436.6
72.5°	955.0	637.8	415.2	381.1	372.5
75°	787.7	487.9	342.6	312.5	308.4
77.5°	621.1	346.6	269.9	252.6	243.9
80°	466.6	248.5	205.3	188.5	188.5
82.5°	325.3	167.1	141.3	132.6	132.6
85°	184.0	94.1	81.3	81.3	81.3
87.5°	68.6	34.1	34.1	30.0	30.0
90°	0.9	11.2	18.6	23.4	25.1
92.5°	23.4	19.6	22.3	24.2	25.1
95°	60.5	29.8	36.3	41.0	40.1
97.5°	109.0	32.6	47.5	50.4	51.2
100°	164.9	37.3	53.1	60.5	62.4
102.5°	226.4	224.7	55.0	65.2	68.0
105°	283.2	311.3	56.9	67.1	70.8
107.5°	349.5	372.7	58.8	69.0	72.7
110°	412.9	432.4	163.1	69.9	73.6

TEST NUMBER: P925259

CATALOG NUMBER: DFN2DIP-PN4F0-120D040US950-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	472.5	489.2	473.4	71.7	74.6
115°	535.8	551.6	575.0	143.5	76.5
117.5°	590.8	609.4	625.3	492.0	247.8
120°	652.3	666.3	683.1	694.3	568.5
122.5°	704.4	719.4	738.1	743.6	744.6
125°	757.6	769.8	787.4	794.0	796.8
127.5°	806.0	819.1	833.1	842.5	843.3
130°	851.7	866.7	876.8	887.1	886.3
132.5°	898.3	910.5	920.7	929.1	928.2
135°	937.5	952.5	960.8	970.1	968.3
137.5°	978.4	989.6	999.0	1008.3	1005.5
140°	1018.5	1026.0	1036.2	1044.6	1040.0
142.5°	1052.2	1058.7	1070.8	1078.1	1073.5
145°	1087.6	1086.6	1102.3	1108.9	1104.3
147.5°	1118.2	1115.4	1131.3	1135.9	1132.3
150°	1148.0	1141.6	1156.5	1162.1	1157.4
152.5°	1173.2	1165.8	1179.7	1185.3	1178.9
155°	1197.5	1189.2	1200.3	1205.9	1198.4
157.5°	1217.0	1209.6	1218.1	1224.6	1217.0
160°	1233.8	1228.2	1233.8	1239.3	1232.9
162.5°	1248.7	1243.2	1247.8	1254.3	1245.9
165°	1261.8	1256.2	1259.0	1265.5	1259.0
167.5°	1272.1	1266.3	1269.3	1275.8	1267.4
170°	1280.5	1274.8	1276.6	1283.2	1274.8
172.5°	1286.0	1280.5	1282.4	1288.9	1280.5
175°	1290.6	1284.1	1286.0	1292.5	1283.2
177.5°	1292.5	1286.0	1286.9	1293.5	1285.1
180°	1287.9	1287.9	1287.9	1287.9	1287.9

TEST NUMBER: P925259

CATALOG NUMBER: DFN2DIP-PN4F0-120D040US950-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.31	14.36	14.06	15.13	16.05	9.28	10.33	10.03	11.09	12.01
	3H	15.01	15.95	15.77	16.72	17.67	10.48	11.42	11.25	12.20	13.15
	4H	15.63	16.51	16.41	17.30	18.26	10.94	11.83	11.72	12.61	13.58
	6H	16.06	16.88	16.86	17.67	18.65	11.28	12.09	12.07	12.88	13.86
	8H	16.20	16.97	17.00	17.79	18.76	11.37	12.15	12.18	12.96	13.94
	12H	16.27	17.01	17.08	17.81	18.82	11.42	12.16	12.23	12.97	13.97
4H	2H	13.36	14.24	14.14	15.03	15.99	9.90	10.79	10.68	11.57	12.53
	3H	15.21	15.94	16.01	16.76	17.74	11.27	12.01	12.07	12.82	13.80
	4H	15.91	16.58	16.72	17.40	18.40	11.83	12.49	12.64	13.31	14.32
	6H	16.44	17.02	17.27	17.86	18.87	12.26	12.84	13.09	13.68	14.69
	8H	16.62	17.16	17.45	18.00	19.02	12.39	12.93	13.22	13.77	14.79
	12H	16.73	17.21	17.58	18.07	19.10	12.47	12.95	13.32	13.81	14.84
8H	4H	15.90	16.43	16.73	17.27	18.30	12.13	12.66	12.96	13.50	14.53
	6H	16.47	16.92	17.33	17.80	18.82	12.65	13.10	13.51	13.98	15.00
	8H	16.69	17.09	17.56	17.96	19.01	12.85	13.24	13.72	14.12	15.16
	12H	16.84	17.19	17.71	18.06	19.16	12.98	13.32	13.85	14.19	15.29
12H	4H	15.86	16.34	16.71	17.20	18.23	12.14	12.62	12.99	13.48	14.51
	6H	16.45	16.84	17.32	17.72	18.76	12.70	13.10	13.57	13.98	15.02
	8H	16.68	17.03	17.55	17.90	18.99	12.93	13.27	13.80	14.14	15.24

END OF REPORT