

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P903492

Luminaire Tested: DFN2DIP-SQ2F0-040D030US830-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P903492
REPORT IS A COMBINATION OF REPORTS P899773 AND P896659
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ2F0-040D030US830-FLLFLL
Description: 2 foot, Square Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6234.9 lumens
Efficiency: N/A
Efficacy: 110.4 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.21' x L: 2.21' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 56.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9952
Total Harmonic Distortion (THDi): 0.069
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P903492

CATALOG NUMBER: DFN2DIP-SQ2F0-040D030US830-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P903492

CATALOG NUMBER: DFN2DIP-SQ2F0-040D030US830-FLLFL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	110	110	110	110	102	102	102	102	89	89	89		77	77	77		65
1	100	96	92	88	93	89	86	83	78	75	73		67	66	64		58
2	91	84	77	72	85	78	73	68	68	64	61		59	56	53		51
3	83	73	66	60	77	69	62	57	60	55	51		52	48	45		45
4	76	65	57	51	71	61	54	48	54	48	43		47	42	39		40
5	70	58	50	44	65	55	47	42	48	42	38		42	37	34		36
6	64	52	44	38	60	49	42	36	43	37	33		38	33	29		33
7	60	47	39	33	56	44	37	32	39	33	29		35	30	26		30
8	55	43	35	30	52	40	33	28	36	30	26		32	27	23		28
9	52	39	32	26	48	37	30	25	33	27	23		29	24	21		26
10	48	36	29	24	45	34	27	23	30	25	21		27	22	19		24

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3226	3226	3226
5°	3225	3174	3198
10°	3194	3124	3150
15°	3141	3066	3078
20°	3072	2987	3004
25°	3003	2895	2920
30°	2918	2808	2813
35°	2837	2708	2701
40°	2739	2605	2594
45°	2640	2503	2485
50°	2532	2395	2358
55°	2419	2270	2241
60°	2290	2123	2106
65°	2148	1969	1948
70°	1968	1782	1775
75°	1723	1558	1610
80°	1422	1271	1308
85°	962	802	822

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2640 cd/sqm

TEST NUMBER: P903492

CATALOG NUMBER: DFN2DIP-SQ2F0-040D030US830-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	138.1	2.2
10°-20°	388.5	6.2
20°-30°	570.9	9.2
30°-40°	663.1	10.6
40°-50°	662.3	10.6
50°-60°	577.5	9.3
60°-70°	426.9	6.8
70°-80°	241.5	3.9
80°-90°	66.3	1.1
90°-100°	55.3	0.9
100°-110°	175.8	2.8
110°-120°	300.9	4.8
120°-130°	395.7	6.3
130°-140°	444.2	7.1
140°-150°	435.6	7.0
150°-160°	365.4	5.9
160°-170°	242.3	3.9
170°-180°	84.7	1.4
0°-30°	1097.5	17.6
0°-40°	1760.6	28.2
0°-60°	3000.3	48.1
0°-90°	3735.0	59.9
90°-120°	532.1	8.5
90°-150°	1807.5	29.0
90°-180°	2500.0	40.1
0°-180°	6234.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1467	1467	1467	1467	1467	
5°	1467	1461	1446	1457	1454	139
15°	1396	1388	1370	1375	1368	393
25°	1264	1253	1229	1231	1229	582
35°	1090	1076	1054	1045	1038	681
45°	887	878	856	841	835	685
55°	672	663	646	629	622	600
65°	453	444	430	418	411	448
75°	237	234	227	219	222	253
85°	58	56	55	51	49	64
90°	1	10	26	25	26	6
95°	39	47	48	48	47	44
105°	162	164	166	167	167	171
115°	302	306	305	304	302	299
125°	439	446	444	441	440	392
135°	568	576	578	577	575	439
145°	690	695	699	700	697	431
155°	789	791	793	797	795	363
165°	858	857	857	862	859	242
175°	893	890	889	894	890	85
180°	894	894	894	894	894	

TEST NUMBER: P903492

CATALOG NUMBER: DFN2DIP-SQ2F0-040D030US830-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1467.0	1467.0	1467.0	1467.0	1467.0
2.5°	1475.5	1468.5	1452.9	1467.0	1464.3
5°	1467.0	1461.4	1445.9	1457.1	1454.4
7.5°	1457.1	1448.7	1433.1	1444.5	1441.7
10°	1441.7	1431.8	1414.9	1426.2	1421.9
12.5°	1420.4	1412.0	1395.2	1402.2	1399.3
15°	1396.5	1388.1	1369.7	1375.4	1368.4
17.5°	1366.9	1358.5	1340.1	1347.1	1340.1
20°	1334.4	1326.0	1306.3	1310.4	1304.9
22.5°	1302.0	1289.3	1270.9	1270.9	1268.1
25°	1263.9	1252.6	1228.7	1231.4	1228.7
27.5°	1221.5	1211.6	1193.4	1189.2	1182.2
30°	1179.3	1168.0	1146.9	1142.6	1137.0
32.5°	1134.2	1125.8	1103.2	1094.7	1088.9
35°	1090.4	1076.4	1053.8	1045.3	1038.2
37.5°	1041.0	1028.3	1005.7	995.9	988.8
40°	990.3	978.9	956.3	943.8	938.1
42.5°	940.9	929.5	907.1	892.9	884.5
45°	887.3	877.5	856.2	840.8	835.1
47.5°	835.1	825.2	802.7	787.1	778.7
50°	780.0	773.0	753.3	733.5	726.4
52.5°	726.4	716.6	698.3	682.8	672.9
55°	671.6	663.0	646.1	629.1	622.2
57.5°	616.4	609.4	591.0	574.1	568.4
60°	561.4	555.8	536.1	520.6	516.3
62.5°	507.8	497.9	483.9	469.8	464.1
65°	452.9	444.3	430.3	417.5	410.6
67.5°	396.4	389.3	376.7	366.8	361.2
70°	344.2	338.6	325.8	315.9	310.4
72.5°	290.7	284.9	278.0	268.1	263.8
75°	237.0	234.2	227.1	218.7	221.5
77.5°	189.0	183.3	180.5	176.3	172.1
80°	141.1	139.6	136.8	132.6	129.8
82.5°	96.0	96.0	94.6	88.9	88.9
85°	57.8	56.5	55.0	50.7	49.4
87.5°	25.4	22.6	19.8	15.6	14.0
90°	0.8	9.7	26.4	24.8	25.6
92.5°	16.7	22.6	23.5	24.2	24.2
95°	39.4	46.9	48.3	48.3	46.9
97.5°	65.5	72.5	75.5	75.5	75.5
100°	95.7	101.9	104.1	104.1	103.3
102.5°	127.5	132.1	135.1	135.9	135.1
105°	162.3	164.5	166.1	167.4	167.4
107.5°	196.8	200.0	200.0	200.6	196.8
110°	230.3	234.6	234.6	234.6	232.4

TEST NUMBER: P903492

CATALOG NUMBER: DFN2DIP-SQ2F0-040D030US830-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	266.4	271.0	270.1	268.0	266.4
115°	302.0	306.2	304.9	304.2	302.0
117.5°	337.2	343.2	339.4	337.2	335.1
120°	372.9	378.8	372.9	372.9	370.4
122.5°	405.2	412.7	409.0	406.8	405.2
125°	439.2	445.9	443.7	441.3	440.5
127.5°	472.3	480.7	477.8	474.5	472.3
130°	503.3	513.0	511.7	510.1	507.1
132.5°	538.1	545.6	546.2	542.4	540.3
135°	568.1	576.4	578.1	577.2	575.0
137.5°	601.4	608.2	609.5	609.1	605.8
140°	630.8	637.6	641.4	641.4	638.4
142.5°	661.1	667.8	670.0	670.8	667.8
145°	689.7	695.0	699.4	700.1	697.2
147.5°	715.3	722.0	725.2	726.6	723.6
150°	741.7	746.3	749.2	751.7	749.2
152.5°	765.2	769.7	773.5	776.5	773.5
155°	788.6	790.7	793.1	796.9	794.6
157.5°	808.8	810.4	811.8	817.2	813.4
160°	826.9	828.5	829.3	833.9	830.7
162.5°	843.6	843.6	844.4	849.5	845.7
165°	857.9	857.1	857.1	862.4	858.7
167.5°	870.8	868.4	868.4	873.7	870.0
170°	880.5	878.4	877.6	883.0	878.4
172.5°	887.2	885.1	884.3	889.7	885.1
175°	892.7	890.5	888.9	894.3	889.7
177.5°	895.6	893.4	891.8	896.5	891.8
180°	894.3	894.3	894.3	894.3	894.3

TEST NUMBER: P903492

CATALOG NUMBER: DFN2DIP-SQ2F0-040D030US830-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.09	13.05	12.96	13.94	15.06	11.65	12.61	12.51	13.49	14.62
	3H	13.74	14.60	14.62	15.50	16.65	13.25	14.11	14.13	15.01	16.16
	4H	14.32	15.13	15.21	16.04	17.19	13.83	14.64	14.72	15.54	16.70
	6H	14.71	15.46	15.62	16.37	17.54	14.21	14.96	15.12	15.87	17.04
	8H	14.81	15.52	15.72	16.45	17.62	14.31	15.02	15.22	15.95	17.12
	12H	14.85	15.53	15.77	16.46	17.65	14.35	15.03	15.27	15.95	17.14
4H	2H	12.55	13.37	13.45	14.27	15.43	12.20	13.01	13.10	13.91	15.07
	3H	14.41	15.08	15.32	16.02	17.19	14.00	14.68	14.91	15.61	16.78
	4H	15.11	15.73	16.03	16.66	17.86	14.68	15.30	15.61	16.23	17.43
	6H	15.61	16.14	16.55	17.10	18.30	15.18	15.71	16.11	16.67	17.87
	8H	15.75	16.25	16.69	17.20	18.41	15.32	15.82	16.25	16.76	17.98
	12H	15.82	16.27	16.78	17.24	18.46	15.37	15.82	16.33	16.79	18.01
8H	4H	15.30	15.80	16.24	16.75	17.96	14.92	15.42	15.86	16.37	17.58
	6H	15.91	16.33	16.88	17.32	18.53	15.53	15.94	16.49	16.93	18.14
	8H	16.12	16.49	17.09	17.47	18.70	15.73	16.09	16.70	17.07	18.30
	12H	16.24	16.57	17.22	17.54	18.82	15.83	16.16	16.81	17.13	18.41
12H	4H	15.29	15.74	16.25	16.71	17.92	14.92	15.37	15.88	16.34	17.55
	6H	15.94	16.30	16.91	17.28	18.51	15.56	15.93	16.54	16.91	18.14
	8H	16.17	16.49	17.15	17.46	18.74	15.79	16.11	16.77	17.08	18.36