

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P906609

Luminaire Tested: DFN2DIP-SQ3F0-110D080US835-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P906609
REPORT IS A COMBINATION OF REPORTS P901467 AND P898289
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ3F0-110D080US835-FLLONL
Description: 3 foot, Square Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 18810.0 lumens
Efficiency: N/A
Efficacy: 109.2 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.06' x L: 3.06' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 172.3
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9977
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P906609

CATALOG NUMBER: DFN2DIP-SQ3F0-110D080US835-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P906609

CATALOG NUMBER: DFN2DIP-SQ3F0-110D080US835-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	109	109	109	109	102	102	102	102	88	88	88		75	75	75		63
1	100	95	91	88	93	89	85	82	77	74	72		66	64	63		56
2	91	83	77	72	84	78	72	68	67	63	60		58	55	52		49
3	83	73	66	60	77	68	62	57	60	54	50		51	47	44		44
4	76	65	57	51	70	61	54	48	53	47	43		46	41	38		39
5	70	58	50	43	65	54	47	41	47	42	37		41	37	33		35
6	64	52	44	38	60	49	41	36	43	37	32		37	32	29		32
7	59	47	39	33	55	44	37	32	39	33	29		34	29	26		29
8	55	43	35	29	51	40	33	28	35	30	25		31	26	23		27
9	51	39	31	26	48	37	30	25	33	27	23		29	24	21		25
10	48	36	28	24	45	34	27	23	30	24	21		26	22	19		23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4904	4904	4904
5°	4909	4833	4867
10°	4866	4764	4799
15°	4791	4683	4695
20°	4692	4570	4588
25°	4592	4437	4464
30°	4468	4312	4308
35°	4351	4166	4142
40°	4207	4018	3985
45°	4063	3869	3824
50°	3905	3713	3637
55°	3740	3533	3465
60°	3553	3319	3268
65°	3348	3097	3035
70°	3088	2826	2784
75°	2728	2502	2551
80°	2293	2087	2108
85°	1614	1383	1380

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4063 cd/sqm

TEST NUMBER: P906609

CATALOG NUMBER: DFN2DIP-SQ3F0-110D080US835-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	402.8	2.1
10°-20°	1133.5	6.0
20°-30°	1665.7	8.9
30°-40°	1934.7	10.3
40°-50°	1932.3	10.3
50°-60°	1684.9	9.0
60°-70°	1245.5	6.6
70°-80°	704.7	3.7
80°-90°	190.7	1.0
90°-100°	89.0	0.5
100°-110°	331.9	1.8
110°-120°	880.2	4.7
120°-130°	1459.9	7.8
130°-140°	1550.7	8.2
140°-150°	1441.2	7.7
150°-160°	1158.7	6.2
160°-170°	746.6	4.0
170°-180°	257.0	1.4
0°-30°	3202.1	17.0
0°-40°	5136.7	27.3
0°-60°	8753.8	46.5
0°-90°	10894.7	57.9
90°-120°	1301.1	6.9
90°-150°	5752.9	30.6
90°-180°	7915.0	42.1
0°-180°	18810.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4280	4280	4280	4280	4280	
5°	4280	4264	4219	4251	4244	406
15°	4074	4050	3996	4013	3992	1148
25°	3688	3655	3585	3593	3585	1697
35°	3182	3140	3074	3050	3029	1987
45°	2589	2560	2498	2453	2437	1998
55°	1959	1934	1885	1836	1815	1752
65°	1321	1296	1255	1218	1198	1306
75°	691	683	662	638	646	738
85°	169	165	161	148	144	188
90°	2	23	39	49	53	17
95°	127	62	76	86	84	150
105°	594	653	119	141	148	635
115°	1123	1156	1205	301	160	1106
125°	1588	1614	1651	1664	1670	1416
135°	1965	1997	2014	2034	2030	1518
145°	2280	2278	2311	2325	2315	1426
155°	2510	2493	2516	2528	2512	1157
165°	2645	2634	2639	2653	2639	747
175°	2706	2692	2696	2710	2690	258
180°	2700	2700	2700	2700	2700	

TEST NUMBER: P906609

CATALOG NUMBER: DFN2DIP-SQ3F0-110D080US835-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4280.2	4280.2	4280.2	4280.2	4280.2
2.5°	4305.0	4284.5	4239.1	4280.2	4272.3
5°	4280.2	4264.0	4218.6	4251.3	4243.5
7.5°	4251.3	4226.9	4181.5	4214.7	4206.4
10°	4206.4	4177.5	4128.2	4160.9	4148.7
12.5°	4144.4	4119.9	4070.6	4091.1	4082.8
15°	4074.5	4050.0	3996.3	4012.9	3992.4
17.5°	3988.0	3963.6	3909.9	3930.4	3909.9
20°	3893.3	3868.8	3811.2	3823.4	3807.3
22.5°	3799.0	3761.8	3708.1	3708.1	3699.8
25°	3687.6	3654.9	3585.0	3592.9	3585.0
27.5°	3564.0	3535.2	3481.9	3469.7	3449.2
30°	3440.9	3407.7	3346.1	3333.9	3317.3
32.5°	3309.0	3284.6	3218.6	3193.7	3177.1
35°	3181.5	3140.5	3074.5	3049.6	3029.1
37.5°	3037.4	3000.3	2934.4	2905.5	2885.0
40°	2889.4	2856.2	2790.3	2753.6	2737.0
42.5°	2745.3	2712.1	2646.6	2605.1	2580.7
45°	2589.0	2560.1	2498.1	2453.2	2436.6
47.5°	2436.6	2407.8	2341.8	2296.4	2271.9
50°	2275.9	2255.4	2197.7	2140.1	2119.6
52.5°	2119.6	2090.7	2037.5	1992.0	1963.2
55°	1959.3	1934.4	1885.1	1835.7	1815.2
57.5°	1798.6	1778.1	1724.4	1675.0	1658.4
60°	1637.9	1621.8	1564.1	1518.7	1506.5
62.5°	1481.6	1452.8	1411.7	1370.7	1354.1
65°	1321.3	1296.4	1255.4	1218.3	1197.8
67.5°	1156.7	1135.8	1099.1	1070.3	1053.7
70°	1004.3	987.7	950.6	921.8	905.6
72.5°	848.0	831.4	810.9	782.1	769.8
75°	691.2	683.4	662.4	638.0	646.3
77.5°	551.5	534.9	526.6	514.4	502.2
80°	411.8	407.4	399.1	386.9	378.6
82.5°	279.9	279.9	276.0	259.4	259.4
85°	168.6	164.6	160.7	148.0	144.1
87.5°	74.2	65.9	57.6	45.4	41.0
90°	1.9	23.4	39.0	48.9	52.7
92.5°	48.9	41.1	46.9	50.8	52.7
95°	126.9	62.4	76.1	86.1	84.0
97.5°	228.5	68.4	99.5	105.6	107.4
100°	345.9	78.2	111.4	126.9	130.8
102.5°	474.7	470.9	115.3	136.6	142.7
105°	593.9	652.6	119.2	140.6	148.5
107.5°	732.6	781.3	123.2	144.5	152.4
110°	865.6	906.4	342.0	146.6	154.3

TEST NUMBER: P906609

CATALOG NUMBER: DFN2DIP-SQ3F0-110D080US835-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	990.6	1025.6	992.5	150.3	156.4
115°	1123.3	1156.5	1205.4	300.9	160.3
117.5°	1238.6	1277.6	1311.0	1031.4	519.7
120°	1367.6	1396.8	1432.1	1455.5	1191.7
122.5°	1476.8	1508.2	1547.4	1559.0	1561.1
125°	1588.2	1613.7	1650.8	1664.5	1670.3
127.5°	1689.8	1717.2	1746.7	1766.1	1768.0
130°	1785.6	1816.9	1838.3	1859.9	1858.0
132.5°	1883.3	1908.8	1930.2	1947.8	1945.9
135°	1965.4	1996.7	2014.1	2033.9	2029.9
137.5°	2051.3	2074.7	2094.4	2113.9	2108.1
140°	2135.2	2151.0	2172.4	2190.0	2180.2
142.5°	2205.8	2219.4	2244.7	2260.3	2250.5
145°	2280.0	2277.9	2311.1	2324.8	2315.0
147.5°	2344.3	2338.5	2371.6	2381.4	2373.7
150°	2406.9	2393.2	2424.5	2436.1	2426.4
152.5°	2459.6	2444.0	2473.2	2485.1	2471.4
155°	2510.4	2493.0	2516.4	2528.0	2512.5
157.5°	2551.4	2535.9	2553.5	2567.2	2551.4
160°	2586.7	2574.9	2586.7	2598.3	2584.6
162.5°	2617.8	2606.2	2615.9	2629.6	2612.0
165°	2645.2	2633.6	2639.4	2653.0	2639.4
167.5°	2666.7	2654.9	2660.9	2674.6	2657.0
170°	2684.4	2672.5	2676.5	2690.2	2672.5
172.5°	2696.0	2684.4	2688.3	2702.0	2684.4
175°	2705.7	2692.0	2696.0	2709.6	2690.2
177.5°	2709.6	2696.0	2698.0	2711.7	2694.1
180°	2699.9	2699.9	2699.9	2699.9	2699.9

TEST NUMBER: P906609

CATALOG NUMBER: DFN2DIP-SQ3F0-110D080US835-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.46	14.40	14.35	15.31	16.46	13.02	13.96	13.90	14.86	16.02
	3H	15.12	15.97	16.02	16.88	18.06	14.63	15.48	15.53	16.39	17.57
	4H	15.71	16.51	16.63	17.43	18.62	15.22	16.01	16.13	16.94	18.12
	6H	16.11	16.85	17.04	17.77	18.98	15.61	16.35	16.54	17.27	18.48
	8H	16.22	16.92	17.15	17.86	19.06	15.72	16.41	16.65	17.36	18.56
	12H	16.27	16.93	17.21	17.87	19.10	15.76	16.42	16.70	17.36	18.59
4H	2H	13.93	14.73	14.85	15.65	16.83	13.57	14.37	14.49	15.29	16.48
	3H	15.80	16.46	16.73	17.41	18.62	15.39	16.05	16.32	17.01	18.21
	4H	16.51	17.12	17.45	18.06	19.29	16.09	16.69	17.03	17.64	18.87
	6H	17.03	17.55	17.98	18.52	19.75	16.59	17.12	17.55	18.09	19.32
	8H	17.17	17.66	18.13	18.63	19.87	16.74	17.23	17.69	18.19	19.43
	12H	17.25	17.69	18.22	18.67	19.92	16.80	17.24	17.77	18.22	19.47
8H	4H	16.71	17.20	17.66	18.16	19.40	16.33	16.82	17.29	17.79	19.03
	6H	17.34	17.74	18.32	18.75	19.99	16.95	17.36	17.93	18.36	19.60
	8H	17.56	17.91	18.55	18.91	20.17	17.16	17.52	18.15	18.52	19.77
	12H	17.69	18.00	18.68	18.99	20.30	17.28	17.59	18.27	18.58	19.89
12H	4H	16.70	17.14	17.67	18.12	19.37	16.33	16.77	17.30	17.75	19.00
	6H	17.37	17.72	18.36	18.72	19.98	16.99	17.35	17.98	18.35	19.61
	8H	17.61	17.92	18.60	18.91	20.22	17.23	17.54	18.22	18.53	19.84