

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P909380

Luminaire Tested: DFN2DIP-SQ3F0-120D100US840-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P909380
REPORT IS A COMBINATION OF REPORTS P899985 AND P896733
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ3F0-120D100US840-FLLFLL
Description: 3 foot, Square Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 20934.5 lumens
Efficiency: N/A
Efficacy: 103.0 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.06' x L: 3.06' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 203.3
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9957
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P909380

CATALOG NUMBER: DFN2DIP-SQ3F0-120D100US840-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P909380

CATALOG NUMBER: DFN2DIP-SQ3F0-120D100US840-FLLFL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	109	109	109	109	101	101	101	101	87	87	87		75	75	75		63
1	99	95	91	88	92	89	85	82	77	74	72		66	64	62		56
2	91	83	77	72	84	78	72	67	67	63	60		58	55	52		49
3	83	73	66	60	77	68	62	56	59	54	50		51	47	44		43
4	76	65	57	51	70	61	53	48	53	47	43		46	41	38		39
5	69	58	49	43	64	54	47	41	47	41	37		41	36	33		35
6	64	52	44	38	59	49	41	36	43	37	32		37	32	29		32
7	59	47	39	33	55	44	37	32	39	33	28		34	29	25		29
8	55	43	35	29	51	40	33	28	35	29	25		31	26	23		27
9	51	39	31	26	48	37	30	25	32	27	23		28	24	20		25
10	48	36	28	24	45	34	27	23	30	24	21		26	22	19		23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5403	5403	5403
5°	5408	5324	5362
10°	5361	5249	5287
15°	5279	5159	5172
20°	5168	5035	5054
25°	5059	4888	4918
30°	4923	4751	4746
35°	4793	4589	4564
40°	4634	4426	4390
45°	4476	4263	4212
50°	4302	4091	4006
55°	4120	3892	3817
60°	3914	3656	3600
65°	3689	3412	3344
70°	3402	3114	3067
75°	3005	2756	2810
80°	2526	2300	2322
85°	1778	1523	1521

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4476 cd/sqm

TEST NUMBER: P909380

CATALOG NUMBER: DFN2DIP-SQ3F0-120D100US840-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	443.8	2.1
10°-20°	1248.7	6.0
20°-30°	1835.1	8.8
30°-40°	2131.4	10.2
40°-50°	2128.7	10.2
50°-60°	1856.2	8.9
60°-70°	1372.1	6.6
70°-80°	776.3	3.7
80°-90°	214.0	1.0
90°-100°	197.6	0.9
100°-110°	627.9	3.0
110°-120°	1074.6	5.1
120°-130°	1413.3	6.8
130°-140°	1586.4	7.6
140°-150°	1555.6	7.4
150°-160°	1304.9	6.2
160°-170°	865.4	4.1
170°-180°	302.5	1.4
0°-30°	3527.6	16.9
0°-40°	5659.0	27.0
0°-60°	9643.8	46.1
0°-90°	12006.2	57.4
90°-120°	1900.2	9.1
90°-150°	6455.4	30.8
90°-180°	8928.0	42.6
0°-180°	20934.5	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4715	4715	4715	4715	4715	
5°	4715	4698	4648	4684	4675	448
15°	4489	4462	4403	4421	4398	1264
25°	4062	4026	3950	3958	3950	1869
35°	3505	3460	3387	3360	3337	2189
45°	2852	2820	2752	2703	2684	2201
55°	2158	2131	2077	2022	2000	1930
65°	1456	1428	1383	1342	1320	1439
75°	762	753	730	703	712	813
85°	186	181	177	163	159	207
90°	3	35	94	89	92	20
95°	141	168	172	172	168	156
105°	580	587	593	598	598	612
115°	1078	1094	1089	1086	1078	1067
125°	1568	1593	1585	1576	1573	1402
135°	2029	2059	2064	2062	2054	1568
145°	2463	2482	2498	2500	2490	1539
155°	2816	2824	2833	2846	2838	1296
165°	3064	3061	3061	3080	3067	864
175°	3188	3180	3175	3194	3177	303
180°	3194	3194	3194	3194	3194	

TEST NUMBER: P909380

CATALOG NUMBER: DFN2DIP-SQ3F0-120D100US840-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4715.4	4715.4	4715.4	4715.4	4715.4
2.5°	4742.7	4720.1	4670.1	4715.4	4706.7
5°	4715.4	4697.5	4647.5	4683.6	4674.9
7.5°	4683.6	4656.6	4606.6	4643.2	4634.1
10°	4634.1	4602.3	4547.9	4584.0	4570.6
12.5°	4565.7	4538.7	4484.4	4507.0	4497.8
15°	4488.8	4461.8	4402.6	4420.9	4398.3
17.5°	4393.5	4366.6	4307.4	4330.0	4307.4
20°	4289.1	4262.1	4198.7	4212.1	4194.4
22.5°	4185.2	4144.3	4085.1	4085.1	4076.0
25°	4062.5	4026.4	3949.5	3958.2	3949.5
27.5°	3926.4	3894.6	3836.0	3822.4	3799.9
30°	3790.7	3754.2	3686.3	3672.9	3654.6
32.5°	3645.4	3618.6	3545.8	3518.5	3500.2
35°	3504.9	3459.8	3387.1	3359.7	3337.1
37.5°	3346.2	3305.4	3232.7	3201.0	3178.3
40°	3183.2	3146.6	3073.9	3033.5	3015.3
42.5°	3024.4	2987.9	2915.7	2870.0	2843.1
45°	2852.2	2820.5	2752.1	2702.6	2684.3
47.5°	2684.3	2652.5	2579.9	2529.9	2503.0
50°	2507.3	2484.7	2421.2	2357.6	2335.0
52.5°	2335.0	2303.3	2244.6	2194.5	2162.8
55°	2158.5	2131.1	2076.7	2022.4	1999.7
57.5°	1981.5	1958.8	1899.7	1845.3	1827.0
60°	1804.4	1786.7	1723.1	1673.1	1659.6
62.5°	1632.2	1600.4	1555.3	1510.1	1491.8
65°	1455.7	1428.3	1383.0	1342.1	1319.6
67.5°	1274.3	1251.2	1210.8	1179.1	1160.8
70°	1106.4	1088.1	1047.2	1015.5	997.7
72.5°	934.2	915.9	893.3	861.6	848.1
75°	761.5	752.9	729.7	702.9	712.0
77.5°	607.5	589.3	580.2	566.6	553.2
80°	453.6	448.8	439.7	426.3	417.1
82.5°	308.3	308.3	304.1	285.8	285.8
85°	185.7	181.4	177.0	163.1	158.8
87.5°	81.8	72.6	63.5	50.0	45.2
90°	2.9	34.6	94.3	88.6	91.5
92.5°	59.7	80.9	83.8	86.6	86.6
95°	140.6	167.5	172.4	172.4	167.5
97.5°	234.0	259.0	269.6	269.6	269.6
100°	341.8	364.0	371.6	371.6	368.8
102.5°	455.4	471.8	482.4	485.2	482.4
105°	579.7	587.3	593.1	597.9	597.9
107.5°	702.9	714.5	714.5	716.4	702.9
110°	822.3	837.7	837.7	837.7	830.0

TEST NUMBER: P909380

CATALOG NUMBER: DFN2DIP-SQ3F0-120D100US840-FLLFL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	951.3	967.7	964.8	957.0	951.3
115°	1078.4	1093.8	1089.0	1086.1	1078.4
117.5°	1204.6	1225.8	1212.2	1204.6	1196.8
120°	1331.6	1352.8	1331.6	1331.6	1323.0
122.5°	1447.1	1474.1	1460.7	1453.0	1447.1
125°	1568.5	1592.6	1584.9	1576.2	1573.4
127.5°	1687.0	1716.8	1706.2	1694.7	1687.0
130°	1797.7	1832.3	1827.6	1821.7	1811.2
132.5°	1921.9	1948.8	1950.8	1937.3	1929.6
135°	2028.7	2058.6	2064.4	2061.5	2053.8
137.5°	2148.2	2172.2	2177.1	2175.1	2163.5
140°	2253.1	2277.1	2290.7	2290.7	2280.1
142.5°	2361.0	2385.0	2392.7	2395.6	2385.0
145°	2463.0	2482.2	2497.7	2500.5	2489.9
147.5°	2554.5	2578.6	2590.1	2595.0	2584.3
150°	2648.9	2665.2	2675.8	2684.4	2675.8
152.5°	2732.6	2749.0	2762.5	2773.1	2762.5
155°	2816.4	2824.1	2832.8	2846.2	2837.5
157.5°	2888.6	2894.4	2899.2	2918.4	2905.0
160°	2953.1	2958.9	2961.7	2978.1	2966.6
162.5°	3012.8	3012.8	3015.7	3033.9	3020.5
165°	3063.8	3060.9	3060.9	3080.2	3066.8
167.5°	3110.1	3101.4	3101.4	3120.7	3107.2
170°	3144.7	3137.0	3134.1	3153.4	3137.0
172.5°	3168.8	3161.1	3158.2	3177.4	3161.1
175°	3188.0	3180.4	3174.6	3193.8	3177.4
177.5°	3198.6	3191.0	3185.1	3201.5	3185.1
180°	3193.8	3193.8	3193.8	3193.8	3193.8

TEST NUMBER: P909380

CATALOG NUMBER: DFN2DIP-SQ3F0-120D100US840-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.75	14.68	14.64	15.59	16.76	13.31	14.24	14.20	15.15	16.31
	3H	15.41	16.25	16.31	17.17	18.36	14.92	15.76	15.82	16.68	17.87
	4H	16.00	16.79	16.92	17.72	18.91	15.50	16.30	16.42	17.22	18.42
	6H	16.40	17.13	17.33	18.06	19.27	15.90	16.63	16.83	17.56	18.77
	8H	16.50	17.20	17.44	18.15	19.36	16.00	16.70	16.94	17.65	18.85
	12H	16.55	17.21	17.50	18.16	19.39	16.04	16.70	16.99	17.65	18.88
4H	2H	14.22	15.01	15.14	15.93	17.13	13.86	14.65	14.78	15.58	16.77
	3H	16.08	16.74	17.02	17.70	18.91	15.67	16.33	16.61	17.29	18.50
	4H	16.80	17.40	17.74	18.35	19.59	16.37	16.97	17.32	17.93	19.16
	6H	17.31	17.83	18.27	18.81	20.04	16.88	17.40	17.84	18.37	19.61
	8H	17.46	17.95	18.42	18.91	20.16	17.02	17.51	17.98	18.48	19.73
	12H	17.53	17.97	18.51	18.96	20.21	17.09	17.52	18.06	18.51	19.77
8H	4H	16.99	17.48	17.95	18.45	19.70	16.62	17.10	17.58	18.07	19.32
	6H	17.62	18.02	18.61	19.03	20.28	17.24	17.64	18.22	18.65	19.90
	8H	17.84	18.20	18.83	19.19	20.46	17.45	17.80	18.44	18.80	20.07
	12H	17.97	18.28	18.97	19.28	20.59	17.56	17.87	18.56	18.87	20.18
12H	4H	16.98	17.42	17.96	18.41	19.66	16.61	17.05	17.59	18.04	19.29
	6H	17.65	18.01	18.65	19.01	20.27	17.28	17.63	18.27	18.63	19.90
	8H	17.89	18.20	18.89	19.20	20.51	17.51	17.82	18.51	18.82	20.13