

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P917279

Luminaire Tested: DFN2DIP-SQ3F0-040D100US930-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P917279
REPORT IS A COMBINATION OF REPORTS P901490 AND P898289
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ3F0-040D100US930-RLLONL
Description: 3 foot, Square Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 10843.5 lumens
Efficiency: N/A
Efficacy: 98.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.06' x L: 3.06' x H: 0.1')
CIE Type: Semi-Indirect

Input Watts (W): 109.8
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9933
Total Harmonic Distortion (THDi): 0.066
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P917279

CATALOG NUMBER: DFN2DIP-SQ3F0-040D100US930-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P917279

CATALOG NUMBER: DFN2DIP-SQ3F0-040D100US930-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					0
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	101	101	101	101		90	90	90	90		70	70	70		51	51	51		34	34	34
1	93	88	85	82		82	79	76	73		61	59	58		45	44	43		30	29	29
2	84	77	72	67		75	69	65	60		54	51	48		40	38	36		27	26	25
3	77	68	61	56		69	61	55	51		48	44	41		35	33	31		24	23	21
4	71	60	53	47		63	54	48	43		43	38	35		32	29	26		22	20	19
5	65	54	46	41		58	48	42	37		38	33	30		28	25	23		19	18	16
6	60	48	41	35		53	43	37	32		34	30	26		26	23	20		18	16	14
7	55	43	36	31		49	39	33	28		31	26	23		23	20	18		16	14	13
8	51	39	32	27		45	36	29	25		28	24	20		21	18	16		15	13	12
9	47	36	29	24		42	32	26	22		26	21	18		20	16	14		14	12	10
10	44	33	26	21		39	30	24	20		24	19	16		18	15	13		13	11	10

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1544	1544	1544
5°	1546	1519	1529
10°	1530	1488	1479
15°	1508	1438	1401
20°	1479	1369	1307
25°	1449	1292	1215
30°	1410	1213	1099
35°	1371	1129	997
40°	1332	1042	881
45°	1286	945	775
50°	1239	847	672
55°	1190	743	573
60°	1132	634	471
65°	1067	524	423
70°	986	421	382
75°	886	369	347
80°	740	306	299
85°	502	200	222

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 90°

Luminance: 1882 cd/sqm

TEST NUMBER: P917279

CATALOG NUMBER: DFN2DIP-SQ3F0-040D100US930-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	126.3	1.2
10°-20°	346.8	3.2
20°-30°	486.9	4.5
30°-40°	530.7	4.9
40°-50°	487.8	4.5
50°-60°	383.1	3.5
60°-70°	249.3	2.3
70°-80°	128.4	1.2
80°-90°	37.6	0.3
90°-100°	90.7	0.8
100°-110°	338.2	3.1
110°-120°	897.0	8.3
120°-130°	1487.8	13.7
130°-140°	1580.4	14.6
140°-150°	1468.8	13.5
150°-160°	1180.9	10.9
160°-170°	760.9	7.0
170°-180°	261.9	2.4
0°-30°	960.0	8.9
0°-40°	1490.7	13.7
0°-60°	2361.5	21.8
0°-90°	2776.9	25.6
90°-120°	1326.0	12.2
90°-150°	5862.9	54.1
90°-180°	8067.0	74.4
0°-180°	10843.5	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1348	1348	1348	1348	1348	
5°	1348	1342	1326	1337	1333	128
15°	1282	1268	1227	1204	1192	361
25°	1164	1125	1044	994	976	535
35°	1003	940	833	756	729	628
45°	820	738	610	523	494	633
55°	623	528	396	323	300	557
65°	421	322	212	171	167	417
75°	224	139	98	89	88	237
85°	52	27	23	23	23	60
90°	2	24	40	50	54	10
95°	129	64	78	88	86	153
105°	605	665	122	143	151	647
115°	1145	1179	1228	307	163	1127
125°	1619	1645	1682	1696	1702	1444
135°	2003	2035	2053	2073	2069	1547
145°	2324	2322	2355	2369	2359	1453
155°	2558	2541	2564	2576	2560	1179
165°	2696	2684	2690	2704	2690	762
175°	2757	2744	2748	2762	2742	262
180°	2752	2752	2752	2752	2752	

TEST NUMBER: P917279

CATALOG NUMBER: DFN2DIP-SQ3F0-040D100US930-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1347.9	1347.9	1347.9	1347.9	1347.9
2.5°	1354.0	1347.9	1334.4	1346.7	1344.2
5°	1347.9	1341.7	1325.8	1336.8	1333.3
7.5°	1336.8	1329.6	1312.5	1317.3	1311.2
10°	1322.3	1313.7	1289.3	1285.6	1278.4
12.5°	1304.0	1293.0	1260.0	1252.7	1239.3
15°	1282.0	1268.5	1227.1	1204.0	1191.8
17.5°	1256.4	1236.8	1185.5	1158.8	1139.2
20°	1227.1	1202.6	1141.7	1111.3	1084.3
22.5°	1195.4	1167.3	1096.5	1055.1	1036.9
25°	1163.7	1124.6	1044.1	994.2	975.7
27.5°	1125.9	1084.3	995.3	938.0	909.9
30°	1085.7	1039.2	941.6	879.5	846.5
32.5°	1046.6	990.4	890.5	817.3	786.7
35°	1002.7	940.4	833.2	756.3	729.4
37.5°	960.0	892.8	779.4	695.2	664.8
40°	914.8	841.7	723.3	636.7	605.0
42.5°	868.5	790.4	667.2	576.9	546.5
45°	819.7	737.9	609.9	523.3	494.0
47.5°	773.4	686.8	555.1	468.4	441.6
50°	722.1	635.5	501.3	417.1	391.6
52.5°	672.1	580.6	450.1	369.6	346.4
55°	623.3	528.2	396.4	323.3	300.1
57.5°	573.3	475.7	348.9	280.5	261.1
60°	522.0	424.4	298.8	236.7	217.2
62.5°	472.1	374.5	256.1	197.6	187.9
65°	420.9	322.0	212.2	170.8	167.1
67.5°	372.1	273.2	170.8	150.0	146.3
70°	320.8	225.7	141.5	129.3	124.3
72.5°	272.1	181.7	118.3	108.6	106.2
75°	224.4	139.0	97.6	89.0	87.9
77.5°	176.9	98.7	76.9	72.0	69.5
80°	132.9	70.8	58.5	53.7	53.7
82.5°	92.7	47.6	40.3	37.7	37.7
85°	52.4	26.8	23.2	23.2	23.2
87.5°	19.6	9.7	9.7	8.6	8.6
90°	1.9	23.9	39.7	49.9	53.6
92.5°	49.9	41.8	47.8	51.8	53.6
95°	129.3	63.6	77.5	87.7	85.6
97.5°	232.8	69.7	101.4	107.5	109.5
100°	352.5	79.7	113.5	129.3	133.4
102.5°	483.7	480.0	117.5	139.3	145.4
105°	605.3	665.0	121.6	143.2	151.3
107.5°	746.7	796.3	125.6	147.3	155.3
110°	882.1	923.7	348.5	149.4	157.2

TEST NUMBER: P917279

CATALOG NUMBER: DFN2DIP-SQ3F0-040D100US930-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1009.5	1045.2	1011.5	153.2	159.4
115°	1144.8	1178.6	1228.5	306.6	163.4
117.5°	1262.2	1302.0	1336.0	1051.2	529.6
120°	1393.8	1423.5	1459.5	1483.4	1214.5
122.5°	1505.1	1537.0	1576.9	1588.8	1590.9
125°	1618.6	1644.6	1682.4	1696.4	1702.3
127.5°	1722.2	1750.0	1780.0	1799.9	1801.8
130°	1819.7	1851.7	1873.5	1895.4	1893.5
132.5°	1919.3	1945.3	1967.1	1985.0	1983.1
135°	2003.0	2034.9	2052.7	2072.7	2068.7
137.5°	2090.5	2114.4	2134.5	2154.3	2148.4
140°	2176.0	2192.2	2213.9	2231.9	2221.9
142.5°	2247.9	2261.9	2287.6	2303.5	2293.6
145°	2323.6	2321.5	2355.3	2369.3	2359.3
147.5°	2389.1	2383.2	2417.0	2426.9	2419.2
150°	2452.9	2439.0	2470.9	2482.7	2472.8
152.5°	2506.6	2490.7	2520.6	2532.6	2518.6
155°	2558.4	2540.6	2564.5	2576.3	2560.5
157.5°	2600.2	2584.4	2602.4	2616.3	2600.2
160°	2636.2	2624.1	2636.2	2648.0	2634.1
162.5°	2667.8	2656.0	2665.9	2679.9	2661.9
165°	2695.7	2683.9	2689.8	2703.8	2689.8
167.5°	2717.7	2705.6	2711.8	2725.8	2707.8
170°	2735.7	2723.7	2727.7	2741.6	2723.7
172.5°	2747.5	2735.7	2739.7	2753.7	2735.7
175°	2757.4	2743.5	2747.5	2761.5	2741.6
177.5°	2761.5	2747.5	2749.7	2763.6	2745.6
180°	2751.6	2751.6	2751.6	2751.6	2751.6

TEST NUMBER: P917279

CATALOG NUMBER: DFN2DIP-SQ3F0-040D100US930-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	5.75	6.41	6.89	7.54	9.13	1.71	2.37	2.85	3.50	5.09
	3H	7.41	8.00	8.56	9.14	10.74	2.88	3.47	4.03	4.61	6.21
	4H	8.01	8.57	9.17	9.71	11.31	3.31	3.88	4.48	5.02	6.62
	6H	8.41	8.93	9.59	10.08	11.69	3.62	4.14	4.79	5.28	6.90
	8H	8.53	9.03	9.71	10.19	11.79	3.70	4.20	4.88	5.35	6.96
	12H	8.59	9.06	9.77	10.21	11.84	3.74	4.21	4.92	5.36	6.99
4H	2H	5.74	6.31	6.91	7.45	9.05	2.28	2.84	3.45	3.98	5.59
	3H	7.55	8.02	8.73	9.19	10.80	3.61	4.08	4.78	5.24	6.86
	4H	8.23	8.67	9.41	9.82	11.45	4.14	4.58	5.32	5.73	7.36
	6H	8.74	9.10	9.92	10.28	11.91	4.55	4.92	5.73	6.09	7.72
	8H	8.90	9.25	10.08	10.42	12.06	4.67	5.01	5.85	6.18	7.82
	12H	8.99	9.30	10.18	10.48	12.13	4.72	5.03	5.92	6.21	7.86
8H	4H	8.19	8.53	9.37	9.70	11.34	4.41	4.75	5.59	5.92	7.56
	6H	8.74	9.03	9.94	10.24	11.87	4.91	5.20	6.11	6.41	8.04
	8H	8.96	9.20	10.16	10.39	12.05	5.10	5.34	6.30	6.53	8.19
	12H	9.08	9.30	10.29	10.49	12.18	5.20	5.42	6.41	6.61	8.30
12H	4H	8.13	8.44	9.33	9.62	11.27	4.41	4.72	5.60	5.90	7.54
	6H	8.72	8.96	9.92	10.15	11.81	4.96	5.21	6.16	6.40	8.05
	8H	8.93	9.14	10.13	10.33	12.02	5.16	5.37	6.36	6.56	8.25

END OF REPORT