

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P906908

Luminaire Tested: DFN2DIP-SQ4F0-120D140US835-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P906908
REPORT IS A COMBINATION OF REPORTS P900197 AND P896915
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ4F0-120D140US835-FLLFL
Description: 4 foot, Square Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 24270.0 lumens
Efficiency: N/A
Efficacy: 108.6 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.92' x L: 3.92' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 223.4
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9933
Total Harmonic Distortion (THDi): 0.066
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P906908

CATALOG NUMBER: DFN2DIP-SQ4F0-120D140US835-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P906908

CATALOG NUMBER: DFN2DIP-SQ4F0-120D140US835-FLLFL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	107	107	107	107	98	98	98	98	83	83	83	68	68	68	55	55	55
1	98	93	89	86	90	86	83	80	73	70	68	60	59	57	49	48	47
2	89	81	75	70	82	75	70	65	64	60	56	53	50	48	43	41	39
3	81	72	64	58	74	66	60	55	56	51	47	47	43	40	38	36	33
4	74	63	55	49	68	59	52	46	50	45	40	42	38	34	34	31	29
5	68	56	48	42	62	52	45	40	45	39	35	37	33	30	31	28	25
6	63	51	43	37	58	47	40	35	40	35	30	34	29	26	28	25	22
7	58	46	38	32	53	42	35	30	36	31	27	31	26	23	25	22	20
8	54	41	34	28	49	39	32	27	33	28	24	28	24	21	23	20	18
9	50	38	30	25	46	35	29	24	30	25	21	26	22	19	22	18	16
10	47	35	28	23	43	32	26	22	28	23	19	24	20	17	20	17	14

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3276	3276	3276
5°	3282	3231	3253
10°	3255	3188	3210
15°	3207	3137	3142
20°	3142	3064	3073
25°	3078	2978	2992
30°	2997	2897	2890
35°	2921	2802	2781
40°	2827	2706	2678
45°	2733	2610	2572
50°	2630	2509	2449
55°	2523	2392	2337
60°	2401	2254	2209
65°	2269	2110	2057
70°	2100	1935	1894
75°	1867	1726	1745
80°	1586	1460	1458
85°	1146	999	980

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 90°

Luminance: 3485 cd/sqm

TEST NUMBER: P906908

CATALOG NUMBER: DFN2DIP-SQ4F0-120D140US835-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	439.5	1.8
10°-20°	1236.5	5.1
20°-30°	1817.2	7.5
30°-40°	2110.5	8.7
40°-50°	2107.9	8.7
50°-60°	1838.0	7.6
60°-70°	1358.7	5.6
70°-80°	768.7	3.2
80°-90°	215.5	0.9
90°-100°	274.0	1.1
100°-110°	870.6	3.6
110°-120°	1489.8	6.1
120°-130°	1959.3	8.1
130°-140°	2199.2	9.1
140°-150°	2156.6	8.9
150°-160°	1809.1	7.5
160°-170°	1199.7	4.9
170°-180°	419.3	1.7
0°-30°	3493.1	14.4
0°-40°	5603.7	23.1
0°-60°	9549.6	39.3
0°-90°	11892.6	49.0
90°-120°	2634.3	10.9
90°-150°	8949.3	36.9
90°-180°	12377.0	51.0
0°-180°	24270.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4669	4669	4669	4669	4669	
5°	4669	4652	4602	4638	4629	443
15°	4445	4418	4360	4378	4355	1252
25°	4023	3987	3911	3920	3911	1851
35°	3471	3426	3354	3327	3304	2167
45°	2824	2793	2725	2676	2658	2180
55°	2137	2110	2056	2003	1980	1911
65°	1442	1414	1370	1329	1307	1425
75°	754	746	723	696	705	805
85°	184	180	175	162	157	205
90°	4	48	131	123	127	24
95°	195	232	239	239	232	217
105°	804	814	822	829	829	848
115°	1495	1516	1510	1506	1495	1479
125°	2174	2208	2197	2185	2181	1943
135°	2812	2854	2862	2858	2847	2174
145°	3414	3441	3463	3467	3452	2133
155°	3904	3915	3927	3946	3934	1797
165°	4248	4244	4244	4270	4252	1198
175°	4420	4409	4401	4428	4405	420
180°	4428	4428	4428	4428	4428	

TEST NUMBER: P906908

CATALOG NUMBER: DFN2DIP-SQ4F0-120D140US835-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4669.3	4669.3	4669.3	4669.3	4669.3
2.5°	4696.4	4674.0	4624.5	4669.3	4660.7
5°	4669.3	4651.6	4602.1	4637.8	4629.2
7.5°	4637.8	4611.1	4561.6	4597.8	4588.8
10°	4588.8	4557.3	4503.5	4539.2	4525.9
12.5°	4521.1	4494.4	4440.6	4463.0	4453.9
15°	4444.9	4418.2	4359.6	4377.7	4355.3
17.5°	4350.6	4323.9	4265.3	4287.7	4265.3
20°	4247.2	4220.5	4157.7	4171.0	4153.4
22.5°	4144.3	4103.8	4045.2	4045.2	4036.2
25°	4022.8	3987.1	3910.9	3919.5	3910.9
27.5°	3888.0	3856.6	3798.5	3785.1	3762.8
30°	3753.7	3717.5	3650.3	3637.0	3618.9
32.5°	3609.8	3583.2	3511.2	3484.1	3466.0
35°	3470.7	3426.0	3354.0	3326.9	3304.5
37.5°	3313.5	3273.1	3201.1	3169.7	3147.3
40°	3152.1	3115.9	3043.9	3003.9	2985.8
42.5°	2994.9	2958.7	2887.2	2842.0	2815.3
45°	2824.3	2792.9	2725.2	2676.2	2658.1
47.5°	2658.1	2626.6	2554.7	2505.2	2478.5
50°	2482.8	2460.4	2397.5	2334.6	2312.2
52.5°	2312.2	2280.8	2222.7	2173.1	2141.7
55°	2137.4	2110.3	2056.4	2002.6	1980.2
57.5°	1962.1	1939.7	1881.1	1827.3	1809.2
60°	1786.8	1769.2	1706.3	1656.8	1643.4
62.5°	1616.3	1584.8	1540.1	1495.3	1477.2
65°	1441.5	1414.3	1369.5	1329.0	1306.7
67.5°	1261.9	1239.0	1199.0	1167.6	1149.5
70°	1095.6	1077.5	1037.0	1005.6	988.0
72.5°	925.1	907.0	884.6	853.2	839.8
75°	754.1	745.5	722.6	696.0	705.0
77.5°	601.6	583.5	574.5	561.1	547.8
80°	449.2	444.4	435.4	422.1	413.0
82.5°	305.3	305.3	301.1	283.0	283.0
85°	183.9	179.6	175.3	161.5	157.2
87.5°	81.0	71.9	62.9	49.5	44.8
90°	4.0	48.1	130.8	122.8	126.8
92.5°	82.8	112.1	116.1	120.1	120.1
95°	194.9	232.3	238.9	238.9	232.3
97.5°	324.4	359.1	373.8	373.8	373.8
100°	473.9	504.6	515.2	515.2	511.2
102.5°	631.4	654.1	668.8	672.8	668.8
105°	803.6	814.3	822.3	828.9	828.9
107.5°	974.4	990.5	990.5	993.1	974.4
110°	1140.0	1161.3	1161.3	1161.3	1150.6

TEST NUMBER: P906908

CATALOG NUMBER: DFN2DIP-SQ4F0-120D140US835-FLLFL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1318.8	1341.5	1337.5	1326.8	1318.8
115°	1495.0	1516.4	1509.7	1505.7	1495.0
117.5°	1669.9	1699.3	1680.6	1669.9	1659.2
120°	1846.1	1875.5	1846.1	1846.1	1834.1
122.5°	2006.3	2043.6	2025.0	2014.3	2006.3
125°	2174.5	2207.8	2197.1	2185.1	2181.1
127.5°	2338.6	2380.0	2365.3	2349.3	2338.6
130°	2492.1	2540.2	2533.5	2525.5	2510.8
132.5°	2664.3	2701.7	2704.4	2685.7	2675.0
135°	2812.5	2853.9	2861.9	2857.9	2847.2
137.5°	2978.0	3011.4	3018.1	3015.4	2999.4
140°	3123.5	3156.9	3175.6	3175.6	3160.9
142.5°	3273.0	3306.4	3317.1	3321.1	3306.4
145°	3414.5	3441.2	3462.6	3466.6	3451.9
147.5°	3541.3	3574.7	3590.7	3597.4	3582.7
150°	3672.1	3694.8	3709.5	3721.5	3709.5
152.5°	3788.3	3811.0	3829.7	3844.3	3829.7
155°	3904.4	3915.1	3927.1	3945.8	3933.8
157.5°	4004.5	4012.5	4019.2	4045.9	4027.2
160°	4094.0	4102.0	4106.0	4128.7	4112.6
162.5°	4176.7	4176.7	4180.7	4206.1	4187.4
165°	4247.5	4243.5	4243.5	4270.2	4251.5
167.5°	4311.5	4299.5	4299.5	4326.2	4307.5
170°	4359.6	4348.9	4344.9	4371.6	4348.9
172.5°	4393.0	4382.3	4378.3	4405.0	4382.3
175°	4419.7	4409.0	4401.0	4427.7	4405.0
177.5°	4434.3	4423.7	4415.7	4438.3	4415.7
180°	4427.7	4427.7	4427.7	4427.7	4427.7

TEST NUMBER: P906908

CATALOG NUMBER: DFN2DIP-SQ4F0-120D140US835-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.31	12.17	12.28	13.15	14.43	10.87	11.72	11.83	12.70	13.99
	3H	12.98	13.74	13.95	14.73	16.04	12.49	13.25	13.46	14.24	15.55
	4H	13.57	14.29	14.56	15.28	16.60	13.07	13.80	14.06	14.79	16.11
	6H	13.97	14.64	14.97	15.63	16.96	13.47	14.14	14.47	15.13	16.46
	8H	14.08	14.71	15.08	15.73	17.05	13.57	14.21	14.58	15.22	16.55
	12H	14.13	14.73	15.14	15.74	17.09	13.62	14.22	14.63	15.23	16.58
4H	2H	11.77	12.50	12.77	13.49	14.81	11.42	12.14	12.41	13.14	14.45
	3H	13.64	14.25	14.65	15.27	16.60	13.24	13.84	14.24	14.86	16.19
	4H	14.36	14.91	15.37	15.93	17.28	13.94	14.49	14.95	15.50	16.86
	6H	14.88	15.35	15.90	16.39	17.74	14.45	14.92	15.47	15.96	17.31
	8H	15.03	15.48	16.06	16.51	17.87	14.59	15.04	15.62	16.07	17.43
	12H	15.11	15.51	16.15	16.55	17.92	14.66	15.06	15.70	16.10	17.47
8H	4H	14.56	15.00	15.58	16.03	17.40	14.18	14.62	15.21	15.66	17.02
	6H	15.19	15.56	16.24	16.63	17.99	14.81	15.18	15.86	16.25	17.61
	8H	15.42	15.74	16.47	16.80	18.18	15.02	15.35	16.08	16.40	17.79
	12H	15.55	15.83	16.61	16.89	18.31	15.14	15.42	16.20	16.48	17.90
12H	4H	14.54	14.94	15.59	15.99	17.36	14.17	14.58	15.22	15.62	16.99
	6H	15.22	15.55	16.28	16.60	17.99	14.85	15.17	15.91	16.23	17.61
	8H	15.47	15.75	16.53	16.80	18.23	15.09	15.37	16.15	16.42	17.85