

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P906964

Luminaire Tested: DFN2DIP-SQ4F0-160D090US835-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P906964
REPORT IS A COMBINATION OF REPORTS P900129 AND P896915
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ4F0-160D090US835-FLLFLL
Description: 4 foot, Square Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 23805.0 lumens
Efficiency: N/A
Efficacy: 102.0 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.92' x L: 3.92' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 233.4
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9971
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P906964

CATALOG NUMBER: DFN2DIP-SQ4F0-160D090US835-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P906964

CATALOG NUMBER: DFN2DIP-SQ4F0-160D090US835-FLLFL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	111	111	111	111	105	105	105	105	93	93	93		81	81	81		71
1	102	97	93	89	95	92	88	85	81	79	76		72	70	68		63
2	92	85	78	73	87	80	74	70	71	67	63		63	60	57		56
3	84	75	67	61	79	71	64	58	63	58	53		56	52	48		49
4	77	66	58	52	72	63	55	50	56	50	45		50	45	41		44
5	71	59	51	44	67	56	48	43	50	44	39		45	40	36		40
6	66	53	45	39	61	50	43	37	45	39	34		41	35	31		36
7	61	48	40	34	57	46	38	33	41	35	30		37	32	28		33
8	56	44	36	30	53	42	34	29	38	31	27		34	29	25		30
9	53	40	32	27	49	38	31	26	35	29	24		31	26	23		28
10	49	37	29	24	46	35	28	24	32	26	22		29	24	20		26

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4368	4368	4368
5°	4375	4308	4338
10°	4340	4251	4280
15°	4276	4182	4190
20°	4190	4086	4097
25°	4104	3970	3990
30°	3996	3863	3853
35°	3894	3736	3708
40°	3769	3608	3570
45°	3644	3480	3429
50°	3507	3346	3266
55°	3364	3190	3116
60°	3202	3005	2945
65°	3025	2814	2742
70°	2800	2581	2525
75°	2489	2302	2327
80°	2114	1947	1944
85°	1528	1332	1306

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 3644 cd/sqm

TEST NUMBER: P906964

CATALOG NUMBER: DFN2DIP-SQ4F0-160D090US835-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	586.0	2.5
10°-20°	1648.7	6.9
20°-30°	2422.9	10.2
30°-40°	2814.1	11.8
40°-50°	2810.6	11.8
50°-60°	2450.7	10.3
60°-70°	1811.6	7.6
70°-80°	1025.0	4.3
80°-90°	278.6	1.2
90°-100°	176.1	0.7
100°-110°	559.6	2.4
110°-120°	957.7	4.0
120°-130°	1259.5	5.3
130°-140°	1413.8	5.9
140°-150°	1386.4	5.8
150°-160°	1163.0	4.9
160°-170°	771.2	3.2
170°-180°	269.6	1.1
0°-30°	4657.5	19.6
0°-40°	7471.6	31.4
0°-60°	12732.9	53.5
0°-90°	15848.1	66.6
90°-120°	1693.5	7.1
90°-150°	5753.1	24.2
90°-180°	7957.0	33.4
0°-180°	23805.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	6226	6226	6226	6226	6226	
5°	6226	6202	6136	6184	6172	591
15°	5926	5891	5813	5837	5807	1669
25°	5364	5316	5214	5226	5214	2468
35°	4628	4568	4472	4436	4406	2890
45°	3766	3724	3634	3568	3544	2906
55°	2850	2814	2742	2670	2640	2548
65°	1922	1886	1826	1772	1742	1900
75°	1005	994	964	928	940	1073
85°	245	239	234	215	210	273
90°	3	31	84	79	82	23
95°	125	149	154	154	149	139
105°	517	523	529	533	533	545
115°	961	975	970	968	961	951
125°	1398	1419	1412	1405	1402	1249
135°	1808	1835	1840	1837	1830	1398
145°	2195	2212	2226	2228	2219	1372
155°	2510	2517	2525	2537	2529	1155
165°	2730	2728	2728	2745	2733	770
175°	2841	2834	2829	2846	2832	270
180°	2846	2846	2846	2846	2846	



TEST NUMBER: P906964

CATALOG NUMBER: DFN2DIP-SQ4F0-160D090US835-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	6225.7	6225.7	6225.7	6225.7	6225.7
2.5°	6261.9	6232.0	6166.0	6225.7	6214.2
5°	6225.7	6202.2	6136.1	6183.8	6172.3
7.5°	6183.8	6148.2	6082.1	6130.4	6118.3
10°	6118.3	6076.4	6004.7	6052.3	6034.5
12.5°	6028.2	5992.6	5920.8	5950.7	5938.6
15°	5926.5	5891.0	5812.8	5837.0	5807.1
17.5°	5800.8	5765.2	5687.1	5716.9	5687.1
20°	5662.9	5627.4	5543.5	5561.3	5537.8
22.5°	5525.8	5471.8	5393.6	5393.6	5381.6
25°	5363.8	5316.2	5214.5	5226.0	5214.5
27.5°	5184.0	5142.1	5064.6	5046.9	5017.0
30°	5004.9	4956.7	4867.1	4849.3	4825.2
32.5°	4813.1	4777.6	4681.6	4645.4	4621.3
35°	4627.7	4568.0	4472.0	4435.8	4406.0
37.5°	4418.1	4364.1	4268.2	4226.2	4196.4
40°	4202.7	4154.5	4058.6	4005.2	3981.1
42.5°	3993.2	3944.9	3849.6	3789.3	3753.7
45°	3765.8	3723.8	3633.7	3568.2	3544.1
47.5°	3544.1	3502.2	3406.3	3340.2	3304.7
50°	3310.4	3280.5	3196.7	3112.8	3083.0
52.5°	3083.0	3041.1	2963.6	2897.5	2855.6
55°	2849.9	2813.7	2741.9	2670.1	2640.3
57.5°	2616.2	2586.3	2508.2	2436.4	2412.3
60°	2382.4	2358.9	2275.1	2209.0	2191.2
62.5°	2155.0	2113.1	2053.4	1993.7	1969.6
65°	1921.9	1885.7	1826.0	1772.1	1742.2
67.5°	1682.5	1652.0	1598.7	1556.7	1532.6
70°	1460.8	1436.7	1382.7	1340.8	1317.3
72.5°	1233.4	1209.3	1179.5	1137.5	1119.8
75°	1005.4	994.0	963.5	927.9	940.0
77.5°	802.2	778.1	766.0	748.2	730.4
80°	598.9	592.6	580.5	562.7	550.7
82.5°	407.1	407.1	401.4	377.3	377.3
85°	245.2	239.4	233.7	215.3	209.6
87.5°	108.0	95.9	83.8	66.1	59.7
90°	2.6	30.9	84.1	78.9	81.5
92.5°	53.2	72.1	74.7	77.2	77.2
95°	125.3	149.3	153.6	153.6	149.3
97.5°	208.5	230.8	240.3	240.3	240.3
100°	304.6	324.4	331.2	331.2	328.7
102.5°	405.9	420.5	429.9	432.5	429.9
105°	516.6	523.4	528.6	532.9	532.9
107.5°	626.4	636.7	636.7	638.4	626.4
110°	732.8	746.6	746.6	746.6	739.7

TEST NUMBER: P906964

CATALOG NUMBER: DFN2DIP-SQ4F0-160D090US835-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	847.8	862.4	859.8	853.0	847.8
115°	961.1	974.8	970.5	968.0	961.1
117.5°	1073.5	1092.4	1080.4	1073.5	1066.6
120°	1186.8	1205.6	1186.8	1186.8	1179.0
122.5°	1289.7	1313.8	1301.8	1294.9	1289.7
125°	1397.9	1419.3	1412.5	1404.7	1402.2
127.5°	1503.4	1530.0	1520.6	1510.3	1503.4
130°	1602.1	1633.0	1628.7	1623.5	1614.1
132.5°	1712.8	1736.8	1738.5	1726.5	1719.7
135°	1808.0	1834.6	1839.8	1837.2	1830.4
137.5°	1914.4	1935.9	1940.2	1938.5	1928.2
140°	2008.0	2029.4	2041.4	2041.4	2032.0
142.5°	2104.1	2125.5	2132.4	2135.0	2125.5
145°	2195.1	2212.2	2225.9	2228.5	2219.1
147.5°	2276.6	2298.0	2308.3	2312.6	2303.2
150°	2360.7	2375.3	2384.7	2392.4	2384.7
152.5°	2435.3	2449.9	2461.9	2471.4	2461.9
155°	2510.0	2516.8	2524.6	2536.6	2528.9
157.5°	2574.3	2579.5	2583.8	2600.9	2588.9
160°	2631.8	2637.0	2639.6	2654.1	2643.8
162.5°	2685.0	2685.0	2687.6	2703.9	2691.9
165°	2730.5	2727.9	2727.9	2745.1	2733.1
167.5°	2771.7	2764.0	2764.0	2781.1	2769.1
170°	2802.6	2795.7	2793.2	2810.3	2795.7
172.5°	2824.0	2817.2	2814.6	2831.8	2817.2
175°	2841.2	2834.3	2829.2	2846.4	2831.8
177.5°	2850.6	2843.8	2838.6	2853.2	2838.6
180°	2846.4	2846.4	2846.4	2846.4	2846.4

TEST NUMBER: P906964

CATALOG NUMBER: DFN2DIP-SQ4F0-160D090US835-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.81	14.84	14.61	15.67	16.68	13.37	14.40	14.17	15.22	16.24
	3H	15.49	16.42	16.30	17.25	18.29	15.00	15.93	15.81	16.76	17.80
	4H	16.09	16.96	16.92	17.80	18.86	15.59	16.47	16.42	17.31	18.36
	6H	16.50	17.31	17.34	18.16	19.22	16.00	16.81	16.84	17.65	18.72
	8H	16.61	17.38	17.46	18.25	19.31	16.11	16.88	16.96	17.74	18.81
	12H	16.67	17.40	17.52	18.26	19.35	16.16	16.89	17.01	17.75	18.84
4H	2H	14.29	15.17	15.13	16.01	17.06	13.94	14.81	14.77	15.65	16.71
	3H	16.18	16.91	17.02	17.78	18.85	15.77	16.50	16.62	17.38	18.44
	4H	16.90	17.57	17.76	18.44	19.54	16.48	17.15	17.34	18.02	19.11
	6H	17.43	18.01	18.31	18.90	20.00	17.00	17.58	17.87	18.47	19.57
	8H	17.59	18.13	18.47	19.02	20.13	17.15	17.69	18.03	18.58	19.69
	12H	17.67	18.16	18.57	19.07	20.18	17.22	17.71	18.12	18.62	19.73
8H	4H	17.11	17.65	17.99	18.54	19.65	16.74	17.28	17.62	18.17	19.28
	6H	17.76	18.20	18.66	19.14	20.25	17.37	17.82	18.28	18.75	19.86
	8H	17.98	18.38	18.90	19.30	20.43	17.59	17.99	18.51	18.91	20.04
	12H	18.12	18.47	19.04	19.39	20.57	17.71	18.06	18.63	18.98	20.16
12H	4H	17.11	17.59	18.01	18.50	19.62	16.74	17.23	17.64	18.13	19.25
	6H	17.79	18.18	18.70	19.11	20.24	17.42	17.81	18.33	18.74	19.87
	8H	18.04	18.39	18.96	19.31	20.49	17.66	18.01	18.58	18.93	20.11