

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P915164

Luminaire Tested: DFN2DIP-SQ4F0-160D140US927-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P915164
REPORT IS A COMBINATION OF REPORTS P900201 AND P896915
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ4F0-160D140US927-FLLFLL
Description: 4 foot, Square Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 22363.3 lumens
Efficiency: N/A
Efficacy: 82.1 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.92' x L: 3.92' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 272.5
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9971
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P915164

CATALOG NUMBER: DFN2DIP-SQ4F0-160D140US927-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P915164

CATALOG NUMBER: DFN2DIP-SQ4F0-160D140US927-FLLFLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	109	109	109	109		101	101	101	101		87	87	87		74	74	74		62	62	62
1	99	95	91	87		92	88	85	82		76	74	71		65	63	61		55	53	52
2	90	83	77	71		84	77	72	67		67	63	59		57	54	51		48	46	44
3	82	73	65	59		76	68	61	56		59	54	50		50	47	43		43	40	37
4	75	64	56	50		70	60	53	48		52	47	42		45	41	37		38	35	32
5	69	57	49	43		64	54	46	41		47	41	37		40	36	32		34	31	28
6	64	52	43	38		59	48	41	36		42	36	32		37	32	28		31	28	25
7	59	47	39	33		55	44	37	31		38	32	28		33	29	25		28	25	22
8	55	42	35	29		51	40	33	28		35	29	25		30	26	22		26	23	20
9	51	39	31	26		47	36	30	25		32	26	23		28	23	20		24	21	18
10	48	36	28	23		44	34	27	22		30	24	20		26	21	18		22	19	16

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3461	3461	3461
5°	3466	3413	3436
10°	3438	3368	3391
15°	3387	3313	3319
20°	3319	3237	3246
25°	3251	3145	3160
30°	3166	3060	3052
35°	3085	2960	2937
40°	2986	2858	2828
45°	2887	2757	2717
50°	2778	2650	2587
55°	2665	2527	2469
60°	2536	2380	2333
65°	2397	2229	2172
70°	2218	2044	2000
75°	1972	1824	1843
80°	1674	1542	1540
85°	1210	1055	1035

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2887 cd/sqm

TEST NUMBER: P915164

CATALOG NUMBER: DFN2DIP-SQ4F0-160D140US927-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	464.2	2.1
10°-20°	1306.0	5.8
20°-30°	1919.4	8.6
30°-40°	2229.2	10.0
40°-50°	2226.5	10.0
50°-60°	1941.4	8.7
60°-70°	1435.1	6.4
70°-80°	812.0	3.6
80°-90°	224.3	1.0
90°-100°	217.0	1.0
100°-110°	689.6	3.1
110°-120°	1180.2	5.3
120°-130°	1552.1	6.9
130°-140°	1742.2	7.8
140°-150°	1708.4	7.6
150°-160°	1433.1	6.4
160°-170°	950.4	4.2
170°-180°	332.2	1.5
0°-30°	3689.6	16.5
0°-40°	5918.9	26.5
0°-60°	10086.7	45.1
0°-90°	12558.1	56.2
90°-120°	2086.8	9.3
90°-150°	7089.5	31.7
90°-180°	9805.0	43.8
0°-180°	22363.3	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4932	4932	4932	4932	4932	
5°	4932	4913	4861	4899	4890	468
15°	4695	4667	4605	4624	4600	1322
25°	4249	4211	4131	4140	4131	1955
35°	3666	3619	3543	3514	3490	2289
45°	2983	2950	2878	2827	2808	2302
55°	2258	2229	2172	2115	2092	2018
65°	1522	1494	1446	1404	1380	1505
75°	796	787	763	735	745	850
85°	194	190	185	171	166	217
90°	3	38	104	97	100	22
95°	154	184	189	189	184	172
105°	637	645	651	657	657	672
115°	1184	1201	1196	1193	1184	1171
125°	1723	1749	1740	1731	1728	1539
135°	2228	2261	2267	2264	2256	1722
145°	2705	2726	2743	2746	2734	1690
155°	3093	3102	3111	3126	3116	1424
165°	3365	3362	3362	3383	3368	949
175°	3501	3493	3486	3508	3490	333
180°	3508	3508	3508	3508	3508	

TEST NUMBER: P915164

CATALOG NUMBER: DFN2DIP-SQ4F0-160D140US927-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4931.9	4931.9	4931.9	4931.9	4931.9
2.5°	4960.6	4936.9	4884.6	4931.9	4922.8
5°	4931.9	4913.3	4860.9	4898.7	4889.6
7.5°	4898.7	4870.5	4818.1	4856.4	4846.8
10°	4846.8	4813.6	4756.8	4794.5	4780.4
12.5°	4775.4	4747.2	4690.3	4714.0	4704.4
15°	4694.9	4666.7	4604.8	4624.0	4600.3
17.5°	4595.3	4567.1	4505.2	4528.8	4505.2
20°	4486.0	4457.9	4391.5	4405.6	4386.9
22.5°	4377.4	4334.7	4272.7	4272.7	4263.2
25°	4249.1	4211.4	4130.8	4139.9	4130.8
27.5°	4106.7	4073.5	4012.1	3998.1	3974.4
30°	3964.8	3926.6	3855.6	3841.5	3822.4
32.5°	3812.8	3784.7	3708.7	3680.0	3660.9
35°	3666.0	3618.7	3542.6	3514.0	3490.4
37.5°	3499.9	3457.2	3381.2	3347.9	3324.3
40°	3329.3	3291.1	3215.1	3172.8	3153.8
42.5°	3163.3	3125.1	3049.6	3001.8	2973.6
45°	2983.2	2949.9	2878.5	2826.7	2807.6
47.5°	2807.6	2774.4	2698.4	2646.0	2617.9
50°	2622.4	2598.8	2532.4	2465.9	2442.3
52.5°	2442.3	2409.1	2347.7	2295.3	2262.2
55°	2257.6	2229.0	2172.1	2115.2	2091.6
57.5°	2072.5	2048.8	1986.9	1930.1	1911.0
60°	1887.3	1868.7	1802.3	1749.9	1735.8
62.5°	1707.2	1674.0	1626.7	1579.4	1560.3
65°	1522.5	1493.8	1446.5	1403.8	1380.1
67.5°	1332.8	1308.7	1266.5	1233.2	1214.1
70°	1157.2	1138.1	1095.3	1062.2	1043.5
72.5°	977.1	958.0	934.4	901.1	887.1
75°	796.5	787.4	763.3	735.1	744.7
77.5°	635.5	616.4	606.8	592.7	578.6
80°	474.4	469.4	459.9	445.8	436.3
82.5°	322.5	322.5	318.0	298.9	298.9
85°	194.2	189.6	185.1	170.6	166.0
87.5°	85.6	76.0	66.4	52.4	47.3
90°	3.2	38.1	103.6	97.3	100.4
92.5°	65.6	88.8	92.0	95.1	95.1
95°	154.4	184.0	189.3	189.3	184.0
97.5°	257.0	284.5	296.1	296.1	296.1
100°	375.4	399.7	408.1	408.1	405.0
102.5°	500.2	518.2	529.8	533.0	529.8
105°	636.6	645.1	651.4	656.6	656.6
107.5°	771.9	784.7	784.7	786.7	771.9
110°	903.1	920.0	920.0	920.0	911.5

TEST NUMBER: P915164

CATALOG NUMBER: DFN2DIP-SQ4F0-160D140US927-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1044.7	1062.7	1059.5	1051.1	1044.7
115°	1184.3	1201.3	1196.0	1192.8	1184.3
117.5°	1322.9	1346.2	1331.3	1322.9	1314.4
120°	1462.4	1485.7	1462.4	1462.4	1452.9
122.5°	1589.4	1618.9	1604.2	1595.7	1589.4
125°	1722.6	1749.0	1740.5	1731.0	1727.8
127.5°	1852.6	1885.4	1873.7	1861.1	1852.6
130°	1974.2	2012.3	2007.0	2000.7	1989.0
132.5°	2110.6	2140.2	2142.4	2127.6	2119.1
135°	2228.0	2260.8	2267.1	2264.0	2255.5
137.5°	2359.1	2385.6	2390.9	2388.7	2376.1
140°	2474.4	2500.8	2515.7	2515.7	2504.0
142.5°	2592.8	2619.3	2627.7	2630.9	2619.3
145°	2704.9	2726.1	2743.0	2746.2	2734.5
147.5°	2805.4	2831.8	2844.5	2849.8	2838.1
150°	2909.0	2927.0	2938.6	2948.1	2938.6
152.5°	3001.0	3019.0	3033.8	3045.4	3033.8
155°	3093.0	3101.5	3111.0	3125.8	3116.3
157.5°	3172.3	3178.6	3183.9	3205.1	3190.3
160°	3243.2	3249.5	3252.7	3270.7	3257.9
162.5°	3308.7	3308.7	3311.9	3332.0	3317.2
165°	3364.8	3361.6	3361.6	3382.8	3368.0
167.5°	3415.5	3406.0	3406.0	3427.1	3412.3
170°	3453.6	3445.1	3441.9	3463.1	3445.1
172.5°	3480.1	3471.6	3468.4	3489.6	3471.6
175°	3501.2	3492.7	3486.4	3507.5	3489.6
177.5°	3512.8	3504.4	3498.0	3515.9	3498.0
180°	3507.5	3507.5	3507.5	3507.5	3507.5

TEST NUMBER: P915164

CATALOG NUMBER: DFN2DIP-SQ4F0-160D140US927-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.15	13.07	13.05	13.99	15.17	11.70	12.62	12.60	13.54	14.72
	3H	13.82	14.64	14.73	15.57	16.78	13.33	14.15	14.24	15.08	16.29
	4H	14.41	15.19	15.34	16.13	17.34	13.91	14.69	14.84	15.63	16.85
	6H	14.82	15.53	15.76	16.48	17.70	14.31	15.03	15.26	15.98	17.20
	8H	14.92	15.61	15.87	16.57	17.79	14.42	15.11	15.37	16.07	17.29
	12H	14.98	15.63	15.93	16.58	17.83	14.47	15.12	15.42	16.07	17.32
4H	2H	12.61	13.40	13.55	14.33	15.55	12.26	13.04	13.19	13.98	15.19
	3H	14.49	15.14	15.44	16.11	17.34	14.08	14.73	15.03	15.70	16.93
	4H	15.21	15.81	16.17	16.77	18.02	14.79	15.38	15.74	16.34	17.60
	6H	15.73	16.25	16.70	17.23	18.48	15.30	15.81	16.27	16.80	18.05
	8H	15.89	16.37	16.86	17.34	18.61	15.45	15.93	16.42	16.91	18.17
	12H	15.96	16.40	16.95	17.39	18.67	15.52	15.95	16.50	16.94	18.22
8H	4H	15.41	15.89	16.38	16.87	18.14	15.04	15.52	16.01	16.49	17.76
	6H	16.05	16.45	17.05	17.47	18.73	15.67	16.06	16.66	17.08	18.35
	8H	16.28	16.63	17.28	17.63	18.92	15.88	16.23	16.89	17.24	18.53
	12H	16.41	16.72	17.42	17.72	19.05	16.00	16.31	17.01	17.31	18.64
12H	4H	15.40	15.83	16.39	16.83	18.10	15.03	15.47	16.02	16.46	17.73
	6H	16.08	16.43	17.09	17.44	18.72	15.71	16.06	16.71	17.07	18.35
	8H	16.33	16.64	17.34	17.64	18.97	15.95	16.26	16.96	17.26	18.59