

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P920547

Luminaire Tested: DFN2DIP-SQ4F0-120D120US935-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P920547
REPORT IS A COMBINATION OF REPORTS P901700 AND P898471
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ4F0-120D120US935-RLONL
Description: 4 foot, Square Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 19010.8 lumens
Efficiency: N/A
Efficacy: 91.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.92' x L: 3.92' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 207.7
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9933
Total Harmonic Distortion (THDi): 0.066
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P920547

CATALOG NUMBER: DFN2DIP-SQ4F0-120D120US935-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P920547

CATALOG NUMBER: DFN2DIP-SQ4F0-120D120US935-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	106	106	106	106		98	98	98	98		81	81	81		66	66	66		53	53	53
1	97	93	90	86		89	86	83	80		72	70	68		59	58	56		47	46	45
2	89	82	76	71		82	76	70	66		63	60	57		52	50	48		42	40	39
3	81	72	65	60		75	67	61	56		56	52	48		47	43	41		38	35	34
4	75	64	57	51		68	60	53	48		50	45	41		42	38	35		34	31	29
5	69	58	50	44		63	53	46	41		45	40	36		38	34	31		31	28	26
6	63	52	44	38		58	48	41	36		41	36	32		34	30	27		28	25	23
7	59	47	39	34		54	44	37	32		37	32	28		31	27	24		26	23	21
8	55	43	35	30		50	40	33	28		34	29	25		29	25	22		24	21	19
9	51	39	32	27		47	36	30	25		31	26	22		27	23	20		22	19	17
10	48	36	29	24		44	33	27	23		29	24	20		25	21	18		20	18	15

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2996	2996	2996
5°	3001	2949	2969
10°	2971	2892	2873
15°	2930	2797	2724
20°	2876	2666	2542
25°	2821	2519	2365
30°	2746	2368	2141
35°	2673	2205	1945
40°	2599	2037	1719
45°	2513	1851	1514
50°	2424	1662	1314
55°	2331	1461	1122
60°	2223	1250	925
65°	2099	1036	833
70°	1949	836	755
75°	1760	739	689
80°	1486	621	600
85°	1035	418	457

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2513 cd/sqm

TEST NUMBER: P920547

CATALOG NUMBER: DFN2DIP-SQ4F0-120D120US935-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	400.2	2.1
10°-20°	1098.7	5.8
20°-30°	1542.5	8.1
30°-40°	1681.4	8.8
40°-50°	1545.4	8.1
50°-60°	1213.7	6.4
60°-70°	790.0	4.2
70°-80°	406.7	2.1
80°-90°	109.9	0.6
90°-100°	115.0	0.6
100°-110°	428.6	2.3
110°-120°	1136.8	6.0
120°-130°	1885.4	9.9
130°-140°	2002.8	10.5
140°-150°	1861.3	9.8
150°-160°	1496.5	7.9
160°-170°	964.3	5.1
170°-180°	331.9	1.7
0°-30°	3041.3	16.0
0°-40°	4722.7	24.8
0°-60°	7481.7	39.4
0°-90°	8788.3	46.2
90°-120°	1680.4	8.8
90°-150°	7429.9	39.1
90°-180°	10223.0	53.8
0°-180°	19010.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4270	4270	4270	4270	4270	
5°	4270	4251	4200	4235	4224	405
15°	4062	4019	3888	3814	3776	1144
25°	3687	3563	3308	3150	3091	1696
35°	3177	2980	2640	2396	2311	1988
45°	2597	2338	1932	1658	1565	2006
55°	1975	1673	1256	1024	951	1764
65°	1333	1020	672	541	529	1322
75°	711	440	309	282	278	752
85°	166	85	73	73	73	191
90°	2	30	50	63	68	18
95°	164	81	98	111	108	194
105°	767	843	154	182	192	820
115°	1451	1494	1557	389	207	1428
125°	2051	2084	2132	2150	2157	1829
135°	2538	2579	2601	2627	2622	1961
145°	2945	2942	2985	3002	2990	1842
155°	3242	3220	3250	3265	3245	1494
165°	3416	3401	3409	3426	3409	965
175°	3494	3477	3482	3500	3474	333
180°	3487	3487	3487	3487	3487	

TEST NUMBER: P920547

CATALOG NUMBER: DFN2DIP-SQ4F0-120D120US935-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4270.2	4270.2	4270.2	4270.2	4270.2
2.5°	4289.5	4270.2	4227.6	4266.5	4258.7
5°	4270.2	4250.9	4200.5	4235.3	4223.9
7.5°	4235.3	4212.3	4158.3	4173.4	4154.1
10°	4189.0	4162.0	4084.8	4073.0	4050.0
12.5°	4131.2	4096.4	3991.8	3968.9	3926.2
15°	4061.5	4018.9	3887.7	3814.2	3775.7
17.5°	3980.3	3918.4	3756.0	3671.2	3609.3
20°	3887.7	3810.2	3617.1	3520.7	3435.4
22.5°	3787.2	3698.2	3474.0	3342.7	3285.0
25°	3686.8	3562.9	3307.9	3149.6	3091.4
27.5°	3567.0	3435.4	3153.3	2971.7	2882.7
30°	3439.5	3292.4	2983.2	2786.4	2681.8
32.5°	3315.7	3137.7	2821.2	2589.2	2492.4
35°	3176.7	2979.5	2639.6	2396.1	2310.7
37.5°	3041.4	2828.6	2469.4	2202.5	2106.2
40°	2898.3	2666.7	2291.5	2017.2	1916.8
42.5°	2751.5	2504.3	2114.0	1827.8	1731.5
45°	2596.9	2337.9	1932.3	1657.7	1564.9
47.5°	2450.1	2175.9	1758.5	1483.8	1398.9
50°	2287.8	2013.5	1588.4	1321.5	1240.7
52.5°	2129.2	1839.3	1426.0	1171.0	1097.6
55°	1974.6	1673.3	1255.9	1024.2	950.8
57.5°	1816.3	1507.2	1105.3	888.9	827.0
60°	1654.0	1344.8	946.7	749.9	688.0
62.5°	1495.7	1186.5	811.4	626.1	595.3
65°	1333.3	1020.1	672.4	541.2	529.3
67.5°	1178.8	865.5	541.2	475.2	463.7
70°	1016.4	715.1	448.1	409.6	394.0
72.5°	861.9	575.7	374.7	344.0	336.2
75°	710.9	440.3	309.2	282.1	278.4
77.5°	560.5	312.8	243.6	228.0	220.2
80°	421.1	224.3	185.3	170.1	170.1
82.5°	293.6	150.8	127.5	119.7	119.7
85°	166.1	84.9	73.4	73.4	73.4
87.5°	61.9	30.7	30.7	27.0	27.0
90°	2.4	30.2	50.4	63.2	68.0
92.5°	63.2	53.0	60.5	65.6	68.0
95°	163.8	80.6	98.2	111.2	108.5
97.5°	295.2	88.4	128.5	136.3	138.7
100°	446.7	101.0	143.8	163.8	169.0
102.5°	613.0	608.2	148.9	176.5	184.3
105°	767.0	842.8	154.0	181.6	191.7
107.5°	946.2	1009.1	159.1	186.7	196.8
110°	1117.8	1170.6	441.6	189.3	199.2



TEST NUMBER: P920547

CATALOG NUMBER: DFN2DIP-SQ4F0-120D120US935-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1279.4	1324.6	1281.8	194.2	201.9
115°	1450.7	1493.6	1556.8	388.6	207.1
117.5°	1599.6	1650.0	1693.2	1332.0	671.1
120°	1766.3	1804.0	1849.5	1879.8	1539.1
122.5°	1907.4	1947.8	1998.5	2013.4	2016.1
125°	2051.2	2084.1	2132.1	2149.7	2157.2
127.5°	2182.4	2217.8	2255.8	2281.0	2283.4
130°	2306.1	2346.6	2374.1	2402.0	2399.6
132.5°	2432.2	2465.2	2492.8	2515.6	2513.2
135°	2538.3	2578.8	2601.2	2626.7	2621.7
137.5°	2649.2	2679.4	2704.9	2730.1	2722.6
140°	2757.7	2778.0	2805.6	2828.4	2815.8
142.5°	2848.7	2866.4	2899.1	2919.1	2906.6
145°	2944.6	2941.9	2984.7	3002.5	2989.8
147.5°	3027.6	3020.1	3063.0	3075.6	3065.7
150°	3108.5	3090.8	3131.3	3146.3	3133.7
152.5°	3176.5	3156.4	3194.2	3209.5	3191.8
155°	3242.1	3219.6	3249.9	3264.9	3244.8
157.5°	3295.1	3275.1	3297.9	3315.5	3295.1
160°	3340.7	3325.4	3340.7	3355.7	3338.0
162.5°	3380.9	3365.9	3378.5	3396.1	3373.4
165°	3416.2	3401.2	3408.7	3426.4	3408.7
167.5°	3444.1	3428.8	3436.6	3454.2	3431.5
170°	3466.8	3451.6	3456.6	3474.3	3451.6
172.5°	3481.8	3466.8	3472.0	3489.6	3466.8
175°	3494.4	3476.7	3481.8	3499.5	3474.3
177.5°	3499.5	3481.8	3484.5	3502.2	3479.5
180°	3487.0	3487.0	3487.0	3487.0	3487.0

TEST NUMBER: P920547

CATALOG NUMBER: DFN2DIP-SQ4F0-120D120US935-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	10.61	11.41	11.60	12.41	13.74	6.57	7.37	7.57	8.37	9.70
	3H	12.29	13.00	13.30	14.02	15.36	7.76	8.47	8.76	9.48	10.83
	4H	12.90	13.58	13.92	14.59	15.95	8.21	8.88	9.23	9.90	11.25
	6H	13.32	13.95	14.35	14.96	16.33	8.53	9.15	9.56	10.17	11.54
	8H	13.45	14.04	14.49	15.08	16.44	8.62	9.21	9.65	10.24	11.61
	12H	13.51	14.08	14.55	15.11	16.49	8.66	9.22	9.70	10.25	11.64
4H	2H	10.62	11.30	11.65	12.32	13.67	7.16	7.84	8.19	8.86	10.21
	3H	12.46	13.02	13.49	14.06	15.43	8.51	9.08	9.55	10.12	11.49
	4H	13.15	13.66	14.19	14.70	16.09	9.06	9.57	10.10	10.61	12.00
	6H	13.67	14.11	14.72	15.17	16.55	9.48	9.92	10.53	10.98	12.37
	8H	13.84	14.26	14.90	15.31	16.71	9.61	10.02	10.66	11.07	12.47
	12H	13.94	14.31	15.01	15.38	16.79	9.67	10.04	10.74	11.11	12.52
8H	4H	13.12	13.53	14.17	14.58	15.98	9.34	9.75	10.39	10.80	12.21
	6H	13.68	14.03	14.76	15.12	16.52	9.86	10.20	10.93	11.29	12.69
	8H	13.90	14.20	14.99	15.28	16.70	10.05	10.35	11.13	11.43	12.85
	12H	14.04	14.31	15.13	15.38	16.84	10.17	10.43	11.25	11.50	12.96
12H	4H	13.07	13.44	14.13	14.50	15.91	9.34	9.72	10.41	10.78	12.19
	6H	13.66	13.96	14.74	15.04	16.46	9.91	10.21	10.99	11.29	12.70
	8H	13.88	14.15	14.97	15.22	16.68	10.12	10.38	11.20	11.45	12.91

END OF REPORT