

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P923321

Luminaire Tested: DFN2DIP-SQ4F0-160D060US940-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P923321
REPORT IS A COMBINATION OF REPORTS P901595 AND P898471
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-SQ4F0-160D060US940-FLLONL
Description: 4 foot, Square Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 19421.4 lumens
Efficiency: N/A
Efficacy: 91.7 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.92' x L: 3.92' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 211.9
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9971
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P923321

CATALOG NUMBER: DFN2DIP-SQ4F0-160D060US940-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P923321

CATALOG NUMBER: DFN2DIP-SQ4F0-160D060US940-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	113	113	113	113	107	107	107	107	96	96	96	86	86	86	77	77	77
1	103	98	94	91	97	94	90	87	84	82	79	76	74	72	68	67	65
2	94	86	80	74	89	82	76	71	74	69	66	67	63	60	60	57	55
3	86	76	68	62	81	72	65	60	65	60	55	59	55	51	53	50	47
4	78	67	59	53	74	64	57	51	58	52	47	53	48	44	48	44	40
5	72	60	51	45	68	57	50	44	52	46	41	47	42	38	43	39	35
6	67	54	45	39	63	52	44	38	47	41	36	43	37	33	39	35	31
7	62	49	41	35	58	47	39	34	43	36	32	39	34	30	36	31	28
8	57	44	36	31	54	43	35	30	39	33	28	36	30	27	33	28	25
9	53	41	33	28	51	39	32	27	36	30	25	33	28	24	30	26	22
10	50	38	30	25	48	36	29	24	33	27	23	31	25	22	28	24	20

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3895	3895	3895
5°	3902	3842	3868
10°	3870	3791	3817
15°	3813	3729	3736
20°	3736	3643	3653
25°	3659	3540	3558
30°	3563	3445	3436
35°	3473	3332	3306
40°	3361	3218	3184
45°	3249	3103	3058
50°	3127	2983	2912
55°	2999	2844	2779
60°	2855	2679	2626
65°	2698	2509	2445
70°	2497	2301	2252
75°	2219	2053	2075
80°	1885	1736	1733
85°	1362	1188	1165

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3249 cd/sqm

TEST NUMBER: P923321

CATALOG NUMBER: DFN2DIP-SQ4F0-160D060US940-FLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	522.5	2.7
10°-20°	1470.1	7.6
20°-30°	2160.5	11.1
30°-40°	2509.3	12.9
40°-50°	2506.2	12.9
50°-60°	2185.3	11.3
60°-70°	1615.4	8.3
70°-80°	914.0	4.7
80°-90°	244.4	1.3
90°-100°	59.5	0.3
100°-110°	222.0	1.1
110°-120°	588.7	3.0
120°-130°	976.3	5.0
130°-140°	1037.1	5.3
140°-150°	963.9	5.0
150°-160°	774.9	4.0
160°-170°	499.3	2.6
170°-180°	171.9	0.9
0°-30°	4153.2	21.4
0°-40°	6662.5	34.3
0°-60°	11354.0	58.5
0°-90°	14127.8	72.7
90°-120°	870.2	4.5
90°-150°	3847.4	19.8
90°-180°	5294.0	27.3
0°-180°	19421.4	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	5552	5552	5552	5552	5552	
5°	5552	5531	5472	5514	5504	527
15°	5285	5253	5183	5205	5178	1488
25°	4783	4740	4650	4660	4650	2201
35°	4127	4073	3988	3955	3929	2577
45°	3358	3321	3240	3182	3160	2592
55°	2541	2509	2445	2381	2354	2272
65°	1714	1682	1628	1580	1554	1694
75°	896	886	859	827	838	957
85°	219	214	208	192	187	244
90°	1	16	26	33	35	18
95°	85	42	51	58	56	101
105°	397	436	80	94	99	424
115°	751	774	806	201	107	740
125°	1062	1079	1104	1113	1117	947
135°	1314	1335	1347	1360	1358	1015
145°	1525	1523	1546	1555	1548	954
155°	1679	1667	1683	1691	1680	774
165°	1769	1761	1765	1774	1765	500
175°	1810	1800	1803	1812	1799	172
180°	1806	1806	1806	1806	1806	

TEST NUMBER: P923321

CATALOG NUMBER: DFN2DIP-SQ4F0-160D060US940-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	5551.5	5551.5	5551.5	5551.5	5551.5
2.5°	5583.8	5557.1	5498.3	5551.5	5541.3
5°	5551.5	5530.6	5471.6	5514.2	5503.9
7.5°	5514.2	5482.4	5423.5	5466.5	5455.8
10°	5455.8	5418.4	5354.5	5396.9	5381.0
12.5°	5375.4	5343.7	5279.6	5306.3	5295.5
15°	5284.7	5253.1	5183.3	5204.9	5178.3
17.5°	5172.6	5140.9	5071.2	5097.8	5071.2
20°	5049.7	5018.0	4943.2	4959.1	4938.1
22.5°	4927.4	4879.3	4809.5	4809.5	4798.8
25°	4783.0	4740.5	4649.8	4660.1	4649.8
27.5°	4622.6	4585.3	4516.2	4500.4	4473.7
30°	4462.9	4419.9	4340.0	4324.2	4302.7
32.5°	4291.9	4260.2	4174.6	4142.4	4120.9
35°	4126.6	4073.3	3987.7	3955.4	3928.9
37.5°	3939.7	3891.5	3806.0	3768.5	3742.0
40°	3747.6	3704.6	3619.1	3571.5	3550.0
42.5°	3560.8	3517.7	3432.7	3379.0	3347.2
45°	3358.0	3320.6	3240.2	3181.8	3160.3
47.5°	3160.3	3122.9	3037.4	2978.5	2946.8
50°	2951.9	2925.3	2850.5	2775.7	2749.1
52.5°	2749.1	2711.8	2642.7	2583.7	2546.4
55°	2541.3	2509.0	2445.0	2381.0	2354.4
57.5°	2332.9	2306.2	2236.6	2172.6	2151.1
60°	2124.4	2103.5	2028.7	1969.8	1953.9
62.5°	1921.6	1884.3	1831.0	1777.8	1756.3
65°	1713.8	1681.5	1628.3	1580.2	1553.5
67.5°	1500.3	1473.1	1425.6	1388.1	1366.6
70°	1302.6	1281.1	1233.0	1195.6	1174.7
72.5°	1099.8	1078.3	1051.8	1014.3	998.5
75°	896.5	886.4	859.2	827.4	838.2
77.5°	715.3	693.8	683.1	667.2	651.3
80°	534.0	528.4	517.6	501.8	491.1
82.5°	363.0	363.0	357.9	336.4	336.4
85°	218.6	213.5	208.4	192.0	186.9
87.5°	96.3	85.5	74.7	58.9	53.2
90°	1.2	15.7	26.0	32.7	35.2
92.5°	32.7	27.5	31.3	34.0	35.2
95°	84.9	41.7	50.9	57.6	56.2
97.5°	152.8	45.7	66.5	70.6	71.9
100°	231.3	52.3	74.5	84.9	87.5
102.5°	317.4	315.0	77.1	91.4	95.4
105°	397.2	436.4	79.7	94.0	99.3
107.5°	490.0	522.5	82.4	96.7	101.9
110°	578.9	606.2	228.7	98.1	103.2



TEST NUMBER: P923321

CATALOG NUMBER: DFN2DIP-SQ4F0-160D060US940-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	662.5	685.9	663.7	100.5	104.6
115°	751.3	773.5	806.2	201.3	107.2
117.5°	828.3	854.4	876.7	689.8	347.5
120°	914.6	934.2	957.8	973.4	797.0
122.5°	987.7	1008.6	1034.8	1042.6	1044.0
125°	1062.2	1079.2	1104.0	1113.2	1117.0
127.5°	1130.2	1148.4	1168.1	1181.2	1182.4
130°	1194.2	1215.1	1229.4	1243.8	1242.6
132.5°	1259.5	1276.6	1290.8	1302.6	1301.4
135°	1314.5	1335.4	1347.0	1360.2	1357.5
137.5°	1371.8	1387.5	1400.7	1413.7	1409.9
140°	1428.0	1438.6	1452.9	1464.6	1458.1
142.5°	1475.2	1484.3	1501.3	1511.6	1505.1
145°	1524.8	1523.4	1545.6	1554.8	1548.3
147.5°	1567.8	1563.9	1586.1	1592.6	1587.5
150°	1609.7	1600.5	1621.5	1629.2	1622.7
152.5°	1644.9	1634.5	1654.0	1662.0	1652.8
155°	1678.9	1667.2	1682.9	1690.7	1680.2
157.5°	1706.4	1695.9	1707.7	1716.9	1706.4
160°	1729.9	1722.0	1729.9	1737.7	1728.6
162.5°	1750.7	1742.9	1749.4	1758.6	1746.9
165°	1769.1	1761.3	1765.1	1774.3	1765.1
167.5°	1783.4	1775.6	1779.6	1788.8	1776.9
170°	1795.3	1787.3	1790.0	1799.1	1787.3
172.5°	1803.0	1795.3	1797.9	1807.1	1795.3
175°	1809.5	1800.4	1803.0	1812.1	1799.1
177.5°	1812.1	1803.0	1804.4	1813.6	1801.8
180°	1805.6	1805.6	1805.6	1805.6	1805.6

TEST NUMBER: P923321

CATALOG NUMBER: DFN2DIP-SQ4F0-160D060US940-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.89	15.00	14.62	15.75	16.66	13.44	14.55	14.18	15.31	16.21
	3H	15.57	16.57	16.32	17.33	18.27	15.08	16.08	15.83	16.84	17.78
	4H	16.17	17.11	16.94	17.89	18.84	15.68	16.62	16.44	17.39	18.34
	6H	16.59	17.46	17.37	18.24	19.20	16.09	16.96	16.86	17.74	18.70
	8H	16.70	17.53	17.49	18.33	19.30	16.20	17.03	16.99	17.83	18.79
	12H	16.76	17.55	17.55	18.35	19.34	16.25	17.04	17.04	17.84	18.83
4H	2H	14.38	15.32	15.15	16.09	17.04	14.02	14.96	14.79	15.74	16.69
	3H	16.27	17.06	17.05	17.87	18.83	15.86	16.65	16.64	17.46	18.42
	4H	17.00	17.71	17.79	18.52	19.52	16.57	17.29	17.37	18.10	19.09
	6H	17.53	18.15	18.34	18.99	19.98	17.10	17.72	17.91	18.55	19.55
	8H	17.69	18.27	18.51	19.10	20.11	17.25	17.83	18.07	18.66	19.67
	12H	17.78	18.30	18.61	19.15	20.17	17.33	17.85	18.16	18.70	19.72
8H	4H	17.21	17.79	18.03	18.62	19.64	16.84	17.42	17.66	18.25	19.26
	6H	17.86	18.34	18.71	19.21	20.23	17.48	17.96	18.32	18.83	19.84
	8H	18.09	18.51	18.94	19.38	20.41	17.69	18.12	18.55	18.99	20.02
	12H	18.23	18.61	19.09	19.47	20.55	17.82	18.20	18.68	19.06	20.14
12H	4H	17.21	17.73	18.05	18.58	19.60	16.84	17.37	17.68	18.22	19.23
	6H	17.89	18.32	18.75	19.19	20.22	17.52	17.95	18.38	18.82	19.85
	8H	18.15	18.53	19.01	19.39	20.47	17.77	18.15	18.63	19.01	20.09