

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P907055

Luminaire Tested: DFN2DIP-TR2F0-050D030US835-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P907055
REPORT IS A COMBINATION OF REPORTS P901758 AND P897145
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-TR2F0-050D030US835-RLLONL
Description: 2 foot, Triangle Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6905.0 lumens
Efficiency: N/A
Efficacy: 99.6 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 2.04' x L: 2.36' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 69.3
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9789
Total Harmonic Distortion (THDi): 0.074
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P907055

CATALOG NUMBER: DFN2DIP-TR2F0-050D030US835-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P907055

CATALOG NUMBER: DFN2DIP-TR2F0-050D030US835-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	103	103	103	103	90	90	90	78	78	78	67	67	67
1	101	97	93	90	94	91	88	85	80	77	75	69	68	66	60	59	58
2	92	85	79	74	86	80	75	70	71	67	63	62	59	56	53	51	49
3	85	75	68	63	79	71	65	60	63	58	54	55	51	48	48	45	43
4	78	67	60	54	73	63	57	51	56	51	46	49	45	42	43	40	37
5	72	60	52	46	67	57	50	44	51	45	41	45	40	37	39	36	33
6	66	54	46	41	62	51	44	39	46	40	36	41	36	32	36	32	29
7	62	49	42	36	58	47	40	35	42	36	32	37	33	29	33	29	26
8	57	45	37	32	54	43	36	31	38	33	28	34	30	26	30	27	24
9	53	41	34	29	50	39	32	28	35	30	26	32	27	24	28	24	22
10	50	38	31	26	47	36	30	25	33	27	23	29	25	22	26	22	20

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4609	4609	4609
5°	4610	4526	4557
10°	4557	4427	4401
15°	4488	4271	4165
20°	4398	4059	3877
25°	4306	3824	3600
30°	4185	3585	3251
35°	4065	3328	2944
40°	3944	3063	2594
45°	3803	2771	2277
50°	3657	2477	1969
55°	3504	2164	1672
60°	3326	1838	1369
65°	3122	1509	1224
70°	2873	1201	1096
75°	2561	1039	982
80°	2111	843	828
85°	1386	523	583

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3803 cd/sqm

TEST NUMBER: P907055

CATALOG NUMBER: DFN2DIP-TR2F0-050D030US835-RLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	193.7	2.8
10°-20°	531.7	7.7
20°-30°	746.5	10.8
30°-40°	813.7	11.8
40°-50°	747.9	10.8
50°-60°	587.3	8.5
60°-70°	382.3	5.5
70°-80°	196.8	2.9
80°-90°	52.9	0.8
90°-100°	58.7	0.9
100°-110°	186.5	2.7
110°-120°	319.2	4.6
120°-130°	419.8	6.1
130°-140°	471.2	6.8
140°-150°	462.1	6.7
150°-160°	387.7	5.6
160°-170°	257.1	3.7
170°-180°	89.9	1.3
0°-30°	1471.8	21.3
0°-40°	2285.5	33.1
0°-60°	3620.7	52.4
0°-90°	4252.7	61.6
90°-120°	564.5	8.2
90°-150°	1917.7	27.8
90°-180°	2652.0	38.4
0°-180°	6905.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2066	2066	2066	2066	2066	
5°	2066	2057	2033	2050	2044	196
15°	1966	1945	1881	1846	1827	554
25°	1784	1724	1601	1524	1496	821
35°	1537	1442	1277	1160	1118	962
45°	1257	1131	935	802	757	971
55°	956	810	608	496	460	854
65°	645	494	325	262	256	640
75°	344	213	150	136	135	364
85°	80	41	36	36	36	92
90°	1	10	28	26	27	7
95°	42	50	51	51	50	46
105°	172	174	176	178	178	182
115°	320	325	324	323	320	317
125°	466	473	471	468	467	416
135°	603	612	613	612	610	466
145°	732	737	742	743	740	457
155°	837	839	842	846	843	385
165°	910	909	909	915	911	257
175°	947	945	943	949	944	90
180°	949	949	949	949	949	

TEST NUMBER: P907055

CATALOG NUMBER: DFN2DIP-TR2F0-050D030US835-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2066.5	2066.5	2066.5	2066.5	2066.5
2.5°	2075.8	2066.5	2045.9	2064.7	2060.9
5°	2066.5	2057.2	2032.8	2049.6	2044.1
7.5°	2049.6	2038.5	2012.3	2019.7	2010.3
10°	2027.2	2014.1	1976.8	1971.1	1959.9
12.5°	1999.2	1982.4	1931.8	1920.7	1900.0
15°	1965.5	1944.9	1881.4	1845.9	1827.2
17.5°	1926.2	1896.3	1817.7	1776.6	1746.6
20°	1881.4	1843.9	1750.4	1703.8	1662.5
22.5°	1832.8	1789.7	1681.2	1617.7	1589.7
25°	1784.1	1724.2	1600.8	1524.2	1496.0
27.5°	1726.2	1662.5	1526.0	1438.1	1395.1
30°	1664.5	1593.3	1443.7	1348.4	1297.8
32.5°	1604.6	1518.5	1365.3	1253.0	1206.2
35°	1537.3	1441.9	1277.4	1159.5	1118.3
37.5°	1471.8	1368.9	1195.1	1065.9	1019.3
40°	1402.6	1290.5	1108.9	976.2	927.6
42.5°	1331.6	1211.9	1023.0	884.5	837.9
45°	1256.8	1131.4	935.1	802.2	757.3
47.5°	1185.7	1053.0	851.0	718.1	677.0
50°	1107.2	974.4	768.7	639.5	600.4
52.5°	1030.4	890.1	690.1	566.7	531.2
55°	955.6	809.7	607.7	495.6	460.1
57.5°	879.0	729.4	534.9	430.2	400.2
60°	800.4	650.8	458.1	362.9	332.9
62.5°	723.8	574.2	392.7	303.0	288.1
65°	645.2	493.7	325.4	261.9	256.2
67.5°	570.4	418.9	261.9	230.0	224.4
70°	491.9	346.0	216.9	198.2	190.7
72.5°	417.1	278.6	181.4	166.5	162.7
75°	344.1	213.1	149.6	136.5	134.7
77.5°	271.2	151.4	117.9	110.3	106.5
80°	203.8	108.5	89.7	82.3	82.3
82.5°	142.1	73.0	61.7	57.9	57.9
85°	80.4	41.1	35.5	35.5	35.5
87.5°	30.0	14.9	14.9	13.1	13.1
90°	0.9	10.3	28.0	26.3	27.2
92.5°	17.7	24.0	24.9	25.7	25.7
95°	41.8	49.8	51.2	51.2	49.8
97.5°	69.5	76.9	80.1	80.1	80.1
100°	101.5	108.1	110.4	110.4	109.6
102.5°	135.3	140.2	143.3	144.2	143.3
105°	172.2	174.5	176.2	177.6	177.6
107.5°	208.8	212.2	212.2	212.8	208.8
110°	244.3	248.9	248.9	248.9	246.6

TEST NUMBER: P907055

CATALOG NUMBER: DFN2DIP-TR2F0-050D030US835-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	282.6	287.5	286.6	284.3	282.6
115°	320.4	324.9	323.5	322.7	320.4
117.5°	357.8	364.1	360.1	357.8	355.5
120°	395.6	401.9	395.6	395.6	393.0
122.5°	429.9	437.9	433.9	431.6	429.9
125°	466.0	473.1	470.8	468.2	467.4
127.5°	501.1	510.0	506.9	503.4	501.1
130°	534.0	544.3	542.9	541.2	538.0
132.5°	570.9	578.9	579.5	575.5	573.2
135°	602.7	611.5	613.3	612.4	610.1
137.5°	638.1	645.3	646.7	646.2	642.7
140°	669.3	676.5	680.5	680.5	677.3
142.5°	701.4	708.5	710.8	711.7	708.5
145°	731.7	737.4	742.0	742.8	739.7
147.5°	758.9	766.0	769.4	770.9	767.7
150°	786.9	791.8	794.9	797.5	794.9
152.5°	811.8	816.6	820.6	823.8	820.6
155°	836.7	838.9	841.5	845.5	843.0
157.5°	858.1	859.8	861.3	867.0	863.0
160°	877.3	879.0	879.9	884.7	881.3
162.5°	895.0	895.0	895.9	901.3	897.3
165°	910.2	909.3	909.3	915.0	911.0
167.5°	923.9	921.3	921.3	927.0	923.0
170°	934.2	931.9	931.1	936.8	931.9
172.5°	941.3	939.1	938.2	943.9	939.1
175°	947.1	944.8	943.1	948.8	943.9
177.5°	950.2	947.9	946.2	951.1	946.2
180°	948.8	948.8	948.8	948.8	948.8

TEST NUMBER: P907055

CATALOG NUMBER: DFN2DIP-TR2F0-050D030US835-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.34	14.28	14.20	15.15	16.25	9.33	10.26	10.19	11.14	12.23
	3H	15.01	15.84	15.88	16.73	17.85	10.51	11.34	11.38	12.23	13.35
	4H	15.60	16.39	16.49	17.28	18.42	10.95	11.74	11.84	12.63	13.77
	6H	16.01	16.74	16.91	17.64	18.78	11.26	11.99	12.16	12.89	14.04
	8H	16.13	16.82	17.04	17.74	18.88	11.35	12.04	12.26	12.96	14.10
	12H	16.19	16.84	17.10	17.75	18.92	11.39	12.05	12.30	12.96	14.13
4H	2H	13.37	14.16	14.26	15.05	16.19	9.92	10.71	10.81	11.60	12.74
	3H	15.18	15.84	16.09	16.76	17.91	11.26	11.92	12.17	12.84	13.99
	4H	15.86	16.46	16.78	17.38	18.55	11.80	12.40	12.71	13.32	14.49
	6H	16.36	16.87	17.29	17.82	18.99	12.21	12.72	13.14	13.66	14.84
	8H	16.52	17.00	17.45	17.94	19.13	12.33	12.81	13.26	13.75	14.94
	12H	16.61	17.04	17.56	18.00	19.19	12.39	12.82	13.34	13.78	14.97
8H	4H	15.83	16.31	16.76	17.25	18.44	12.08	12.56	13.01	13.49	14.68
	6H	16.38	16.77	17.33	17.75	18.94	12.57	12.97	13.53	13.95	15.14
	8H	16.58	16.93	17.54	17.90	19.11	12.75	13.10	13.72	14.07	15.28
	12H	16.71	17.01	17.67	17.98	19.23	12.86	13.17	13.83	14.13	15.39
12H	4H	15.79	16.22	16.74	17.17	18.37	12.08	12.51	13.03	13.47	14.66
	6H	16.35	16.70	17.32	17.67	18.88	12.62	12.97	13.58	13.94	15.15
	8H	16.56	16.87	17.53	17.83	19.09	12.82	13.13	13.79	14.09	15.35