

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P920629

Luminaire Tested: DFN2DIP-TR2F0-020D020US935-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P920629
REPORT IS A COMBINATION OF REPORTS P901741 AND P897145
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-TR2F0-020D020US935-FLLONL
Description: 2 foot, Triangle Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3228.7 lumens
Efficiency: N/A
Efficacy: 105.9 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.04' x L: 2.36' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 30.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9968
Total Harmonic Distortion (THDi): 0.064
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P920629

CATALOG NUMBER: DFN2DIP-TR2F0-020D020US935-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P920629

CATALOG NUMBER: DFN2DIP-TR2F0-020D020US935-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	108	108	108	108	100	100	100	100	85	85	85	71	71	71	59	59	59
1	98	94	90	87	91	87	84	81	74	72	70	63	61	59	52	51	50
2	90	82	76	71	83	76	71	66	65	61	58	55	52	50	46	44	42
3	82	72	65	59	75	67	61	55	58	53	49	49	45	42	41	38	36
4	75	64	56	50	69	60	52	47	51	46	41	43	39	36	36	33	31
5	69	57	49	43	63	53	46	40	46	40	36	39	35	31	33	29	27
6	63	51	43	37	58	48	40	35	41	36	31	35	31	27	30	26	24
7	59	46	38	33	54	43	36	31	37	32	28	32	28	24	27	24	21
8	54	42	34	29	50	39	32	27	34	29	24	29	25	22	25	21	19
9	51	38	31	26	47	36	29	24	31	26	22	27	23	19	23	20	17
10	47	35	28	23	44	33	26	22	29	23	20	25	21	18	21	18	15

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1494	1494	1494
5°	1495	1470	1481
10°	1480	1447	1458
15°	1456	1420	1425
20°	1425	1384	1390
25°	1393	1341	1350
30°	1354	1301	1301
35°	1317	1254	1248
40°	1272	1206	1198
45°	1226	1159	1147
50°	1177	1109	1088
55°	1125	1051	1033
60°	1066	983	970
65°	1001	911	896
70°	918	824	815
75°	805	720	737
80°	668	588	595
85°	453	370	371

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 1226 cd/sqm

TEST NUMBER: P920629

CATALOG NUMBER: DFN2DIP-TR2F0-020D020US935-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	63.1	2.0
10°-20°	177.4	5.5
20°-30°	260.8	8.1
30°-40°	302.9	9.4
40°-50°	302.5	9.4
50°-60°	263.8	8.2
60°-70°	195.0	6.0
70°-80°	110.3	3.4
80°-90°	30.6	0.9
90°-100°	33.7	1.0
100°-110°	107.1	3.3
110°-120°	183.2	5.7
120°-130°	241.0	7.5
130°-140°	270.5	8.4
140°-150°	265.3	8.2
150°-160°	222.5	6.9
160°-170°	147.6	4.6
170°-180°	51.6	1.6
0°-30°	501.3	15.5
0°-40°	804.1	24.9
0°-60°	1370.4	42.4
0°-90°	1706.3	52.8
90°-120°	324.0	10.0
90°-150°	1100.8	34.1
90°-180°	1522.0	47.1
0°-180°	3228.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	670	670	670	670	670	
5°	670	668	660	666	664	64
15°	638	634	626	628	625	180
25°	577	572	561	562	561	266
35°	498	492	481	477	474	311
45°	405	401	391	384	381	313
55°	307	303	295	287	284	274
65°	207	203	197	191	188	205
75°	108	107	104	100	101	116
85°	26	26	25	23	23	29
90°	0	6	16	15	16	3
95°	24	29	29	29	29	27
105°	99	100	101	102	102	104
115°	184	186	186	185	184	182
125°	267	272	270	269	268	239
135°	346	351	352	352	350	267
145°	420	423	426	426	425	262
155°	480	482	483	485	484	221
165°	522	522	522	525	523	147
175°	544	542	541	545	542	52
180°	545	545	545	545	545	

TEST NUMBER: P920629

CATALOG NUMBER: DFN2DIP-TR2F0-020D020US935-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	670.0	670.0	670.0	670.0	670.0
2.5°	673.9	670.7	663.6	670.0	668.8
5°	670.0	667.5	660.4	665.6	664.3
7.5°	665.6	661.7	654.6	659.8	658.5
10°	658.5	654.0	646.3	651.3	649.5
12.5°	648.8	645.0	637.2	640.4	639.1
15°	637.8	634.0	625.6	628.2	625.0
17.5°	624.3	620.5	612.1	615.3	612.1
20°	609.5	605.6	596.6	598.6	596.0
22.5°	594.7	588.9	580.5	580.5	579.2
25°	577.3	572.1	561.2	562.4	561.2
27.5°	557.9	553.4	545.1	543.2	539.9
30°	538.6	533.5	523.8	521.9	519.3
32.5°	518.0	514.2	503.9	500.0	497.4
35°	498.1	491.6	481.3	477.4	474.2
37.5°	475.5	469.7	459.3	454.9	451.6
40°	452.3	447.1	436.8	431.1	428.4
42.5°	429.7	424.6	414.3	407.9	404.0
45°	405.3	400.8	391.1	384.0	381.4
47.5°	381.4	376.9	366.6	359.5	355.7
50°	356.3	353.1	344.1	335.0	331.8
52.5°	331.8	327.3	318.9	311.9	307.4
55°	306.7	302.8	295.1	287.4	284.1
57.5°	281.5	278.4	269.9	262.3	259.6
60°	256.4	253.9	244.9	237.7	235.8
62.5°	232.0	227.4	221.0	214.6	212.0
65°	206.8	202.9	196.6	190.7	187.5
67.5°	181.1	177.8	172.0	167.6	165.0
70°	157.2	154.6	148.8	144.3	141.8
72.5°	132.8	130.2	126.9	122.4	120.5
75°	108.2	107.0	103.7	99.9	101.2
77.5°	86.4	83.8	82.4	80.5	78.6
80°	64.5	63.8	62.5	60.5	59.2
82.5°	43.8	43.8	43.2	40.6	40.6
85°	26.3	25.7	25.1	23.2	22.6
87.5°	11.6	10.3	9.0	7.1	6.5
90°	0.5	5.9	16.1	15.1	15.6
92.5°	10.2	13.8	14.3	14.8	14.8
95°	23.9	28.6	29.4	29.4	28.6
97.5°	39.9	44.2	46.0	46.0	46.0
100°	58.3	62.1	63.4	63.4	62.9
102.5°	77.7	80.4	82.2	82.7	82.2
105°	98.8	100.1	101.2	101.9	101.9
107.5°	119.9	121.8	121.8	122.2	119.9
110°	140.3	142.8	142.8	142.8	141.5



TEST NUMBER: P920629

CATALOG NUMBER: DFN2DIP-TR2F0-020D020US935-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	162.2	165.0	164.5	163.2	162.2
115°	183.9	186.5	185.7	185.2	183.9
117.5°	205.4	209.1	206.7	205.4	204.1
120°	227.0	230.7	227.0	227.0	225.6
122.5°	246.8	251.3	249.1	247.8	246.8
125°	267.4	271.6	270.3	268.8	268.3
127.5°	287.7	292.7	290.9	289.0	287.7
130°	306.5	312.5	311.6	310.6	308.8
132.5°	327.7	332.3	332.6	330.4	329.0
135°	345.9	351.0	352.0	351.5	350.2
137.5°	366.3	370.4	371.3	370.9	368.9
140°	384.2	388.3	390.6	390.6	388.8
142.5°	402.6	406.6	408.0	408.5	406.6
145°	420.0	423.3	425.9	426.4	424.6
147.5°	435.6	439.7	441.7	442.5	440.7
150°	451.7	454.4	456.2	457.7	456.2
152.5°	466.0	468.7	471.1	472.9	471.1
155°	480.3	481.6	483.0	485.3	483.9
157.5°	492.6	493.5	494.4	497.7	495.3
160°	503.6	504.5	505.1	507.8	505.8
162.5°	513.8	513.8	514.2	517.4	515.0
165°	522.5	521.9	521.9	525.2	523.0
167.5°	530.3	528.8	528.8	532.1	529.9
170°	536.2	534.9	534.4	537.7	534.9
172.5°	540.4	539.0	538.6	541.8	539.0
175°	543.6	542.3	541.3	544.6	541.8
177.5°	545.4	544.2	543.1	545.9	543.1
180°	544.6	544.6	544.6	544.6	544.6

TEST NUMBER: P920629

CATALOG NUMBER: DFN2DIP-TR2F0-020D020US935-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	8.80	9.69	9.73	10.64	11.87	8.38	9.26	9.31	10.21	11.44
	3H	10.44	11.23	11.38	12.19	13.45	9.98	10.77	10.92	11.73	12.99
	4H	11.01	11.76	11.97	12.73	13.99	10.55	11.30	11.51	12.27	13.53
	6H	11.39	12.09	12.36	13.06	14.33	10.93	11.63	11.90	12.60	13.87
	8H	11.49	12.15	12.47	13.14	14.41	11.03	11.69	12.01	12.68	13.95
	12H	11.53	12.16	12.51	13.14	14.44	11.07	11.70	12.05	12.68	13.97
4H	2H	9.25	10.01	10.22	10.97	12.23	8.92	9.67	9.88	10.63	11.89
	3H	11.09	11.72	12.07	12.72	13.99	10.71	11.34	11.68	12.33	13.61
	4H	11.79	12.37	12.77	13.35	14.65	11.40	11.97	12.38	12.96	14.26
	6H	12.29	12.78	13.28	13.79	15.09	11.89	12.38	12.88	13.40	14.69
	8H	12.43	12.89	13.42	13.89	15.20	12.03	12.49	13.02	13.49	14.81
	12H	12.49	12.91	13.50	13.93	15.24	12.08	12.50	13.10	13.52	14.84
8H	4H	11.98	12.44	12.98	13.45	14.76	11.63	12.09	12.62	13.09	14.41
	6H	12.58	12.97	13.61	14.01	15.32	12.23	12.61	13.25	13.66	14.97
	8H	12.79	13.13	13.82	14.16	15.49	12.43	12.77	13.46	13.80	15.13
	12H	12.91	13.20	13.94	14.23	15.60	12.54	12.83	13.57	13.86	15.23
12H	4H	11.96	12.38	12.98	13.40	14.72	11.62	12.04	12.64	13.06	14.38
	6H	12.61	12.95	13.64	13.98	15.31	12.27	12.61	13.30	13.64	14.97
	8H	12.84	13.13	13.87	14.16	15.53	12.49	12.79	13.52	13.81	15.19