

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P907263

Luminaire Tested: DFN2DIP-TR3F0-090D070US835-RLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P907263
REPORT IS A COMBINATION OF REPORTS P901860 AND P898751
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-TR3F0-090D070US835-RLLONL
Description: 3 foot, Triangle Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14580.0 lumens
Efficiency: N/A
Efficacy: 98.4 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 2.74' x L: 3.16' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 148.1
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9951
Total Harmonic Distortion (THDi): 0.07
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P907263

CATALOG NUMBER: DFN2DIP-TR3F0-090D070US835-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P907263

CATALOG NUMBER: DFN2DIP-TR3F0-090D070US835-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	108	108	108	108	100	100	100	100	85	85	85		71	71	71		58
1	99	95	91	88	91	88	85	82	75	73	71		63	62	60		52
2	90	83	77	72	84	77	72	68	66	63	59		56	53	51		47
3	83	74	67	61	76	69	62	57	59	54	50		50	47	44		42
4	76	66	58	52	70	61	54	49	53	48	43		45	41	38		38
5	70	59	51	45	65	55	48	43	47	42	38		41	36	33		34
6	65	53	45	39	60	49	42	37	43	37	33		37	33	29		31
7	60	48	40	35	55	45	38	33	39	34	30		34	29	26		29
8	56	44	36	31	52	41	34	29	36	30	26		31	27	24		26
9	52	40	33	28	48	38	31	26	33	28	24		29	24	21		25
10	49	37	30	25	45	35	28	24	30	25	22		27	22	19		23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4635	4635	4635
5°	4640	4558	4588
10°	4592	4464	4435
15°	4526	4313	4202
20°	4440	4106	3916
25°	4351	3875	3640
30°	4234	3638	3292
35°	4118	3383	2986
40°	4001	3121	2635
45°	3864	2830	2318
50°	3723	2536	2008
55°	3575	2223	1710
60°	3404	1897	1405
65°	3207	1565	1261
70°	2968	1256	1136
75°	2667	1099	1027
80°	2231	909	881
85°	1518	589	644

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 3864 cd/sqm

TEST NUMBER: P907263

CATALOG NUMBER: DFN2DIP-TR3F0-090D070US835-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	348.6	2.4
10°-20°	957.0	6.6
20°-30°	1343.6	9.2
30°-40°	1464.6	10.0
40°-50°	1346.2	9.2
50°-60°	1057.2	7.3
60°-70°	688.1	4.7
70°-80°	354.2	2.4
80°-90°	94.6	0.6
90°-100°	77.9	0.5
100°-110°	290.4	2.0
110°-120°	770.2	5.3
120°-130°	1277.4	8.8
130°-140°	1356.9	9.3
140°-150°	1261.1	8.6
150°-160°	1013.9	7.0
160°-170°	653.3	4.5
170°-180°	224.9	1.5
0°-30°	2649.2	18.2
0°-40°	4113.9	28.2
0°-60°	6517.2	44.7
0°-90°	7654.2	52.5
90°-120°	1138.5	7.8
90°-150°	5033.8	34.5
90°-180°	6926.0	47.5
0°-180°	14580.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3720	3720	3720	3720	3720	
5°	3720	3703	3659	3689	3679	353
15°	3538	3501	3386	3322	3289	997
25°	3212	3104	2882	2744	2693	1477
35°	2767	2595	2299	2087	2013	1732
45°	2262	2036	1683	1444	1363	1747
55°	1720	1458	1094	892	828	1537
65°	1161	889	586	471	461	1151
75°	619	384	269	246	242	655
85°	145	74	64	64	64	166
90°	2	20	34	43	46	14
95°	111	55	67	75	74	131
105°	520	571	104	123	130	555
115°	983	1012	1055	263	140	968
125°	1390	1412	1444	1456	1462	1239
135°	1720	1747	1762	1780	1776	1328
145°	1995	1993	2022	2034	2026	1248
155°	2197	2181	2202	2212	2198	1012
165°	2314	2304	2309	2321	2309	654
175°	2368	2356	2359	2371	2354	225
180°	2362	2362	2362	2362	2362	

TEST NUMBER: P907263

CATALOG NUMBER: DFN2DIP-TR3F0-090D070US835-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3719.7	3719.7	3719.7	3719.7	3719.7
2.5°	3736.5	3719.7	3682.5	3716.5	3709.7
5°	3719.7	3702.9	3659.0	3689.3	3679.3
7.5°	3689.3	3669.3	3622.2	3635.4	3618.6
10°	3649.0	3625.4	3558.3	3547.9	3527.9
12.5°	3598.6	3568.3	3477.2	3457.2	3420.0
15°	3537.9	3500.8	3386.5	3322.5	3289.0
17.5°	3467.2	3413.3	3271.8	3197.9	3144.0
20°	3386.5	3319.0	3150.7	3066.8	2992.5
22.5°	3299.0	3221.5	3026.1	2911.8	2861.5
25°	3211.5	3103.6	2881.5	2743.6	2692.9
27.5°	3107.2	2992.5	2746.8	2588.6	2511.1
30°	2996.1	2867.9	2598.6	2427.2	2336.1
32.5°	2888.2	2733.2	2457.5	2255.4	2171.1
35°	2767.2	2595.4	2299.3	2087.2	2012.9
37.5°	2649.3	2464.0	2151.1	1918.6	1834.7
40°	2524.7	2322.9	1996.1	1757.2	1669.7
42.5°	2396.8	2181.5	1841.4	1592.2	1508.2
45°	2262.2	2036.5	1683.2	1443.9	1363.2
47.5°	2134.3	1895.4	1531.8	1292.5	1218.6
50°	1992.9	1753.9	1383.6	1151.1	1080.7
52.5°	1854.7	1602.2	1242.2	1020.0	956.1
55°	1720.0	1457.5	1093.9	892.2	828.2
57.5°	1582.2	1312.9	962.9	774.3	720.4
60°	1440.7	1171.4	824.7	653.2	599.3
62.5°	1302.9	1033.6	706.8	545.4	518.6
65°	1161.4	888.6	585.7	471.4	461.1
67.5°	1026.8	753.9	471.4	413.9	403.9
70°	885.4	622.9	390.4	356.8	343.2
72.5°	750.7	501.4	326.4	299.6	292.9
75°	619.3	383.6	269.3	245.7	242.5
77.5°	488.2	272.5	212.1	198.6	191.8
80°	366.8	195.4	161.4	148.2	148.2
82.5°	255.7	131.4	111.1	104.3	104.3
85°	144.6	73.9	63.9	63.9	63.9
87.5°	53.9	26.8	26.8	23.6	23.6
90°	1.6	20.5	34.1	42.8	46.1
92.5°	42.8	35.9	41.0	44.5	46.1
95°	111.0	54.6	66.6	75.3	73.5
97.5°	199.9	59.9	87.1	92.4	94.0
100°	302.7	68.4	97.4	111.0	114.5
102.5°	415.3	412.1	100.9	119.6	124.8
105°	519.7	571.0	104.3	123.0	129.9
107.5°	641.0	683.7	107.8	126.5	133.4
110°	757.4	793.1	299.2	128.3	135.0

TEST NUMBER: P907263

CATALOG NUMBER: DFN2DIP-TR3F0-090D070US835-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	866.8	897.4	868.4	131.5	136.8
115°	982.9	1011.9	1054.7	263.3	140.3
117.5°	1083.8	1117.9	1147.1	902.5	454.7
120°	1196.6	1222.2	1253.1	1273.6	1042.8
122.5°	1292.2	1319.6	1354.0	1364.1	1365.9
125°	1389.7	1412.0	1444.5	1456.5	1461.5
127.5°	1478.6	1502.5	1528.3	1545.4	1547.0
130°	1562.4	1589.8	1608.5	1627.4	1625.8
132.5°	1647.9	1670.2	1688.9	1704.3	1702.7
135°	1719.7	1747.1	1762.4	1779.6	1776.2
137.5°	1794.8	1815.4	1832.6	1849.7	1844.6
140°	1868.3	1882.1	1900.8	1916.2	1907.7
142.5°	1930.0	1942.0	1964.1	1977.7	1969.2
145°	1995.0	1993.2	2022.2	2034.2	2025.7
147.5°	2051.2	2046.2	2075.2	2083.7	2077.0
150°	2106.0	2094.1	2121.5	2131.6	2123.1
152.5°	2152.1	2138.5	2164.1	2174.4	2162.5
155°	2196.6	2181.3	2201.8	2212.0	2198.4
157.5°	2232.5	2218.9	2234.3	2246.3	2232.5
160°	2263.4	2253.0	2263.4	2273.5	2261.5
162.5°	2290.6	2280.4	2288.9	2300.9	2285.5
165°	2314.5	2304.4	2309.4	2321.4	2309.4
167.5°	2333.4	2323.0	2328.3	2340.3	2324.9
170°	2348.8	2338.5	2341.9	2353.9	2338.5
172.5°	2359.0	2348.8	2352.3	2364.2	2348.8
175°	2367.5	2355.5	2359.0	2370.9	2353.9
177.5°	2370.9	2359.0	2360.8	2372.8	2357.3
180°	2362.4	2362.4	2362.4	2362.4	2362.4

TEST NUMBER: P907263

CATALOG NUMBER: DFN2DIP-TR3F0-090D070US835-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.65	13.51	13.60	14.46	15.70	8.63	9.48	9.57	10.44	11.67
	3H	14.32	15.09	15.28	16.05	17.31	9.82	10.58	10.77	11.54	12.80
	4H	14.93	15.65	15.90	16.61	17.88	10.26	10.98	11.23	11.95	13.22
	6H	15.34	16.00	16.32	16.98	18.26	10.58	11.24	11.56	12.22	13.50
	8H	15.47	16.09	16.45	17.08	18.36	10.67	11.30	11.65	12.29	13.57
	12H	15.52	16.12	16.51	17.11	18.41	10.71	11.31	11.70	12.29	13.60
4H	2H	12.67	13.39	13.65	14.36	15.63	9.22	9.94	10.20	10.91	12.18
	3H	14.49	15.09	15.48	16.09	17.37	10.57	11.17	11.55	12.16	13.45
	4H	15.18	15.73	16.17	16.72	18.02	11.11	11.66	12.11	12.65	13.96
	6H	15.69	16.16	16.69	17.17	18.48	11.53	12.00	12.53	13.01	14.32
	8H	15.86	16.30	16.86	17.30	18.62	11.65	12.09	12.66	13.10	14.42
	12H	15.95	16.34	16.97	17.37	18.69	11.72	12.11	12.74	13.13	14.46
8H	4H	15.15	15.59	16.15	16.59	17.91	11.39	11.83	12.39	12.83	14.15
	6H	15.71	16.07	16.73	17.12	18.43	11.90	12.26	12.93	13.31	14.63
	8H	15.92	16.23	16.95	17.27	18.61	12.09	12.41	13.12	13.44	14.78
	12H	16.05	16.33	17.09	17.36	18.74	12.20	12.48	13.24	13.51	14.89
12H	4H	15.10	15.50	16.12	16.52	17.84	11.39	11.79	12.42	12.81	14.14
	6H	15.68	16.00	16.72	17.03	18.37	11.95	12.27	12.98	13.30	14.64
	8H	15.89	16.17	16.93	17.20	18.59	12.15	12.43	13.19	13.46	14.84