

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P904775

Luminaire Tested: DFN2DIP-TR4F0-100D080US830-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P904775
REPORT IS A COMBINATION OF REPORTS P901973 AND P898849
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-TR4F0-100D080US830-FLLONL
Description: 4 foot, Triangle Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 16796.1 lumens
Efficiency: N/A
Efficacy: 104.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.43' x L: 3.96' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 160.2
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9972
Total Harmonic Distortion (THDi): 0.128
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P904775

CATALOG NUMBER: DFN2DIP-TR4F0-100D080US830-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P904775

CATALOG NUMBER: DFN2DIP-TR4F0-100D080US830-FLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	108	108	108	108	101	101	101	101	86	86	86		73	73	73		61
1	99	95	91	87	92	88	85	82	76	73	71		65	63	61		54
2	90	83	76	71	84	77	72	67	66	62	59		57	54	51		48
3	82	73	65	59	76	68	61	56	59	54	50		50	46	43		42
4	75	64	56	50	70	60	53	48	52	47	42		45	40	37		38
5	69	57	49	43	64	54	46	41	47	41	36		40	36	32		34
6	64	52	43	37	59	48	41	36	42	36	32		36	32	28		31
7	59	47	39	33	55	44	36	31	38	32	28		33	28	25		28
8	55	42	34	29	51	40	33	28	35	29	25		30	26	22		26
9	51	39	31	26	47	36	29	25	32	26	22		28	23	20		24
10	48	35	28	23	44	33	27	22	29	24	20		26	21	18		22

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2914	2914	2914
5°	2918	2873	2892
10°	2895	2834	2853
15°	2852	2788	2792
20°	2795	2723	2729
25°	2737	2645	2656
30°	2666	2573	2564
35°	2598	2488	2467
40°	2514	2402	2374
45°	2431	2316	2279
50°	2340	2225	2169
55°	2244	2120	2068
60°	2136	1996	1952
65°	2019	1868	1816
70°	1869	1711	1669
75°	1661	1523	1533
80°	1412	1284	1273
85°	1021	871	844

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 2431 cd/sqm

TEST NUMBER: P904775

CATALOG NUMBER: DFN2DIP-TR4F0-100D080US830-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	345.2	2.1
10°-20°	971.2	5.8
20°-30°	1427.3	8.5
30°-40°	1657.7	9.9
40°-50°	1655.7	9.9
50°-60°	1443.7	8.6
60°-70°	1067.2	6.4
70°-80°	603.8	3.6
80°-90°	163.9	1.0
90°-100°	83.9	0.5
100°-110°	312.8	1.9
110°-120°	829.6	4.9
120°-130°	1376.0	8.2
130°-140°	1461.6	8.7
140°-150°	1358.4	8.1
150°-160°	1092.1	6.5
160°-170°	703.7	4.2
170°-180°	242.2	1.4
0°-30°	2743.7	16.3
0°-40°	4401.4	26.2
0°-60°	7500.8	44.7
0°-90°	9335.7	55.6
90°-120°	1226.4	7.3
90°-150°	5422.4	32.3
90°-180°	7460.0	44.4
0°-180°	16796.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3668	3668	3668	3668	3668	
5°	3668	3654	3615	3643	3636	348
15°	3491	3470	3424	3438	3421	983
25°	3160	3132	3072	3078	3072	1454
35°	2726	2691	2634	2613	2596	1702
45°	2218	2194	2140	2102	2088	1712
55°	1679	1658	1615	1573	1555	1501
65°	1132	1111	1076	1044	1026	1119
75°	592	586	568	547	554	632
85°	144	141	138	127	124	161
90°	2	22	37	46	50	16
95°	120	59	72	81	79	142
105°	560	615	112	132	140	598
115°	1059	1090	1136	284	151	1042
125°	1497	1521	1556	1569	1574	1335
135°	1852	1882	1898	1917	1913	1431
145°	2149	2147	2178	2191	2182	1344
155°	2366	2350	2372	2383	2368	1090
165°	2493	2482	2488	2501	2488	704
175°	2550	2537	2541	2554	2536	243
180°	2545	2545	2545	2545	2545	

TEST NUMBER: P904775

CATALOG NUMBER: DFN2DIP-TR4F0-100D080US830-FLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3667.5	3667.5	3667.5	3667.5	3667.5
2.5°	3688.8	3671.2	3632.3	3667.5	3660.7
5°	3667.5	3653.7	3614.7	3642.8	3636.0
7.5°	3642.8	3621.8	3582.9	3611.4	3604.3
10°	3604.3	3579.6	3537.3	3565.4	3554.9
12.5°	3551.1	3530.2	3487.9	3505.5	3498.3
15°	3491.3	3470.3	3424.3	3438.5	3421.0
17.5°	3417.2	3396.3	3350.2	3367.8	3350.2
20°	3335.9	3315.0	3265.6	3276.1	3262.2
22.5°	3255.2	3223.4	3177.3	3177.3	3170.2
25°	3159.8	3131.7	3071.8	3078.5	3071.8
27.5°	3053.8	3029.1	2983.5	2973.1	2955.4
30°	2948.4	2919.9	2867.1	2856.7	2842.4
32.5°	2835.4	2814.4	2757.9	2736.6	2722.3
35°	2726.1	2691.0	2634.4	2613.1	2595.5
37.5°	2602.6	2570.8	2514.3	2489.6	2472.0
40°	2475.8	2447.3	2390.9	2359.5	2345.2
42.5°	2352.3	2323.8	2267.8	2232.2	2211.3
45°	2218.4	2193.7	2140.5	2102.0	2087.8
47.5°	2087.8	2063.1	2006.6	1967.7	1946.7
50°	1950.1	1932.5	1883.1	1833.7	1816.2
52.5°	1816.2	1791.5	1745.8	1706.9	1682.2
55°	1678.9	1657.6	1615.2	1572.9	1555.4
57.5°	1541.2	1523.5	1477.5	1435.3	1421.1
60°	1403.4	1389.6	1340.2	1301.3	1290.8
62.5°	1269.5	1244.8	1209.7	1174.5	1160.3
65°	1132.2	1110.9	1075.7	1043.9	1026.3
67.5°	991.2	973.2	941.8	917.1	902.9
70°	860.5	846.3	814.5	789.9	776.0
72.5°	726.6	712.4	694.8	670.1	659.6
75°	592.3	585.6	567.6	546.7	553.7
77.5°	472.6	458.4	451.2	440.7	430.3
80°	352.8	349.1	342.0	331.5	324.4
82.5°	239.9	239.9	236.5	222.3	222.3
85°	144.4	141.1	137.7	126.9	123.5
87.5°	63.6	56.5	49.4	38.9	35.2
90°	1.8	22.1	36.8	46.1	49.7
92.5°	46.1	38.7	44.2	47.9	49.7
95°	119.6	58.8	71.7	81.2	79.2
97.5°	215.4	64.5	93.8	99.5	101.2
100°	326.0	73.7	105.0	119.6	123.3
102.5°	447.4	443.8	108.7	128.8	134.5
105°	559.8	615.1	112.4	132.5	140.0
107.5°	690.5	736.4	116.1	136.2	143.6
110°	815.9	854.3	322.3	138.2	145.4

TEST NUMBER: P904775

CATALOG NUMBER: DFN2DIP-TR4F0-100D080US830-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	933.7	966.7	935.5	141.7	147.4
115°	1058.8	1090.1	1136.1	283.6	151.1
117.5°	1167.4	1204.2	1235.7	972.1	489.8
120°	1289.0	1316.5	1349.8	1371.9	1123.2
122.5°	1391.9	1421.5	1458.5	1469.4	1471.4
125°	1496.9	1521.0	1555.9	1568.9	1574.3
127.5°	1592.7	1618.5	1646.3	1664.6	1666.4
130°	1683.0	1712.5	1732.7	1753.0	1751.2
132.5°	1775.1	1799.1	1819.3	1835.9	1834.1
135°	1852.5	1882.0	1898.4	1917.0	1913.3
137.5°	1933.4	1955.5	1974.1	1992.4	1987.0
140°	2012.5	2027.4	2047.6	2064.2	2054.9
142.5°	2079.1	2091.9	2115.7	2130.4	2121.2
145°	2149.0	2147.0	2178.3	2191.2	2182.0
147.5°	2209.6	2204.1	2235.3	2244.6	2237.3
150°	2268.6	2255.7	2285.2	2296.1	2287.0
152.5°	2318.3	2303.6	2331.1	2342.3	2329.4
155°	2366.2	2349.8	2371.8	2382.7	2368.1
157.5°	2404.8	2390.2	2406.8	2419.7	2404.8
160°	2438.1	2427.0	2438.1	2449.0	2436.1
162.5°	2467.4	2456.5	2465.6	2478.5	2461.9
165°	2493.2	2482.3	2487.7	2500.6	2487.7
167.5°	2513.5	2502.4	2508.0	2520.9	2504.3
170°	2530.2	2518.9	2522.7	2535.6	2518.9
172.5°	2541.1	2530.2	2533.8	2546.7	2530.2
175°	2550.2	2537.3	2541.1	2553.9	2535.6
177.5°	2553.9	2541.1	2543.0	2555.9	2539.3
180°	2544.8	2544.8	2544.8	2544.8	2544.8

TEST NUMBER: P904775

CATALOG NUMBER: DFN2DIP-TR4F0-100D080US830-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.48	12.40	12.39	13.32	14.51	11.05	11.96	11.96	12.89	14.08
	3H	13.15	13.97	14.07	14.90	16.12	12.67	13.49	13.59	14.43	15.64
	4H	13.74	14.51	14.67	15.45	16.68	13.26	14.04	14.20	14.98	16.20
	6H	14.14	14.85	15.08	15.80	17.04	13.66	14.38	14.61	15.33	16.56
	8H	14.25	14.93	15.20	15.89	17.12	13.77	14.45	14.72	15.42	16.65
	12H	14.30	14.94	15.25	15.90	17.16	13.81	14.46	14.77	15.42	16.68
4H	2H	11.95	12.73	12.89	13.67	14.89	11.61	12.38	12.55	13.32	14.55
	3H	13.82	14.47	14.77	15.44	16.68	13.43	14.08	14.38	15.05	16.28
	4H	14.54	15.13	15.50	16.09	17.36	14.13	14.72	15.09	15.69	16.95
	6H	15.06	15.57	16.03	16.56	17.82	14.65	15.16	15.62	16.15	17.41
	8H	15.21	15.68	16.18	16.67	17.94	14.79	15.27	15.77	16.25	17.53
	12H	15.28	15.71	16.28	16.71	17.99	14.86	15.29	15.85	16.29	17.57
8H	4H	14.74	15.21	15.71	16.20	17.47	14.38	14.85	15.35	15.84	17.11
	6H	15.37	15.77	16.37	16.79	18.06	15.01	15.40	16.01	16.43	17.70
	8H	15.59	15.94	16.60	16.95	18.25	15.22	15.57	16.23	16.58	17.88
	12H	15.73	16.03	16.74	17.04	18.38	15.34	15.65	16.36	16.66	17.99
12H	4H	14.73	15.16	15.72	16.16	17.44	14.38	14.81	15.37	15.80	17.09
	6H	15.40	15.75	16.41	16.76	18.06	15.05	15.40	16.06	16.41	17.70
	8H	15.65	15.95	16.66	16.96	18.30	15.29	15.60	16.30	16.60	17.94