

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P910029

Luminaire Tested: DFN2DIP-TR4F0-040D110US840-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P910029
REPORT IS A COMBINATION OF REPORTS P902016 AND P898849
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-TR4F0-040D110US840-RLLONL
Description: 4 foot, Triangle Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14430.9 lumens
Efficiency: N/A
Efficacy: 123.7 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.43' x L: 3.96' x H: 0.1')
CIE Type: Semi-Indirect

Input Watts (W): 116.7
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9952
Total Harmonic Distortion (THDi): 0.069
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P910029

CATALOG NUMBER: DFN2DIP-TR4F0-040D110US840-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P910029

CATALOG NUMBER: DFN2DIP-TR4F0-040D110US840-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	101	101	101	101		90	90	90	90		69	69	69		50	50	50		32	32	32
1	92	88	84	81		82	78	75	73		60	58	57		44	43	42		29	28	27
2	84	77	71	67		75	69	64	60		53	50	47		39	37	35		25	24	23
3	77	68	61	56		68	61	55	50		47	43	40		34	32	30		23	21	20
4	70	60	53	47		62	54	48	43		42	38	34		31	28	26		20	19	18
5	64	53	46	40		57	48	41	37		37	33	29		28	25	22		19	17	15
6	59	48	40	35		53	43	36	32		34	29	26		25	22	20		17	15	14
7	55	43	36	30		49	39	32	28		30	26	22		23	20	17		15	14	12
8	51	39	32	27		45	35	29	24		28	23	20		21	18	15		14	12	11
9	47	36	28	24		42	32	26	22		25	21	18		19	16	14		13	11	10
10	44	32	26	21		39	29	23	19		23	19	16		18	15	12		12	10	9

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1326	1326	1326
5°	1328	1305	1314
10°	1315	1280	1271
15°	1297	1237	1205
20°	1273	1179	1124
25°	1249	1114	1045
30°	1216	1047	946
35°	1184	975	859
40°	1151	900	759
45°	1113	817	668
50°	1073	734	579
55°	1032	645	494
60°	984	551	407
65°	930	456	366
70°	863	368	331
75°	779	324	301
80°	659	272	261
85°	459	182	196

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 90°

Luminance: 1989 cd/sqm

TEST NUMBER: P910029

CATALOG NUMBER: DFN2DIP-TR4F0-040D110US840-RLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	156.5	1.1
10°-20°	429.5	3.0
20°-30°	603.0	4.2
30°-40°	657.4	4.6
40°-50°	604.2	4.2
50°-60°	474.5	3.3
60°-70°	308.9	2.1
70°-80°	159.0	1.1
80°-90°	47.2	0.3
90°-100°	123.6	0.9
100°-110°	460.8	3.2
110°-120°	1222.2	8.5
120°-130°	2027.1	14.0
130°-140°	2153.3	14.9
140°-150°	2001.2	13.9
150°-160°	1608.9	11.1
160°-170°	1036.7	7.2
170°-180°	356.8	2.5
0°-30°	1189.0	8.2
0°-40°	1846.4	12.8
0°-60°	2925.1	20.3
0°-90°	3440.1	23.8
90°-120°	1806.7	12.5
90°-150°	7988.3	55.4
90°-180°	10991.0	76.2
0°-180°	14430.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1670	1670	1670	1670	1670	
5°	1670	1662	1642	1656	1651	158
15°	1588	1571	1520	1491	1476	447
25°	1441	1393	1293	1231	1209	663
35°	1242	1165	1032	937	903	777
45°	1015	914	756	648	612	784
55°	772	654	491	400	372	690
65°	521	399	263	212	207	517
75°	278	172	121	110	109	294
85°	65	33	29	29	29	75
90°	3	32	54	68	73	13
95°	176	87	106	120	117	209
105°	825	906	166	195	206	881
115°	1560	1606	1674	418	223	1536
125°	2205	2241	2292	2311	2319	1967
135°	2729	2773	2797	2824	2819	2108
145°	3166	3163	3209	3228	3215	1980
155°	3486	3462	3494	3510	3489	1606
165°	3673	3657	3665	3684	3665	1038
175°	3757	3738	3744	3763	3736	358
180°	3749	3749	3749	3749	3749	

TEST NUMBER: P910029

CATALOG NUMBER: DFN2DIP-TR4F0-040D110US840-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1669.5	1669.5	1669.5	1669.5	1669.5
2.5°	1677.1	1669.5	1652.8	1668.1	1665.0
5°	1669.5	1661.9	1642.2	1655.9	1651.4
7.5°	1655.9	1646.9	1625.8	1631.6	1624.2
10°	1637.8	1627.2	1597.0	1592.4	1583.5
12.5°	1615.2	1601.5	1560.6	1551.7	1535.0
15°	1587.9	1571.2	1519.9	1491.3	1476.2
17.5°	1556.2	1532.0	1468.4	1435.3	1411.1
20°	1519.9	1489.7	1414.1	1376.4	1343.1
22.5°	1480.7	1445.9	1358.2	1306.9	1284.3
25°	1441.4	1393.0	1293.2	1231.4	1208.6
27.5°	1394.6	1343.1	1232.8	1161.9	1127.0
30°	1344.7	1287.2	1166.3	1089.3	1048.5
32.5°	1296.4	1226.8	1103.0	1012.3	974.4
35°	1242.0	1164.9	1032.0	936.8	903.4
37.5°	1189.1	1105.9	965.4	861.1	823.4
40°	1133.2	1042.6	896.0	788.7	749.4
42.5°	1075.7	979.1	826.5	714.6	676.9
45°	1015.3	914.0	755.5	648.1	611.9
47.5°	958.0	850.7	687.5	580.2	546.9
50°	894.4	787.2	621.0	516.6	485.0
52.5°	832.4	719.1	557.5	457.8	429.1
55°	772.0	654.2	491.0	400.4	371.7
57.5°	710.1	589.3	432.1	347.5	323.4
60°	646.6	525.7	370.1	293.2	269.0
62.5°	584.8	463.9	317.2	244.8	232.8
65°	521.3	398.8	262.9	211.6	206.9
67.5°	460.9	338.4	211.6	185.8	181.3
70°	397.4	279.5	175.2	160.2	154.0
72.5°	337.0	225.1	146.5	134.5	131.5
75°	277.9	172.2	120.9	110.3	108.9
77.5°	219.1	122.3	95.2	89.2	86.0
80°	164.6	87.7	72.4	66.6	66.6
82.5°	114.8	59.0	49.9	46.8	46.8
85°	64.9	33.2	28.7	28.7	28.7
87.5°	24.2	12.0	12.0	10.6	10.6
90°	2.6	32.5	54.1	68.0	73.1
92.5°	68.0	57.1	65.0	70.6	73.1
95°	176.2	86.6	105.6	119.5	116.6
97.5°	317.3	95.0	138.1	146.5	149.2
100°	480.3	108.6	154.6	176.2	181.7
102.5°	659.0	653.9	160.1	189.8	198.1
105°	824.7	906.2	165.6	195.2	206.2
107.5°	1017.3	1084.9	171.1	200.7	211.7
110°	1201.8	1258.6	474.8	203.6	214.2

TEST NUMBER: P910029

CATALOG NUMBER: DFN2DIP-TR4F0-040D110US840-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1375.5	1424.1	1378.1	208.7	217.1
115°	1559.7	1605.8	1673.9	417.8	222.6
117.5°	1719.9	1774.0	1820.4	1432.2	721.5
120°	1899.0	1939.5	1988.5	2021.0	1654.8
122.5°	2050.7	2094.2	2148.6	2164.7	2167.7
125°	2205.3	2240.8	2292.3	2311.3	2319.4
127.5°	2346.4	2384.4	2425.3	2452.4	2455.0
130°	2479.4	2522.9	2552.5	2582.5	2580.0
132.5°	2615.0	2650.5	2680.2	2704.6	2702.1
135°	2729.2	2772.6	2796.7	2824.2	2818.6
137.5°	2848.3	2880.8	2908.2	2935.3	2927.2
140°	2965.0	2986.8	3016.5	3040.9	3027.4
142.5°	3062.8	3081.8	3116.9	3138.6	3125.0
145°	3165.9	3163.0	3209.0	3228.1	3214.6
147.5°	3255.2	3247.1	3293.2	3306.7	3296.1
150°	3342.2	3323.2	3366.6	3382.7	3369.2
152.5°	3415.3	3393.7	3434.2	3450.7	3431.7
155°	3485.9	3461.6	3494.1	3510.3	3488.7
157.5°	3542.8	3521.2	3545.7	3564.7	3542.8
160°	3591.8	3575.3	3591.8	3607.8	3588.9
162.5°	3634.9	3618.9	3632.4	3651.4	3626.9
165°	3673.0	3656.8	3664.9	3683.9	3664.9
167.5°	3702.9	3686.5	3694.9	3713.9	3689.4
170°	3727.4	3711.0	3716.4	3735.5	3711.0
172.5°	3743.5	3727.4	3732.9	3751.9	3727.4
175°	3757.0	3738.0	3743.5	3762.6	3735.5
177.5°	3762.6	3743.5	3746.4	3765.4	3740.9
180°	3749.0	3749.0	3749.0	3749.0	3749.0

TEST NUMBER: P910029

CATALOG NUMBER: DFN2DIP-TR4F0-040D110US840-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	4.96	5.62	6.12	6.76	8.36	0.94	1.59	2.09	2.73	4.33
	3H	6.63	7.21	7.79	8.36	9.98	2.11	2.70	3.28	3.85	5.46
	4H	7.23	7.78	8.40	8.93	10.55	2.55	3.11	3.73	4.26	5.88
	6H	7.64	8.15	8.82	9.30	10.93	2.87	3.38	4.05	4.53	6.16
	8H	7.76	8.24	8.94	9.41	11.04	2.95	3.44	4.14	4.61	6.23
	12H	7.82	8.28	9.00	9.44	11.08	2.99	3.45	4.18	4.61	6.26
4H	2H	4.96	5.51	6.14	6.66	8.29	1.51	2.06	2.69	3.21	4.84
	3H	6.77	7.23	7.96	8.41	10.04	2.84	3.31	4.03	4.48	6.12
	4H	7.46	7.88	8.64	9.05	10.70	3.39	3.81	4.57	4.97	6.63
	6H	7.96	8.33	9.15	9.51	11.15	3.80	4.16	4.99	5.35	6.99
	8H	8.13	8.47	9.32	9.65	11.31	3.92	4.26	5.11	5.44	7.10
	12H	8.22	8.53	9.42	9.72	11.38	3.98	4.29	5.19	5.48	7.14
8H	4H	7.41	7.75	8.60	8.93	10.59	3.65	3.99	4.84	5.17	6.83
	6H	7.97	8.25	9.18	9.47	11.13	4.17	4.45	5.37	5.67	7.32
	8H	8.19	8.43	9.40	9.63	11.30	4.36	4.60	5.57	5.80	7.47
	12H	8.32	8.53	9.53	9.73	11.43	4.47	4.68	5.69	5.88	7.58
12H	4H	7.36	7.66	8.56	8.85	10.51	3.65	3.96	4.85	5.15	6.81
	6H	7.95	8.19	9.16	9.39	11.06	4.21	4.46	5.43	5.65	7.33
	8H	8.16	8.37	9.38	9.57	11.27	4.42	4.63	5.64	5.83	7.53

END OF REPORT