

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P910255

Luminaire Tested: DFN2DIP-TR4F0-110D050US840-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P910255
REPORT IS A COMBINATION OF REPORTS P901921 AND P898849
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-TR4F0-110D050US840-FLLONL
Description: 4 foot, Triangle Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 15996.3 lumens
Efficiency: N/A
Efficacy: 106.3 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.43' x L: 3.96' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 150.5
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9613
Total Harmonic Distortion (THDi): 0.083
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P910255

CATALOG NUMBER: DFN2DIP-TR4F0-110D050US840-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P910255

CATALOG NUMBER: DFN2DIP-TR4F0-110D050US840-FLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	112	112	112	112	105	105	105	105	94	94	94	83	83	83	73	73	73	69		
1	102	98	94	90	96	92	89	86	82	80	77	73	71	69	65	63	62	58		
2	93	85	79	74	87	81	75	70	72	68	64	64	61	58	57	55	52	49		
3	85	75	67	61	80	71	64	59	64	58	54	57	53	49	51	47	45	41		
4	78	66	58	52	73	63	56	50	57	51	46	51	46	42	45	42	38	35		
5	71	59	51	45	67	56	49	43	51	45	40	46	41	37	41	37	33	31		
6	66	53	45	39	62	51	43	38	46	40	35	41	36	32	37	33	30	27		
7	61	48	40	34	57	46	38	33	42	35	31	38	32	29	34	30	26	24		
8	57	44	36	30	53	42	35	29	38	32	27	35	29	26	31	27	24	21		
9	53	40	33	27	50	38	31	26	35	29	25	32	27	23	29	24	21	19		
10	50	37	30	25	47	35	29	24	32	26	22	29	24	21	27	22	19	18		

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3434	3434	3434
5°	3439	3386	3409
10°	3412	3340	3362
15°	3361	3285	3290
20°	3294	3209	3216
25°	3226	3118	3131
30°	3142	3032	3022
35°	3062	2932	2907
40°	2963	2831	2798
45°	2865	2729	2686
50°	2758	2623	2557
55°	2645	2499	2437
60°	2518	2353	2301
65°	2379	2201	2140
70°	2203	2016	1966
75°	1958	1795	1807
80°	1664	1513	1501
85°	1204	1027	994

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2865 cd/sqm

TEST NUMBER: P910255

CATALOG NUMBER: DFN2DIP-TR4F0-110D050US840-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	406.8	2.5
10°-20°	1144.7	7.2
20°-30°	1682.2	10.5
30°-40°	1953.7	12.2
40°-50°	1951.3	12.2
50°-60°	1701.5	10.6
60°-70°	1257.8	7.9
70°-80°	711.6	4.4
80°-90°	190.8	1.2
90°-100°	56.2	0.4
100°-110°	209.5	1.3
110°-120°	555.6	3.5
120°-130°	921.4	5.8
130°-140°	978.8	6.1
140°-150°	909.7	5.7
150°-160°	731.3	4.6
160°-170°	471.2	2.9
170°-180°	162.2	1.0
0°-30°	3233.7	20.2
0°-40°	5187.4	32.4
0°-60°	8840.2	55.3
0°-90°	11000.4	68.8
90°-120°	821.2	5.1
90°-150°	3631.1	22.7
90°-180°	4996.0	31.2
0°-180°	15996.3	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4322	4322	4322	4322	4322	
5°	4322	4306	4260	4293	4285	410
15°	4115	4090	4036	4052	4032	1159
25°	3724	3691	3620	3628	3620	1714
35°	3213	3172	3105	3080	3059	2006
45°	2614	2585	2523	2477	2461	2018
55°	1979	1954	1904	1854	1833	1769
65°	1334	1309	1268	1230	1210	1319
75°	698	690	669	644	653	745
85°	170	166	162	150	146	190
90°	1	15	25	31	33	15
95°	80	39	48	54	53	95
105°	375	412	75	89	94	401
115°	709	730	761	190	101	698
125°	1002	1019	1042	1051	1054	894
135°	1240	1260	1271	1284	1281	958
145°	1439	1438	1459	1467	1461	900
155°	1584	1574	1588	1596	1586	730
165°	1670	1662	1666	1674	1666	472
175°	1708	1699	1702	1710	1698	163
180°	1704	1704	1704	1704	1704	

TEST NUMBER: P910255

CATALOG NUMBER: DFN2DIP-TR4F0-110D050US840-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4322.4	4322.4	4322.4	4322.4	4322.4
2.5°	4347.5	4326.8	4280.9	4322.4	4314.4
5°	4322.4	4306.1	4260.2	4293.2	4285.4
7.5°	4293.2	4268.6	4222.8	4256.3	4247.9
10°	4247.9	4218.7	4168.9	4201.9	4189.6
12.5°	4185.3	4160.5	4110.8	4131.5	4123.1
15°	4114.7	4090.0	4035.7	4052.5	4031.8
17.5°	4027.3	4002.7	3948.5	3969.2	3948.5
20°	3931.7	3907.0	3848.8	3861.1	3844.9
22.5°	3836.5	3798.9	3744.7	3744.7	3736.3
25°	3724.0	3691.0	3620.4	3628.3	3620.4
27.5°	3599.2	3570.1	3516.3	3503.9	3483.2
30°	3474.8	3441.3	3379.1	3366.8	3350.0
32.5°	3341.6	3317.0	3250.4	3225.2	3208.4
35°	3212.9	3171.5	3104.8	3079.7	3059.0
37.5°	3067.4	3029.9	2963.3	2934.2	2913.5
40°	2917.9	2884.4	2817.8	2780.8	2764.0
42.5°	2772.4	2738.9	2672.7	2630.8	2606.2
45°	2614.5	2585.4	2522.7	2477.4	2460.6
47.5°	2460.6	2431.6	2364.9	2319.1	2294.3
50°	2298.4	2277.7	2219.4	2161.2	2140.5
52.5°	2140.5	2111.3	2057.6	2011.7	1982.6
55°	1978.6	1953.5	1903.7	1853.8	1833.1
57.5°	1816.3	1795.6	1741.4	1691.5	1674.8
60°	1654.1	1637.8	1579.5	1533.7	1521.4
62.5°	1496.2	1467.1	1425.6	1384.2	1367.5
65°	1334.3	1309.2	1267.8	1230.3	1209.6
67.5°	1168.1	1147.0	1109.9	1080.9	1064.1
70°	1014.2	997.4	960.0	930.9	914.5
72.5°	856.4	839.6	818.9	789.8	777.4
75°	698.0	690.1	668.9	644.3	652.7
77.5°	556.9	540.2	531.8	519.5	507.2
80°	415.9	411.4	403.0	390.7	382.3
82.5°	282.7	282.7	278.7	262.0	262.0
85°	170.3	166.2	162.3	149.5	145.5
87.5°	74.9	66.6	58.2	45.8	41.4
90°	1.2	14.7	24.6	30.9	33.2
92.5°	30.9	26.0	29.6	32.1	33.2
95°	80.1	39.4	48.1	54.3	53.0
97.5°	144.2	43.2	62.8	66.7	67.8
100°	218.3	49.4	70.3	80.1	82.6
102.5°	299.6	297.2	72.8	86.2	90.1
105°	374.9	411.9	75.2	88.8	93.7
107.5°	462.4	493.1	77.8	91.2	96.2
110°	546.3	572.1	215.8	92.5	97.4

TEST NUMBER: P910255

CATALOG NUMBER: DFN2DIP-TR4F0-110D050US840-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	625.2	647.3	626.4	94.9	98.7
115°	709.0	729.9	760.8	190.0	101.2
117.5°	781.7	806.4	827.5	651.0	328.0
120°	863.1	881.6	903.8	918.7	752.1
122.5°	932.1	951.9	976.6	984.0	985.3
125°	1002.4	1018.6	1042.0	1050.6	1054.3
127.5°	1066.5	1083.8	1102.5	1114.7	1115.9
130°	1127.0	1146.8	1160.2	1173.9	1172.8
132.5°	1188.7	1204.8	1218.2	1229.4	1228.2
135°	1240.5	1260.3	1271.2	1283.7	1281.2
137.5°	1294.6	1309.5	1321.9	1334.2	1330.6
140°	1347.7	1357.7	1371.1	1382.2	1376.1
142.5°	1392.2	1400.9	1416.8	1426.6	1420.5
145°	1439.1	1437.7	1458.6	1467.3	1461.2
147.5°	1479.7	1475.9	1496.9	1503.1	1498.2
150°	1519.1	1510.6	1530.2	1537.6	1531.5
152.5°	1552.4	1542.6	1561.1	1568.5	1559.8
155°	1584.5	1573.5	1588.2	1595.6	1585.8
157.5°	1610.3	1600.5	1611.6	1620.3	1610.3
160°	1632.6	1625.2	1632.6	1639.9	1631.3
162.5°	1652.2	1645.0	1651.0	1659.7	1648.6
165°	1669.5	1662.2	1665.9	1674.5	1665.9
167.5°	1683.1	1675.7	1679.5	1688.1	1677.0
170°	1694.3	1686.8	1689.3	1697.9	1686.8
172.5°	1701.6	1694.3	1696.8	1705.4	1694.3
175°	1707.8	1699.1	1701.6	1710.2	1697.9
177.5°	1710.2	1701.6	1702.9	1711.5	1700.4
180°	1704.0	1704.0	1704.0	1704.0	1704.0

TEST NUMBER: P910255

CATALOG NUMBER: DFN2DIP-TR4F0-110D050US840-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.13	14.19	13.90	14.99	15.96	12.70	13.76	13.47	14.56	15.53
	3H	14.80	15.75	15.59	16.56	17.57	14.33	15.28	15.12	16.09	17.10
	4H	15.40	16.30	16.21	17.12	18.13	14.93	15.82	15.73	16.64	17.66
	6H	15.81	16.64	16.63	17.46	18.49	15.33	16.16	16.15	16.99	18.02
	8H	15.92	16.71	16.75	17.55	18.58	15.44	16.23	16.27	17.08	18.11
	12H	15.97	16.73	16.81	17.57	18.62	15.49	16.25	16.33	17.09	18.14
4H	2H	13.61	14.51	14.42	15.33	16.35	13.27	14.17	14.08	14.99	16.00
	3H	15.50	16.25	16.32	17.10	18.13	15.10	15.85	15.93	16.71	17.74
	4H	16.22	16.90	17.06	17.75	18.81	15.81	16.50	16.65	17.35	18.41
	6H	16.74	17.34	17.60	18.21	19.27	16.34	16.93	17.19	17.80	18.87
	8H	16.90	17.45	17.76	18.32	19.40	16.49	17.04	17.34	17.91	18.99
	12H	16.98	17.48	17.86	18.37	19.45	16.56	17.06	17.44	17.95	19.03
8H	4H	16.43	16.98	17.29	17.85	18.93	16.07	16.62	16.93	17.49	18.57
	6H	17.07	17.53	17.96	18.44	19.52	16.71	17.17	17.59	18.08	19.15
	8H	17.29	17.70	18.19	18.60	19.70	16.92	17.33	17.82	18.24	19.33
	12H	17.43	17.79	18.33	18.69	19.84	17.05	17.41	17.95	18.31	19.45
12H	4H	16.43	16.92	17.30	17.81	18.90	16.07	16.57	16.95	17.46	18.54
	6H	17.10	17.51	18.00	18.41	19.51	16.75	17.16	17.65	18.06	19.16
	8H	17.35	17.71	18.25	18.61	19.76	17.00	17.36	17.90	18.25	19.40