

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P912883

Luminaire Tested: DFN2DIP-TR4F0-080D070US850-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P912883
REPORT IS A COMBINATION OF REPORTS P901951 AND P898849
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-TR4F0-080D070US850-FLLONL
Description: 4 foot, Triangle Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 16468.7 lumens
Efficiency: N/A
Efficacy: 129.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.43' x L: 3.96' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 127.2
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9957
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P912883

CATALOG NUMBER: DFN2DIP-TR4F0-080D070US850-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P912883

CATALOG NUMBER: DFN2DIP-TR4F0-080D070US850-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	108	108	108	108	100	100	100	100	85	85	85		72	72	72		59
1	99	94	90	87	91	87	84	81	75	72	70		63	61	60		52
2	90	82	76	71	83	76	71	66	65	61	58		55	52	50		46
3	82	72	65	59	76	67	61	56	58	53	49		49	45	42		41
4	75	64	56	50	69	60	53	47	51	46	42		44	40	36		37
5	69	57	49	43	63	53	46	41	46	40	36		39	35	31		33
6	63	51	43	37	59	48	41	35	41	36	31		35	31	28		30
7	59	46	38	33	54	43	36	31	38	32	28		32	28	24		27
8	54	42	34	29	50	39	32	27	34	29	25		30	25	22		25
9	51	38	31	26	47	36	29	25	31	26	22		27	23	20		23
10	47	35	28	23	44	33	26	22	29	24	20		25	21	18		21

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2742	2742	2742
5°	2747	2704	2722
10°	2725	2668	2686
15°	2685	2624	2628
20°	2630	2563	2569
25°	2577	2490	2501
30°	2509	2422	2414
35°	2445	2342	2322
40°	2367	2261	2235
45°	2288	2180	2145
50°	2202	2095	2042
55°	2112	1996	1947
60°	2011	1879	1838
65°	1900	1758	1709
70°	1759	1611	1571
75°	1564	1434	1443
80°	1329	1209	1198
85°	962	820	794

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 2288 cd/sqm

TEST NUMBER: P912883

CATALOG NUMBER: DFN2DIP-TR4F0-080D070US850-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	324.9	2.0
10°-20°	914.2	5.6
20°-30°	1343.5	8.2
30°-40°	1560.4	9.5
40°-50°	1558.4	9.5
50°-60°	1358.9	8.3
60°-70°	1004.5	6.1
70°-80°	568.4	3.5
80°-90°	154.6	0.9
90°-100°	86.4	0.5
100°-110°	322.1	2.0
110°-120°	854.1	5.2
120°-130°	1416.6	8.6
130°-140°	1504.8	9.1
140°-150°	1398.5	8.5
150°-160°	1124.4	6.8
160°-170°	724.5	4.4
170°-180°	249.4	1.5
0°-30°	2582.6	15.7
0°-40°	4143.0	25.2
0°-60°	7060.4	42.9
0°-90°	8787.9	53.4
90°-120°	1262.6	7.7
90°-150°	5582.5	33.9
90°-180°	7681.0	46.6
0°-180°	16468.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3452	3452	3452	3452	3452	
5°	3452	3439	3402	3429	3423	328
15°	3286	3267	3223	3237	3220	926
25°	2974	2948	2892	2898	2892	1369
35°	2566	2533	2480	2460	2443	1602
45°	2088	2065	2015	1979	1965	1612
55°	1580	1560	1520	1481	1464	1413
65°	1066	1046	1012	983	966	1054
75°	558	551	534	515	521	595
85°	136	133	130	119	116	152
90°	2	23	38	48	51	15
95°	123	61	74	84	82	146
105°	576	633	116	136	144	616
115°	1090	1122	1170	292	156	1073
125°	1541	1566	1602	1615	1621	1375
135°	1907	1938	1954	1974	1970	1473
145°	2212	2210	2243	2256	2246	1384
155°	2436	2419	2442	2453	2438	1123
165°	2567	2556	2561	2574	2561	725
175°	2626	2612	2616	2629	2610	250
180°	2620	2620	2620	2620	2620	

TEST NUMBER: P912883

CATALOG NUMBER: DFN2DIP-TR4F0-080D070US850-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3452.1	3452.1	3452.1	3452.1	3452.1
2.5°	3472.2	3455.6	3419.0	3452.1	3445.8
5°	3452.1	3439.1	3402.5	3428.9	3422.6
7.5°	3428.9	3409.2	3372.6	3399.3	3392.7
10°	3392.7	3369.4	3329.6	3355.9	3346.2
12.5°	3342.6	3322.9	3283.1	3299.6	3293.0
15°	3286.3	3266.6	3223.2	3236.6	3220.1
17.5°	3216.5	3196.8	3153.4	3170.1	3153.4
20°	3140.1	3120.4	3073.9	3083.8	3070.7
22.5°	3064.1	3034.1	2990.8	2990.8	2984.1
25°	2974.2	2947.8	2891.5	2897.8	2891.5
27.5°	2874.5	2851.3	2808.3	2798.5	2781.9
30°	2775.3	2748.4	2698.9	2689.0	2675.6
32.5°	2668.9	2649.2	2595.9	2575.9	2562.6
35°	2566.0	2533.0	2479.7	2459.7	2443.1
37.5°	2449.8	2419.8	2366.7	2343.4	2326.9
40°	2330.5	2303.6	2250.5	2220.9	2207.5
42.5°	2214.2	2187.4	2134.6	2101.1	2081.5
45°	2088.1	2064.8	2014.8	1978.6	1965.3
47.5°	1965.3	1942.0	1888.7	1852.1	1832.4
50°	1835.6	1819.1	1772.5	1726.0	1709.5
52.5°	1709.5	1686.2	1643.3	1606.7	1583.4
55°	1580.2	1560.1	1520.4	1480.6	1464.0
57.5°	1450.7	1434.2	1390.8	1351.0	1337.6
60°	1321.0	1308.1	1261.5	1224.9	1215.0
62.5°	1194.9	1171.8	1138.6	1105.6	1092.1
65°	1065.7	1045.7	1012.5	982.6	966.0
67.5°	932.9	916.0	886.4	863.2	849.8
70°	810.0	796.6	766.8	743.5	730.4
72.5°	683.9	670.6	654.0	630.8	620.9
75°	557.5	551.2	534.3	514.6	521.2
77.5°	444.8	431.4	424.7	414.9	405.0
80°	332.1	328.6	321.9	312.1	305.3
82.5°	225.8	225.8	222.6	209.2	209.2
85°	136.0	132.7	129.6	119.4	116.2
87.5°	59.9	53.2	46.5	36.6	33.2
90°	1.8	22.7	37.8	47.5	51.1
92.5°	47.5	39.8	45.5	49.4	51.1
95°	123.1	60.6	73.9	83.5	81.5
97.5°	221.7	66.4	96.6	102.5	104.2
100°	335.7	75.9	108.0	123.1	127.0
102.5°	460.6	457.0	111.9	132.6	138.4
105°	576.3	633.2	115.7	136.4	144.1
107.5°	710.9	758.2	119.6	140.3	147.9
110°	840.0	879.5	331.8	142.3	149.7

TEST NUMBER: P912883

CATALOG NUMBER: DFN2DIP-TR4F0-080D070US850-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	961.3	995.2	963.1	145.8	151.7
115°	1090.0	1122.2	1169.7	292.0	155.6
117.5°	1201.9	1239.8	1272.1	1000.9	504.3
120°	1327.0	1355.4	1389.7	1412.4	1156.5
122.5°	1433.0	1463.4	1501.6	1512.8	1514.8
125°	1541.2	1565.9	1602.0	1615.3	1620.8
127.5°	1639.8	1666.3	1694.9	1713.8	1715.6
130°	1732.7	1763.1	1783.8	1804.8	1803.0
132.5°	1827.5	1852.3	1873.0	1890.1	1888.3
135°	1907.1	1937.5	1954.5	1973.6	1969.8
137.5°	1990.4	2013.3	2032.4	2051.3	2045.7
140°	2071.9	2087.2	2108.0	2125.1	2115.6
142.5°	2140.4	2153.7	2178.2	2193.3	2183.8
145°	2212.5	2210.5	2242.6	2255.9	2246.5
147.5°	2274.8	2269.2	2301.4	2310.8	2303.4
150°	2335.6	2322.4	2352.7	2363.9	2354.5
152.5°	2386.7	2371.6	2400.0	2411.4	2398.2
155°	2436.0	2419.1	2441.8	2453.1	2438.0
157.5°	2475.8	2460.8	2477.8	2491.1	2475.8
160°	2510.1	2498.6	2510.1	2521.3	2508.0
162.5°	2540.3	2529.0	2538.4	2551.7	2534.6
165°	2566.8	2555.6	2561.1	2574.4	2561.1
167.5°	2587.7	2576.2	2582.1	2595.4	2578.3
170°	2604.8	2593.4	2597.2	2610.5	2593.4
172.5°	2616.1	2604.8	2608.7	2621.9	2604.8
175°	2625.6	2612.2	2616.1	2629.3	2610.5
177.5°	2629.3	2616.1	2618.1	2631.4	2614.2
180°	2619.9	2619.9	2619.9	2619.9	2619.9

TEST NUMBER: P912883

CATALOG NUMBER: DFN2DIP-TR4F0-080D070US850-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.08	11.97	12.01	12.92	14.14	10.65	11.54	11.57	12.48	13.71
	3H	12.74	13.54	13.68	14.50	15.74	12.27	13.07	13.21	14.02	15.27
	4H	13.33	14.09	14.28	15.05	16.30	12.86	13.61	13.81	14.57	15.83
	6H	13.73	14.43	14.69	15.39	16.66	13.25	13.95	14.22	14.92	16.19
	8H	13.84	14.50	14.81	15.48	16.75	13.36	14.03	14.33	15.01	16.27
	12H	13.88	14.52	14.86	15.49	16.78	13.40	14.04	14.38	15.01	16.30
4H	2H	11.54	12.30	12.50	13.26	14.51	11.20	11.96	12.16	12.92	14.17
	3H	13.41	14.04	14.38	15.03	16.30	13.02	13.65	13.99	14.64	15.91
	4H	14.13	14.70	15.11	15.69	16.98	13.72	14.30	14.70	15.28	16.58
	6H	14.64	15.14	15.63	16.15	17.44	14.23	14.73	15.23	15.74	17.03
	8H	14.79	15.26	15.79	16.26	17.57	14.38	14.85	15.37	15.85	17.15
	12H	14.87	15.29	15.88	16.30	17.62	14.45	14.87	15.46	15.88	17.19
8H	4H	14.33	14.79	15.32	15.79	17.10	13.97	14.43	14.96	15.43	16.74
	6H	14.96	15.34	15.98	16.39	17.69	14.60	14.98	15.61	16.02	17.33
	8H	15.18	15.52	16.21	16.55	17.87	14.81	15.15	15.84	16.18	17.50
	12H	15.31	15.61	16.34	16.63	18.00	14.93	15.23	15.96	16.25	17.62
12H	4H	14.31	14.73	15.32	15.75	17.06	13.96	14.38	14.97	15.40	16.71
	6H	14.99	15.33	16.01	16.36	17.68	14.64	14.98	15.66	16.01	17.33
	8H	15.23	15.53	16.26	16.55	17.92	14.88	15.17	15.90	16.20	17.56

END OF REPORT