

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P905126

Luminaire Tested: DFN2DIP-4P4F0-080D040US835-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P905126
REPORT IS A COMBINATION OF REPORTS P899101 AND P895967
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P4F0-080D040US835-FLLFLL
Description: 4 foot, 90deg - 4way Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 11460.0 lumens
Efficiency: N/A
Efficacy: 98.3 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 4.07' x L: 4.07' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 116.6
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9971
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P905126

CATALOG NUMBER: DFN2DIP-4P4F0-080D040US835-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P905126

CATALOG NUMBER: DFN2DIP-4P4F0-080D040US835-FLLFL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	112	112	112	112	106	106	106	106	94	94	94		83	83	83		74
1	102	98	94	90	96	92	89	86	83	80	77		74	71	70		65
2	93	85	79	74	88	81	75	70	72	68	64		65	61	58		57
3	85	75	67	61	80	71	64	59	64	58	54		57	53	49		51
4	78	67	58	52	73	63	56	50	57	51	46		51	46	42		46
5	71	59	51	45	67	56	49	43	51	45	40		46	41	37		41
6	66	53	45	39	62	51	43	38	46	40	35		41	36	32		37
7	61	48	40	34	58	46	39	33	42	36	31		38	33	29		34
8	57	44	36	31	54	42	35	30	38	32	28		35	29	26		31
9	53	40	33	27	50	39	31	26	35	29	25		32	27	23		29
10	50	37	30	25	47	36	29	24	32	27	22		30	25	21		27

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2019	2019	2019
5°	2023	1992	2005
10°	2007	1966	1979
15°	1977	1934	1937
20°	1937	1890	1895
25°	1898	1837	1845
30°	1848	1787	1782
35°	1801	1729	1715
40°	1744	1670	1652
45°	1686	1611	1587
50°	1623	1549	1512
55°	1557	1477	1443
60°	1483	1392	1364
65°	1401	1304	1270
70°	1298	1197	1170
75°	1154	1069	1079
80°	982	906	903
85°	713	623	609

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 1686 cd/sqm

TEST NUMBER: P905126

CATALOG NUMBER: DFN2DIP-4P4F0-080D040US835-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	293.0	2.6
10°-20°	824.3	7.2
20°-30°	1211.5	10.6
30°-40°	1407.0	12.3
40°-50°	1405.3	12.3
50°-60°	1225.4	10.7
60°-70°	905.8	7.9
70°-80°	512.5	4.5
80°-90°	138.9	1.2
90°-100°	78.3	0.7
100°-110°	248.7	2.2
110°-120°	425.6	3.7
120°-130°	559.8	4.9
130°-140°	628.3	5.5
140°-150°	616.2	5.4
150°-160°	516.9	4.5
160°-170°	342.8	3.0
170°-180°	119.8	1.0
0°-30°	2328.8	20.3
0°-40°	3735.8	32.6
0°-60°	6366.4	55.6
0°-90°	7923.6	69.1
90°-120°	752.7	6.6
90°-150°	2556.9	22.3
90°-180°	3536.0	30.9
0°-180°	11460.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3113	3113	3113	3113	3113	
5°	3113	3101	3068	3092	3086	295
15°	2963	2946	2906	2918	2904	835
25°	2682	2658	2607	2613	2607	1234
35°	2314	2284	2236	2218	2203	1445
45°	1883	1862	1817	1784	1772	1453
55°	1425	1407	1371	1335	1320	1274
65°	961	943	913	886	871	950
75°	503	497	482	464	470	537
85°	123	120	117	108	105	137
90°	1	14	37	35	36	11
95°	56	66	68	68	66	62
105°	230	233	235	237	237	242
115°	427	433	431	430	427	422
125°	621	631	628	624	623	555
135°	804	815	818	816	814	621
145°	976	983	989	990	986	610
155°	1116	1119	1122	1127	1124	513
165°	1214	1212	1212	1220	1215	342
175°	1263	1260	1257	1265	1259	120
180°	1265	1265	1265	1265	1265	

TEST NUMBER: P905126

CATALOG NUMBER: DFN2DIP-4P4F0-080D040US835-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3112.8	3112.8	3112.8	3112.8	3112.8
2.5°	3130.9	3116.0	3083.0	3112.8	3107.1
5°	3112.8	3101.1	3068.1	3091.9	3086.2
7.5°	3091.9	3074.1	3041.1	3065.2	3059.2
10°	3059.2	3038.2	3002.3	3026.1	3017.3
12.5°	3014.1	2996.3	2960.4	2975.3	2969.3
15°	2963.3	2945.5	2906.4	2918.5	2903.6
17.5°	2900.4	2882.6	2843.5	2858.5	2843.5
20°	2831.5	2813.7	2771.8	2780.7	2768.9
22.5°	2762.9	2735.9	2696.8	2696.8	2690.8
25°	2681.9	2658.1	2607.3	2613.0	2607.3
27.5°	2592.0	2571.1	2532.3	2523.4	2508.5
30°	2502.5	2478.3	2433.6	2424.7	2412.6
32.5°	2406.6	2388.8	2340.8	2322.7	2310.7
35°	2313.8	2284.0	2236.0	2217.9	2203.0
37.5°	2209.0	2182.0	2134.1	2113.1	2098.2
40°	2101.4	2077.2	2029.3	2002.6	1990.5
42.5°	1996.6	1972.4	1924.8	1894.6	1876.9
45°	1882.9	1861.9	1816.8	1784.1	1772.1
47.5°	1772.1	1751.1	1703.1	1670.1	1652.3
50°	1655.2	1640.3	1598.3	1556.4	1541.5
52.5°	1541.5	1520.5	1481.8	1448.8	1427.8
55°	1424.9	1406.8	1371.0	1335.1	1320.1
57.5°	1308.1	1293.2	1254.1	1218.2	1206.1
60°	1191.2	1179.5	1137.5	1104.5	1095.6
62.5°	1077.5	1056.6	1026.7	996.9	984.8
65°	961.0	942.9	913.0	886.0	871.1
67.5°	841.2	826.0	799.3	778.4	766.3
70°	730.4	718.3	691.4	670.4	658.6
72.5°	616.7	604.7	589.7	568.8	559.9
75°	502.7	497.0	481.8	464.0	470.0
77.5°	401.1	389.0	383.0	374.1	365.2
80°	299.5	296.3	290.3	281.4	275.3
82.5°	203.6	203.6	200.7	188.6	188.6
85°	122.6	119.7	116.9	107.7	104.8
87.5°	54.0	48.0	41.9	33.0	29.9
90°	1.1	13.7	37.4	35.1	36.2
92.5°	23.6	32.0	33.2	34.3	34.3
95°	55.7	66.4	68.3	68.3	66.4
97.5°	92.7	102.6	106.8	106.8	106.8
100°	135.4	144.2	147.2	147.2	146.1
102.5°	180.4	186.9	191.1	192.2	191.1
105°	229.6	232.6	234.9	236.8	236.8
107.5°	278.4	283.0	283.0	283.7	278.4
110°	325.7	331.8	331.8	331.8	328.8

TEST NUMBER: P905126

CATALOG NUMBER: DFN2DIP-4P4F0-080D040US835-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	376.8	383.3	382.1	379.1	376.8
115°	427.1	433.3	431.3	430.2	427.1
117.5°	477.1	485.5	480.2	477.1	474.1
120°	527.5	535.8	527.5	527.5	524.0
122.5°	573.2	583.9	578.6	575.5	573.2
125°	621.3	630.8	627.8	624.3	623.2
127.5°	668.2	680.0	675.8	671.2	668.2
130°	712.0	725.8	723.9	721.6	717.4
132.5°	761.2	771.9	772.7	767.3	764.3
135°	803.6	815.4	817.7	816.5	813.5
137.5°	850.9	860.4	862.3	861.5	857.0
140°	892.4	902.0	907.3	907.3	903.1
142.5°	935.2	944.7	947.7	948.9	944.7
145°	975.6	983.2	989.3	990.5	986.3
147.5°	1011.8	1021.3	1025.9	1027.8	1023.6
150°	1049.2	1055.7	1059.9	1063.3	1059.9
152.5°	1082.4	1088.8	1094.2	1098.4	1094.2
155°	1115.5	1118.6	1122.0	1127.4	1123.9
157.5°	1144.2	1146.4	1148.3	1156.0	1150.6
160°	1169.7	1172.0	1173.1	1179.6	1175.0
162.5°	1193.3	1193.3	1194.5	1201.7	1196.4
165°	1213.6	1212.4	1212.4	1220.0	1214.7
167.5°	1231.9	1228.4	1228.4	1236.1	1230.7
170°	1245.6	1242.5	1241.4	1249.0	1242.5
172.5°	1255.1	1252.1	1250.9	1258.6	1252.1
175°	1262.8	1259.7	1257.4	1265.0	1258.6
177.5°	1267.0	1263.9	1261.6	1268.1	1261.6
180°	1265.0	1265.0	1265.0	1265.0	1265.0

TEST NUMBER: P905126

CATALOG NUMBER: DFN2DIP-4P4F0-080D040US835-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.34	12.40	12.11	13.20	14.16	10.89	11.96	11.66	12.75	13.72
	3H	13.02	13.97	13.80	14.78	15.78	12.53	13.48	13.31	14.29	15.29
	4H	13.62	14.52	14.42	15.33	16.34	13.12	14.03	13.93	14.84	15.85
	6H	14.03	14.86	14.85	15.69	16.71	13.53	14.36	14.35	15.19	16.21
	8H	14.14	14.94	14.97	15.78	16.80	13.64	14.44	14.47	15.28	16.30
	12H	14.20	14.96	15.03	15.79	16.84	13.69	14.45	14.52	15.28	16.33
4H	2H	11.82	12.72	12.63	13.54	14.55	11.47	12.37	12.27	13.18	14.19
	3H	13.71	14.47	14.53	15.31	16.34	13.30	14.06	14.12	14.91	15.93
	4H	14.44	15.13	15.27	15.97	17.03	14.01	14.70	14.85	15.55	16.60
	6H	14.97	15.57	15.82	16.44	17.49	14.54	15.13	15.39	16.00	17.06
	8H	15.13	15.68	15.98	16.55	17.62	14.69	15.25	15.54	16.11	17.18
	12H	15.21	15.71	16.09	16.60	17.68	14.76	15.26	15.64	16.15	17.23
8H	4H	14.65	15.21	15.51	16.07	17.14	14.28	14.83	15.13	15.70	16.77
	6H	15.30	15.76	16.18	16.67	17.74	14.92	15.38	15.80	16.28	17.35
	8H	15.53	15.93	16.42	16.84	17.92	15.13	15.54	16.03	16.44	17.53
	12H	15.67	16.03	16.57	16.92	18.06	15.26	15.62	16.15	16.51	17.65
12H	4H	14.65	15.15	15.52	16.03	17.11	14.28	14.78	15.15	15.67	16.74
	6H	15.33	15.74	16.22	16.64	17.73	14.96	15.37	15.85	16.27	17.36
	8H	15.59	15.95	16.48	16.84	17.98	15.21	15.57	16.10	16.46	17.60