

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P222854

Luminaire Tested: **LSR2B15NFL259027D010 2LBDLC*MMS**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P222854
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (155)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR2B15NFL259027D010 2LBDLC*MMS
Description: 1500 Lumen, 2inch Portfolio LED Cylinder
NARROW FLOOD OPTIC
LENSED CAST ROUND TRIM WITH MATTE METALLIC SILVER
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 991.3 lumens
Efficiency: N/A
Efficacy: 69.3 lumens/watt
Spacing Criteria (0/90/45): 0.39 / 0.39 / 0.35
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P222854

CATALOG NUMBER: LSR2B15NFL259027D010 2LBDLC*MMS

Luminous Intensity Polar Plot





TEST NUMBER: P222854

CATALOG NUMBER: LSR2B15NFL259027D010 2LBDLC*MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	115	113	112	110	113	111	110	108	107	106	105	104	103	102	100	100	99	97		
2	112	109	106	104	110	107	104	102	104	102	100	101	99	98	98	97	96	95		
3	109	105	101	99	107	103	100	98	101	98	96	99	97	95	96	95	93	92		
4	106	101	97	95	104	100	97	94	98	95	93	96	94	92	95	93	91	90		
5	103	98	94	91	102	97	94	91	95	92	90	94	91	89	93	90	89	88		
6	101	95	91	89	99	94	91	88	93	90	88	92	89	87	91	88	87	86		
7	98	92	89	86	97	92	88	86	91	88	85	90	87	85	89	86	85	84		
8	96	90	86	84	95	90	86	84	89	86	83	88	85	83	87	85	83	82		
9	94	88	84	82	93	88	84	82	87	84	82	86	83	81	85	83	81	80		
10	92	86	82	80	91	86	82	80	85	82	80	84	82	80	84	81	79	79		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2277982
5°	2103313
10°	1423666
15°	484340
20°	177908
25°	94325
30°	48484
35°	22603
40°	7382
45°	3725
50°	1748
55°	675
60°	775
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P222854

CATALOG NUMBER: LSR2B15NFL259027D010 2LBDLC*MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	460.1	46.4
10°-20°	386.9	39.0
20°-30°	106.2	10.7
30°-40°	30.9	3.1
40°-50°	5.7	0.6
50°-60°	1.3	0.1
60°-70°	0.1	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	953.2	96.2
0°-40°	984.1	99.3
0°-60°	991.2	100.0
0°-90°	991.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	991.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5881	
5°	5409	460
15°	1208	387
25°	221	106
35°	48	31
45°	7	6
55°	1	1
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P222854

CATALOG NUMBER: LSR2B15NFL259027D010 2LBDLC*MMS

CANDELA DISTRIBUTION (FULL):

	0°
0°	5881.0
1°	5846.8
2°	5786.3
3°	5699.4
4°	5580.3
5°	5409.4
6°	5176.0
7°	4884.1
8°	4527.7
9°	4106.8
10°	3619.6
11°	3085.5
12°	2529.9
13°	1999.7
14°	1547.6
15°	1207.8
17.5°	681.5
20°	431.6
22.5°	307.6
25°	220.7
27.5°	156.2
30°	108.4
32.5°	76.2
35°	47.8
37.5°	19.5
40°	14.6
42.5°	10.7
45°	6.8
47.5°	3.9
50°	2.9
52.5°	2.0
55°	1.0
57.5°	1.0
60°	1.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P222854

CATALOG NUMBER: LSR2B15NFL259027D010 2LBDLC*MMS

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°		0.0
87.5°		0.0



(END OF REPORT)