

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P222319

Luminaire Tested: **LSR2B15NFL259727D010 2LBDL\*B**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P222319  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (155)  
Test Lab: INNOVATION CENTER-P2  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR2B15NFL259727D010 2LBDL\*B  
Description: 1500 Lumen, 2inch Portfolio LED Cylinder  
NARROW FLOOD OPTIC  
LENSED SPUN ROUND TRIM WITH BLACK FINISH  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 950.0 lumens  
Efficiency: N/A  
Efficacy: 66.4 lumens/watt  
Spacing Criteria (0/90/45): 0.39 / 0.39 / 0.35  
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')  
CIE Type: Direct

Input Watts (W): 14.3  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P222319

CATALOG NUMBER: LSR2B15NFL259727D010 2LBDL\*B

### Luminous Intensity Polar Plot





TEST NUMBER: P222319

CATALOG NUMBER: LSR2B15NFL259727D010 2LBDL\*B

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		100
1	115	113	112	110	113	111	110	108	107	106	105	104	103	102	100	100	99	97		97
2	112	109	106	104	110	107	104	102	104	102	100	101	99	98	98	97	96	95		95
3	109	105	101	99	107	103	100	98	101	98	96	99	97	95	96	95	93	92		92
4	106	101	97	95	104	100	97	94	98	95	93	96	94	92	95	93	91	90		90
5	103	98	94	91	102	97	94	91	95	92	90	94	91	89	93	90	89	88		88
6	101	95	91	89	99	94	91	88	93	90	88	92	89	87	91	88	87	86		86
7	98	92	89	86	97	92	88	86	91	88	85	90	87	85	89	87	85	84		84
8	96	90	86	84	95	90	86	84	89	86	83	88	85	83	87	85	83	82		82
9	94	88	84	82	93	88	84	82	87	84	82	86	83	81	85	83	81	80		80
10	92	86	82	80	91	86	82	80	85	82	80	84	82	80	84	81	79	79		79

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	2183082
5°	2015672
10°	1364353
15°	464169
20°	170488
25°	90393
30°	46471
35°	21704
40°	7079
45°	3615
50°	1687
55°	608
60°	697
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P222319

CATALOG NUMBER: LSR2B15NFL259727D010 2LBDL\*B

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	441.0	46.4
10°-20°	370.8	39.0
20°-30°	101.8	10.7
30°-40°	29.7	3.1
40°-50°	5.5	0.6
50°-60°	1.2	0.1
60°-70°	0.1	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	913.5	96.2
0°-40°	943.2	99.3
0°-60°	949.9	100.0
0°-90°	950.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	950.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	5636	
5°	5184	441
15°	1158	371
25°	212	102
35°	46	30
45°	7	5
55°	1	1
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P222319

CATALOG NUMBER: LSR2B15NFL259727D010 2LBDL\*B

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	5636.0
1°	5603.2
2°	5545.2
3°	5461.9
4°	5347.8
5°	5184.0
6°	4960.4
7°	4680.6
8°	4339.0
9°	3935.7
10°	3468.8
11°	2957.0
12°	2424.5
13°	1916.4
14°	1483.2
15°	1157.5
17.5°	653.1
20°	413.6
22.5°	294.8
25°	211.5
27.5°	149.7
30°	103.9
32.5°	73.0
35°	45.9
37.5°	18.7
40°	14.0
42.5°	10.3
45°	6.6
47.5°	3.7
50°	2.8
52.5°	1.9
55°	0.9
57.5°	0.9
60°	0.9
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P222319

CATALOG NUMBER: LSR2B15NFL259727D010 2LBDL\*B

**CANDELA DISTRIBUTION (continued):**

0°  
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







85°		0.0
87.5°		0.0



(END OF REPORT)