

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P224667

Luminaire Tested: **LSSQWM2B15FL408040D010 2LBDLC*MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P224667
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14835)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQWM2B15FL408040D010 2LBDLC*MW
Description: 1500 Lumen, 2inch Portfolio LED Cylinder
FLOOD OPTIC
LENSED CAST ROUND TRIM WITH MATTE WHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1345.1 lumens
Efficiency: N/A
Efficacy: 94.1 lumens/watt
Spacing Criteria (0/90/45): 0.61 / 0.61 / 0.59
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P224667

CATALOG NUMBER: LSSQWM2B15FL408040D010 2LBDLC*MW

Luminous Intensity Polar Plot





TEST NUMBER: P224667

CATALOG NUMBER: LSSQWM2B15FL408040D010 2LBDLC*MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10		0		
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	112	110	108	112	110	108	106	106	104	103	102	101	100	99	98	97	95			
2	110	106	102	99	108	104	101	98	101	98	96	98	96	94	95	94	92	91			
3	105	100	96	93	104	99	95	92	96	93	90	94	91	89	92	90	88	86			
4	101	95	90	87	100	94	90	86	92	88	85	90	87	85	88	86	84	82			
5	98	91	86	82	96	90	85	82	88	84	81	86	83	80	85	82	80	79			
6	94	86	82	78	93	86	81	78	84	80	77	83	79	77	82	79	76	75			
7	90	83	78	74	89	82	77	74	81	77	74	80	76	73	79	76	73	72			
8	87	79	74	71	86	79	74	71	78	74	71	77	73	70	76	73	70	69			
9	84	76	71	68	83	76	71	68	75	71	68	74	70	67	73	70	67	66			
10	81	73	68	65	80	73	68	65	72	68	65	71	68	65	71	67	65	64			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1217738
5°	1195561
10°	1062794
15°	835865
20°	556188
25°	319302
30°	161285
35°	75894
40°	30541
45°	15119
50°	8316
55°	5808
60°	5345
65°	3208
70°	3964
75°	2544
80°	3792
85°	0



TEST NUMBER: P224667

CATALOG NUMBER: LSSQWM2B15FL408040D010 2LBDLC*MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	281.6	20.9
10°-20°	564.6	42.0
20°-30°	351.3	26.1
30°-40°	108.0	8.0
40°-50°	23.7	1.8
50°-60°	8.4	0.6
60°-70°	4.3	0.3
70°-80°	2.5	0.2
80°-90°	0.7	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1197.5	89.0
0°-40°	1305.5	97.1
0°-60°	1337.6	99.4
0°-90°	1345.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1345.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3144	
5°	3075	282
15°	2084	565
25°	747	351
35°	160	108
45°	28	24
55°	9	8
65°	4	4
75°	2	3
85°	0	1
90°	0	



TEST NUMBER: P224667

CATALOG NUMBER: LSSQWM2B15FL408040D010 2LBDLC*MW

CANDELA DISTRIBUTION (FULL):

0°	
0°	3143.8
2.5°	3130.0
5°	3074.8
7.5°	2935.0
10°	2702.1
12.5°	2422.5
15°	2084.4
17.5°	1715.1
20°	1349.3
22.5°	1023.2
25°	747.1
27.5°	526.3
30°	360.6
32.5°	243.3
35°	160.5
37.5°	96.6
40°	60.4
42.5°	41.4
45°	27.6
47.5°	19.0
50°	13.8
52.5°	12.1
55°	8.6
57.5°	6.9
60°	6.9
62.5°	5.2
65°	3.5
67.5°	3.5
70°	3.5
72.5°	3.5
75°	1.7
77.5°	1.7
80°	1.7
82.5°	1.7
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)