

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P225527

Luminaire Tested: **LSR2B20FL409024D010 2LBDL*H**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P225527
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14832)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR2B20FL409024D010 2LBDL*H
Description: 2000 Lumen, 2inch Portfolio LED Cylinder
FLOOD OPTIC
LENSED SPUN ROUND TRIM WITH HAZE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1250.1 lumens
Efficiency: N/A
Efficacy: 59.8 lumens/watt
Spacing Criteria (0/90/45): 0.6 / 0.6 / 0.6
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P225527

CATALOG NUMBER: LSR2B20FL409024D010 2LBDL*H

Luminous Intensity Polar Plot





TEST NUMBER: P225527

CATALOG NUMBER: LSR2B20FL409024D010 2LBDL*H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					0
RW	70	50	30	10		70	50	30	10		50	30	10			50	30	10			0
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111			106	106	106			100
1	114	112	110	108		112	110	108	106		106	104	103			102	101	100			95
2	110	105	102	99		108	104	101	98		101	98	96			98	96	94			90
3	105	100	96	92		103	98	95	91		96	93	90			94	91	89			86
4	101	95	90	86		99	94	89	86		91	88	85			90	86	84			82
5	97	90	85	81		96	89	84	81		87	83	80			86	82	80			78
6	93	86	81	77		92	85	80	77		84	79	76			82	79	76			74
7	90	82	77	73		88	81	76	73		80	76	73			79	75	72			71
8	86	78	73	70		85	78	73	70		77	72	69			76	72	69			68
9	83	75	70	67		82	75	70	67		74	69	66			73	69	66			65
10	80	72	67	64		79	72	67	64		71	67	64			70	66	64			62

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1098901
5°	1062310
10°	937324
15°	738460
20°	507466
25°	306438
30°	166116
35°	85352
40°	41716
45°	19775
50°	10365
55°	6956
60°	4028
65°	1558
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P225527

CATALOG NUMBER: LSR2B20FL409024D010 2LBDL*H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	249.6	20.0
10°-20°	501.3	40.1
20°-30°	334.9	26.8
30°-40°	121.3	9.7
40°-50°	31.3	2.5
50°-60°	9.4	0.7
60°-70°	2.3	0.2
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1085.9	86.9
0°-40°	1207.1	96.6
0°-60°	1247.8	99.8
0°-90°	1250.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1250.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2837	
5°	2732	250
15°	1842	501
25°	717	335
35°	180	121
45°	36	31
55°	10	9
65°	2	2
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P225527

CATALOG NUMBER: LSR2B20FL409024D010 2LBDL*H

CANDELA DISTRIBUTION (FULL):

	0°
0°	2837.0
2.5°	2811.2
5°	2732.1
7.5°	2587.7
10°	2383.1
12.5°	2132.0
15°	1841.5
17.5°	1532.0
20°	1231.1
22.5°	954.3
25°	717.0
27.5°	522.7
30°	371.4
32.5°	261.3
35°	180.5
37.5°	125.5
40°	82.5
42.5°	53.3
45°	36.1
47.5°	25.8
50°	17.2
52.5°	13.8
55°	10.3
57.5°	6.9
60°	5.2
62.5°	3.4
65°	1.7
67.5°	1.7
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)