

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P225371

Luminaire Tested: **LSSQ2B20FL409030D010 2LBDC*MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P225371
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14835)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQ2B20FL409030D010 2LBDC*MW
Description: 2000 Lumen, 2inch Portfolio LED Cylinder
FLOOD OPTIC
CAST ROUND TRIM WITH MATTE WHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1308.3 lumens
Efficiency: N/A
Efficacy: 62.6 lumens/watt
Spacing Criteria (0/90/45): 0.61 / 0.61 / 0.59
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P225371

CATALOG NUMBER: LSSQ2B20FL409030D010 2LBDC*MW

Luminous Intensity Polar Plot





TEST NUMBER: P225371

CATALOG NUMBER: LSSQ2B20FL409030D010 2LBDC*MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	114	112	110	108		112	110	108	106		106	104	103		102	101	100		99	98	97
2	110	106	102	99		108	104	101	98		101	98	96		98	96	94		95	94	92
3	105	100	96	93		104	99	95	92		96	93	90		94	91	89		92	90	88
4	101	95	90	87		100	94	90	86		92	88	85		90	87	85		88	86	84
5	98	91	86	82		96	90	85	82		88	84	81		86	83	80		85	82	80
6	94	86	82	78		93	86	81	78		84	80	77		83	79	77		82	79	76
7	90	83	78	74		89	82	77	74		81	77	74		80	76	73		79	76	73
8	87	79	74	71		86	79	74	71		78	74	71		77	73	70		76	73	70
9	84	76	71	68		83	76	71	68		75	71	68		74	70	67		73	70	67
10	81	73	68	65		80	73	68	65		72	68	65		71	68	65		71	67	65

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1184310
5°	1162744
10°	1033609
15°	812928
20°	540937
25°	310541
30°	156857
35°	73814
40°	29681
45°	14736
50°	8075
55°	5673
60°	5190
65°	3116
70°	3851
75°	2544
80°	3792
85°	0



TEST NUMBER: P225371

CATALOG NUMBER: LSSQ2B20FL409030D010 2LBDC*MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	273.9	20.9
10°-20°	549.1	42.0
20°-30°	341.6	26.1
30°-40°	105.0	8.0
40°-50°	23.1	1.8
50°-60°	8.2	0.6
60°-70°	4.2	0.3
70°-80°	2.5	0.2
80°-90°	0.7	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1164.6	89.0
0°-40°	1269.6	97.0
0°-60°	1300.9	99.4
0°-90°	1308.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1308.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3058	
5°	2990	274
15°	2027	549
25°	727	342
35°	156	105
45°	27	23
55°	8	8
65°	3	4
75°	2	2
85°	0	1
90°	0	



TEST NUMBER: P225371

CATALOG NUMBER: LSSQ2B20FL409030D010 2LBDC*MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	3057.5
2.5°	3044.1
5°	2990.4
7.5°	2854.5
10°	2627.9
12.5°	2356.1
15°	2027.2
17.5°	1668.1
20°	1312.3
22.5°	995.1
25°	726.6
27.5°	511.8
30°	350.7
32.5°	236.6
35°	156.1
37.5°	94.0
40°	58.7
42.5°	40.3
45°	26.9
47.5°	18.5
50°	13.4
52.5°	11.7
55°	8.4
57.5°	6.7
60°	6.7
62.5°	5.0
65°	3.4
67.5°	3.4
70°	3.4
72.5°	3.4
75°	1.7
77.5°	1.7
80°	1.7
82.5°	1.7
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)