

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P#

Luminaire Tested: **LSSQ2B20WFL558050D010 2LBDL*MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P#
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14810)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQ2B20WFL558050D010 2LBDL*MW
Description: 2000 Lumen, 2inch Portfolio LED Cylinder
WIDE FLOOD OPTIC
LENSED SPUN ROUND TRIM WITH MATTE WHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1710.4 lumens
Efficiency: N/A
Efficacy: 81.8 lumens/watt
Spacing Criteria (0/90/45): 0.79 / 0.79 / 0.84
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P#

CATALOG NUMBER: LSSQ2B20WFL558050D010 2LBDL*MW

Luminous Intensity Polar Plot





TEST NUMBER: P#

CATALOG NUMBER: LSSQ2B20WFL558050D010 2LBDL*MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10			50	30	10			50
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111			106	106	106			102
1	113	110	108	106		111	108	106	104		104	102	101			101	99	98			97
2	108	102	98	95		105	101	97	94		98	94	92			95	92	90			92
3	102	95	90	86		100	94	89	85		91	87	84			89	85	83			87
4	97	89	83	79		95	88	82	78		85	81	77			83	80	76			82
5	91	83	77	72		90	82	76	72		80	75	71			78	74	71			77
6	87	78	71	67		85	77	71	67		75	70	66			74	69	66			73
7	82	73	67	62		81	72	66	62		71	66	62			70	65	62			69
8	78	69	62	58		77	68	62	58		67	62	58			66	61	58			65
9	74	65	59	55		73	64	58	54		63	58	54			62	57	54			61
10	71	61	55	51		70	61	55	51		60	55	51			59	54	51			58

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	802348
5°	797209
10°	741136
15°	650639
20°	560846
25°	479616
30°	380626
35°	265323
40°	167874
45°	102437
50°	60562
55°	33158
60°	7282
65°	6416
70°	5323
75°	7034
80°	5130
85°	10222



TEST NUMBER: P#

CATALOG NUMBER: LSSQ2B20WFL558050D010 2LBDL*MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	190.3	11.1
10°-20°	451.9	26.4
20°-30°	509.8	29.8
30°-40°	352.7	20.6
40°-50°	150.3	8.8
50°-60°	43.5	2.5
60°-70°	6.4	0.4
70°-80°	4.0	0.2
80°-90°	1.6	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1152.0	67.4
0°-40°	1504.6	88.0
0°-60°	1698.5	99.3
0°-90°	1710.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1710.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2071	
5°	2050	190
15°	1622	452
25°	1122	510
35°	561	353
45°	187	150
55°	49	43
65°	7	6
75°	5	4
85°	2	2
90°	0	



TEST NUMBER: P#

CATALOG NUMBER: LSSQ2B20WFL558050D010 2LBDL*MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	2071.4
2.5°	2069.0
5°	2050.3
7.5°	1987.2
10°	1884.3
12.5°	1758.1
15°	1622.5
17.5°	1482.2
20°	1360.6
22.5°	1246.1
25°	1122.2
27.5°	991.3
30°	851.0
32.5°	699.0
35°	561.1
37.5°	434.8
40°	332.0
42.5°	250.2
45°	187.0
47.5°	135.6
50°	100.5
52.5°	72.5
55°	49.1
57.5°	21.0
60°	9.4
62.5°	7.0
65°	7.0
67.5°	4.7
70°	4.7
72.5°	4.7
75°	4.7
77.5°	2.3
80°	2.3
82.5°	2.3
85°	2.3
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)