

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P#

Luminaire Tested: **LSSQ2B20WFL559050D010 2LBDL*GPH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P#
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14806)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQ2B20WFL559050D010 2LBDL*GPH
Description: 2000 Lumen, 2inch Portfolio LED Cylinder
WIDE FLOOD OPTIC
LENSED SPUN ROUND TRIM WITH GRAPHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1395.4 lumens
Efficiency: N/A
Efficacy: 66.8 lumens/watt
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.83
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P#

CATALOG NUMBER: LSSQ2B20WFL559050D010 2LBDL*GPH

Luminous Intensity Polar Plot





TEST NUMBER: P#

CATALOG NUMBER: LSSQ2B20WFL559050D010 2LBDL*GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10		50	30	10			50	30	10			50
RCR																				
0	119	119	119	119	116	116	116	116		111	111	111			106	106	106			102
1	113	111	108	106	111	108	106	104		104	103	101			101	99	98			97
2	108	103	99	95	105	101	97	94		98	95	92			95	92	90			92
3	102	95	90	86	100	94	89	86		91	88	84			89	86	83			87
4	97	89	83	79	95	88	83	79		86	81	78			84	80	77			82
5	92	83	77	73	90	82	77	72		80	75	72			79	74	71			77
6	87	78	72	67	85	77	71	67		75	70	67			74	70	66			73
7	83	73	67	63	81	72	67	62		71	66	62			70	65	62			69
8	78	69	63	58	77	68	62	58		67	62	58			66	61	58			65
9	75	65	59	55	74	64	59	55		63	58	54			62	58	54			62
10	71	61	55	51	70	61	55	51		60	55	51			59	54	51			58

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	664879
5°	657582
10°	607760
15°	532221
20°	458867
25°	391745
30°	309868
35°	214396
40°	138749
45°	84195
50°	49233
55°	27620
60°	10536
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P#

CATALOG NUMBER: LSSQ2B20WFL559050D010 2LBDL*GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	156.7	11.2
10°-20°	370.0	26.5
20°-30°	416.4	29.8
30°-40°	287.2	20.6
40°-50°	124.0	8.9
50°-60°	38.5	2.8
60°-70°	2.6	0.2
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	943.1	67.6
0°-40°	1230.3	88.2
0°-60°	1392.8	99.8
0°-90°	1395.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1395.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1716	
5°	1691	157
15°	1327	370
25°	917	416
35°	453	287
45°	154	124
55°	41	38
65°	0	3
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P#

CATALOG NUMBER: LSSQ2B20WFL559050D010 2LBDL*GPH

CANDELA DISTRIBUTION (FULL):

0°	
0°	1716.5
2.5°	1712.6
5°	1691.2
7.5°	1634.7
10°	1545.2
12.5°	1440.1
15°	1327.2
17.5°	1214.4
20°	1113.2
22.5°	1015.9
25°	916.6
27.5°	811.5
30°	692.8
32.5°	568.3
35°	453.4
37.5°	356.1
40°	274.4
42.5°	206.3
45°	153.7
47.5°	112.9
50°	81.7
52.5°	58.4
55°	40.9
57.5°	27.2
60°	13.6
62.5°	3.9
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)