

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P224071

Luminaire Tested: **LSR2B05SP158035D010 2LBD*MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P224071
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (150)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR2B05SP158035D010 2LBD*MW
Description: 500 Lumen, 2inch Portfolio LED Cylinder
SPOT OPTIC
SPUN ROUND TRIM WITH MATTE WHITE FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 432.0 lumens
Efficiency: N/A
Efficacy: 59.2 lumens/watt
Spacing Criteria (0/90/45): 0.24 / 0.24 / 0.23
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 7.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P224071

CATALOG NUMBER: LSR2B05SP158035D010 2LBD*MW

Luminous Intensity Polar Plot





TEST NUMBER: P224071

CATALOG NUMBER: LSR2B05SP158035D010 2LBD*MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									20									
RC	80									70									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																			
RCR																																														
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																												
1	116	114	112	111	113	112	110	109	108	107	106	104	103	103	101	100	100	98																												
2	113	110	107	105	111	108	106	104	105	103	102	102	101	100	100	99	98	96																												
3	110	106	103	101	108	105	102	100	102	100	98	100	98	97	98	97	96	94																												
4	108	103	100	97	106	102	99	97	100	98	96	98	96	95	97	95	94	93																												
5	105	101	97	95	104	100	97	94	98	96	94	97	95	93	95	94	92	91																												
6	103	98	95	93	102	98	95	92	96	94	92	95	93	91	94	92	91	90																												
7	101	96	93	91	100	96	93	90	95	92	90	94	91	90	93	91	89	88																												
8	100	94	91	89	99	94	91	89	93	90	89	92	90	88	92	89	88	87																												
9	98	93	90	88	97	92	89	87	92	89	87	91	89	87	90	88	87	86																												
10	96	91	88	86	96	91	88	86	90	88	86	90	87	86	89	87	86	85																												

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2075865
5°	1500633
10°	436862
15°	153306
20°	65623
25°	29533
30°	11405
35°	5674
40°	3792
45°	2465
50°	1386
55°	1013
60°	620
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P224071

CATALOG NUMBER: LSR2B05SP158035D010 2LBD*MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	273.1	63.2
10°-20°	111.1	25.7
20°-30°	34.1	7.9
30°-40°	8.4	1.9
40°-50°	3.5	0.8
50°-60°	1.5	0.4
60°-70°	0.3	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	418.3	96.8
0°-40°	426.7	98.8
0°-60°	431.7	99.9
0°-90°	432.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	432.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5359	
5°	3859	273
15°	382	111
25°	69	34
35°	12	8
45°	4	4
55°	2	2
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P224071

CATALOG NUMBER: LSR2B05SP158035D010 2LBD**MW*

CANDELA DISTRIBUTION (FULL):

	0°
0°	5359.2
1°	5277.3
2°	5077.5
3°	4759.1
4°	4343.1
5°	3859.4
6°	3314.2
7°	2722.4
8°	2122.3
9°	1561.3
10°	1110.7
11°	796.1
12°	598.5
13°	487.4
14°	426.6
15°	382.3
17.5°	235.8
20°	159.2
22.5°	106.6
25°	69.1
27.5°	42.1
30°	25.5
32.5°	16.5
35°	12.0
37.5°	9.8
40°	7.5
42.5°	6.0
45°	4.5
47.5°	3.0
50°	2.3
52.5°	2.3
55°	1.5
57.5°	1.5
60°	0.8
62.5°	0.8
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P224071

CATALOG NUMBER: LSR2B05SP158035D010 2LBD*MW

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°		0.0
87.5°		0.0



(END OF REPORT)