

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P263991

Luminaire Tested: **LD2B15D010 EU2B1510SP158030 2LBD*H**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P263991
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1805-787-1)
Test Lab: INNOVATION CENTER(G2)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD2B15D010 EU2B1510SP158030 2LBD*H
Description: 1500 Lumen, 2inch Portfolio LED Downlight
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1237.0 lumens
Efficiency: N/A
Efficacy: 86.5 lumens/watt
Spacing Criteria (0/90/45): 0.28 / 0.28 / 0.28
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P263991

CATALOG NUMBER: LD2B15D010 EU2B1510SP158030 2LBD*H

Luminous Intensity Polar Plot





TEST NUMBER: P263991

CATALOG NUMBER: LD2B15D010 EU2B1510SP158030 2LBD*H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	116	114	112	111	113	112	110	109	108	107	106	104	103	102	101	100	100	98				98
2	113	109	107	105	111	108	106	104	105	103	101	102	101	99	99	98	97	96				96
3	110	106	103	100	108	105	102	100	102	100	98	100	98	97	98	96	95	94				94
4	107	103	99	97	106	102	99	96	100	97	95	98	96	94	96	95	93	92				92
5	105	100	97	94	104	99	96	94	98	95	93	96	94	92	95	93	91	90				90
6	103	98	94	92	102	97	94	91	96	93	91	95	92	90	93	91	90	89				89
7	101	95	92	90	100	95	92	89	94	91	89	93	90	89	92	90	88	87				87
8	99	93	90	88	98	93	90	88	92	89	87	91	89	87	91	88	87	86				86
9	97	92	88	86	96	91	88	86	91	88	86	90	87	86	89	87	85	85				85
10	95	90	87	85	95	90	87	85	89	86	85	89	86	84	88	86	84	83				83

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	5836914
5°	4678592
10°	2042015
15°	632788
20°	220615
25°	97441
30°	44094
35°	22947
40°	13074
45°	6210
50°	3914
55°	2150
60°	1283
65°	1518
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P263991

CATALOG NUMBER: LD2B15D010 EU2B1510SP158030 2LBD*H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	717.4	58.0
10°-20°	392.9	31.8
20°-30°	89.6	7.2
30°-40°	25.7	2.1
40°-50°	8.0	0.6
50°-60°	2.4	0.2
60°-70°	1.1	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1199.8	97.0
0°-40°	1225.6	99.1
0°-60°	1235.9	99.9
0°-90°	1237.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1237.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	11831	
5°	9447	717
15°	1239	393
25°	179	90
35°	38	26
45°	9	8
55°	2	2
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P263991

CATALOG NUMBER: LD2B15D010 EU2B1510SP158030 2LBD*H

CANDELA DISTRIBUTION (FULL):

	0°
0°	11830.9
1°	11683.7
2°	11377.7
3°	10903.0
4°	10250.5
5°	9447.0
6°	8461.9
7°	7361.3
8°	6212.5
9°	5100.5
10°	4076.1
11°	3209.1
12°	2526.1
13°	1987.9
14°	1570.3
15°	1238.9
16°	977.4
17°	778.1
18°	625.8
19°	509.0
20°	420.2
22.5°	271.7
25°	179.0
26°	151.1
27°	128.2
28°	107.9
29°	90.1
30°	77.4
32.5°	53.3
35°	38.1
37.5°	27.9
40°	20.3
42.5°	14.0
45°	8.9
47.5°	6.3
50°	5.1
52.5°	3.8
55°	2.5
57.5°	1.3
60°	1.3
62.5°	1.3
65°	1.3
67.5°	1.3



TEST NUMBER: P263991

CATALOG NUMBER: LD2B15D010 EU2B1510SP158030 2LBD*H

CANDELA DISTRIBUTION (continued):

	0°
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







70°		0.0
72.5°		0.0



(END OF REPORT)