

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P222758

Luminaire Tested: **LD2B15D010 EU2B15NFL259030D2W 2LBDSQLC*MB**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P222758
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (155)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD2B15D010 EU2B15NFL259030D2W 2LBDSQLC*MB
Description: 1500 Lumen, 2inch Portfolio LED Downlight
NARROW FLOOD OPTIC
LENSED SQUARE CAST TRIM WITH MATTE BLACK FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 714.9 lumens
Efficiency: N/A
Efficacy: 50.0 lumens/watt
Spacing Criteria (0/90/45): 0.39 / 0.39 / 0.35
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P222758

CATALOG NUMBER: LD2B15D010 EU2B15NFL259030D2W 2LBDSQLC*MB

Luminous Intensity Polar Plot





TEST NUMBER: P222758

CATALOG NUMBER: LD2B15D010 EU2B15NFL259030D2W 2LBDSQLC*MB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									20								
RC	80									50									30									10									0								
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0															
RCR																																													
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																											
1	115	113	112	110	113	111	110	108	107	106	105	104	103	102	100	100	99	97																											
2	112	109	106	104	110	107	104	102	104	102	100	101	99	98	98	97	96	95																											
3	109	105	101	99	107	103	100	98	101	98	96	99	97	95	96	95	93	92																											
4	106	101	97	95	104	100	97	94	98	95	93	96	94	92	95	93	91	90																											
5	103	98	94	91	102	97	94	91	95	92	90	94	91	89	93	90	89	88																											
6	101	95	91	89	99	94	91	88	93	90	88	92	89	87	91	88	87	86																											
7	98	92	89	86	97	92	88	86	91	88	85	90	87	85	89	86	85	84																											
8	96	90	86	84	95	90	86	84	89	86	83	88	85	83	87	85	83	82																											
9	94	88	84	82	93	88	84	82	87	84	82	86	83	81	85	83	81	80																											
10	92	86	82	80	91	86	82	80	85	82	80	84	82	80	84	81	79	79																											

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1642851
5°	1516886
10°	1026766
15°	349320
20°	128319
25°	68040
30°	34932
35°	16314
40°	5360
45°	2739
50°	1265
55°	473
60°	542
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P222758

CATALOG NUMBER: LD2B15D010 EU2B15NFL259030D2W 2LBDSQLC*MB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	331.9	46.4
10°-20°	279.0	39.0
20°-30°	76.6	10.7
30°-40°	22.3	3.1
40°-50°	4.2	0.6
50°-60°	0.9	0.1
60°-70°	0.1	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	687.5	96.2
0°-40°	709.8	99.3
0°-60°	714.9	100.0
0°-90°	714.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	714.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4241	
5°	3901	332
15°	871	279
25°	159	77
35°	34	22
45°	5	4
55°	1	1
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P222758

CATALOG NUMBER: LD2B15D010 EU2B15NFL259030D2W 2LBDSQLC*MB

CANDELA DISTRIBUTION (FULL):

	0°
0°	4241.3
1°	4216.7
2°	4173.0
3°	4110.4
4°	4024.5
5°	3901.2
6°	3732.9
7°	3522.4
8°	3265.3
9°	2961.9
10°	2610.5
11°	2225.3
12°	1824.6
13°	1442.2
14°	1116.1
15°	871.1
17.5°	491.5
20°	311.3
22.5°	221.8
25°	159.2
27.5°	112.7
30°	78.1
32.5°	54.9
35°	34.5
37.5°	14.1
40°	10.6
42.5°	7.8
45°	5.0
47.5°	2.8
50°	2.1
52.5°	1.4
55°	0.7
57.5°	0.7
60°	0.7
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P222758

CATALOG NUMBER: LD2B15D010 EU2B15NFL259030D2W 2LBDSQLC*MB

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°		0.0
87.5°		0.0



(END OF REPORT)