

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P263956

Luminaire Tested: **LD2B20D010 EU2B2010SP158027 2LBD*WMH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P263956
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1805-787-1)
Test Lab: INNOVATION CENTER(G2)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD2B20D010 EU2B2010SP158027 2LBD*WMH
Description: 2000 Lumen, 2inch Portfolio LED Downlight
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1638.0 lumens
Efficiency: N/A
Efficacy: 78.4 lumens/watt
Spacing Criteria (0/90/45): 0.28 / 0.28 / 0.28
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P263956

CATALOG NUMBER: LD2B20D010 EU2B2010SP158027 2LBD*WMH

Luminous Intensity Polar Plot





TEST NUMBER: P263956

CATALOG NUMBER: LD2B20D010 EU2B2010SP158027 2LBD*WMH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	116	114	112	111	113	112	110	109	108	107	106	104	103	102	101	100	100	98			
2	113	109	107	105	111	108	106	104	105	103	101	102	101	99	99	98	97	96			
3	110	106	103	100	108	105	102	100	102	100	98	100	98	97	98	96	95	94			
4	107	103	99	97	106	102	99	96	100	97	95	98	96	94	96	95	93	92			
5	105	100	97	94	104	99	96	94	98	95	93	96	94	92	95	93	91	90			
6	103	98	94	92	102	97	94	91	96	93	91	95	92	90	93	91	90	89			
7	101	95	92	90	100	95	92	89	94	91	89	93	90	89	92	90	88	87			
8	99	93	90	88	98	93	90	88	92	89	87	91	89	87	91	88	87	86			
9	97	92	88	86	96	91	88	86	91	88	86	90	87	86	89	87	85	85			
10	95	90	87	85	95	90	87	85	89	86	85	89	86	84	88	86	84	83			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	7729104
5°	6195235
10°	2703950
15°	837962
20°	292124
25°	129014
30°	58393
35°	30355
40°	17325
45°	8233
50°	5142
55°	2925
60°	1677
65°	1985
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P263956

CATALOG NUMBER: LD2B20D010 EU2B2010SP158027 2LBD*WMH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	949.9	58.0
10°-20°	520.2	31.8
20°-30°	118.6	7.2
30°-40°	34.1	2.1
40°-50°	10.5	0.6
50°-60°	3.2	0.2
60°-70°	1.5	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1588.8	97.0
0°-40°	1622.9	99.1
0°-60°	1636.5	99.9
0°-90°	1638.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1638.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	15666	
5°	12509	950
15°	1641	520
25°	237	119
35°	50	34
45°	12	11
55°	3	3
65°	2	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P263956

CATALOG NUMBER: LD2B20D010 EU2B2010SP158027 2LBD*WMH

CANDELA DISTRIBUTION (FULL):

	0°
0°	15666.2
1°	15471.2
2°	15066.1
3°	14437.4
4°	13573.4
5°	12509.4
6°	11205.0
7°	9747.6
8°	8226.4
9°	6753.9
10°	5397.4
11°	4249.4
12°	3345.0
13°	2632.3
14°	2079.3
15°	1640.6
16°	1294.3
17°	1030.4
18°	828.7
19°	674.0
20°	556.4
22.5°	359.7
25°	237.0
26°	200.0
27°	169.8
28°	142.9
29°	119.3
30°	102.5
32.5°	70.6
35°	50.4
37.5°	37.0
40°	26.9
42.5°	18.5
45°	11.8
47.5°	8.4
50°	6.7
52.5°	5.0
55°	3.4
57.5°	1.7
60°	1.7
62.5°	1.7
65°	1.7
67.5°	1.7



TEST NUMBER: P263956

CATALOG NUMBER: LD2B20D010 EU2B2010SP158027 2LBD*WMH

CANDELA DISTRIBUTION (continued):

	0°
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







70°		0.0
72.5°		0.0



(END OF REPORT)