

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P264303

Luminaire Tested: **LD2B15D010 EU2B1510SP159030 2LBD\*H**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P264303  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1805-787-1)  
Test Lab: INNOVATION CENTER(G2)  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LD2B15D010 EU2B1510SP159030 2LBD\*H  
Description: 1500 Lumen, 2inch Portfolio LED Downlight  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 998.0 lumens  
Efficiency: N/A  
Efficacy: 69.8 lumens/watt  
Spacing Criteria (0/90/45): 0.28 / 0.28 / 0.28  
Luminous Opening: Circular (Dia: 0.17' x H: 0')  
CIE Type: Direct


Input Watts (W): 14.3  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P264303

CATALOG NUMBER: LD2B15D010 EU2B1510SP159030 2LBD\*H

### Luminous Intensity Polar Plot





TEST NUMBER: P264303

CATALOG NUMBER: LD2B15D010 EU2B1510SP159030 2LBD\*H

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									20									
RC	80									70									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																			
RCR																																														
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																												
1	116	114	112	111	113	112	110	109	108	107	106	104	103	102	101	100	100	98	96	94	92	90	88	86	84	82	80																			
2	113	109	107	105	111	108	106	104	105	103	101	102	101	99	99	98	97	96	95	94	93	92	91	90	89	88	87																			
3	110	106	103	100	108	105	102	100	102	100	98	100	98	97	98	96	95	94	93	92	91	90	89	88	87	86	85																			
4	107	103	99	97	106	102	99	96	100	97	95	98	96	94	96	95	93	92	91	90	89	88	87	86	85	84	83																			
5	105	100	97	94	104	99	96	94	98	95	93	96	94	92	95	93	91	90	89	88	87	86	85	84	83	82	81																			
6	103	98	94	92	102	97	94	91	96	93	91	95	92	90	93	91	90	89	88	87	86	85	84	83	82	81	80																			
7	101	95	92	90	100	95	92	89	94	91	89	93	90	89	92	90	88	87	86	85	84	83	82	81	80	79	78																			
8	99	93	90	88	98	93	90	88	92	89	87	91	89	87	91	88	87	86	85	84	83	82	81	80	79	78	77																			
9	97	92	88	86	96	91	88	86	91	88	86	90	87	86	89	87	85	84	83	82	81	80	79	78	77	76	75																			
10	95	90	87	85	95	90	87	85	89	86	85	89	86	84	88	86	84	83	82	81	80	79	78	77	76	75	74																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	4709188
5°	3774619
10°	1647449
15°	510561
20°	177983
25°	78606
30°	35605
35°	18490
40°	10562
45°	5024
50°	3147
55°	1720
60°	987
65°	1167
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P264303

CATALOG NUMBER: LD2B15D010 EU2B1510SP159030 2LBD\*H

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	578.8	58.0
10°-20°	317.0	31.8
20°-30°	72.3	7.2
30°-40°	20.8	2.1
40°-50°	6.4	0.6
50°-60°	1.9	0.2
60°-70°	0.9	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	968.0	97.0
0°-40°	988.8	99.1
0°-60°	997.1	99.9
0°-90°	998.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	998.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	9545	
5°	7622	579
15°	1000	317
25°	144	72
35°	31	21
45°	7	6
55°	2	2
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P264303

CATALOG NUMBER: LD2B15D010 EU2B1510SP159030 2LBD\*H

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	9545.1
1°	9426.3
2°	9179.4
3°	8796.4
4°	8270.0
5°	7621.7
6°	6827.0
7°	5939.0
8°	5012.2
9°	4115.0
10°	3288.5
11°	2589.0
12°	2038.1
13°	1603.8
14°	1266.9
15°	999.6
16°	788.6
17°	627.8
18°	504.9
19°	410.7
20°	339.0
22.5°	219.2
25°	144.4
26°	121.9
27°	103.4
28°	87.1
29°	72.7
30°	62.5
32.5°	43.0
35°	30.7
37.5°	22.5
40°	16.4
42.5°	11.3
45°	7.2
47.5°	5.1
50°	4.1
52.5°	3.1
55°	2.0
57.5°	1.0
60°	1.0
62.5°	1.0
65°	1.0
67.5°	1.0



TEST NUMBER: P264303

CATALOG NUMBER: LD2B15D010 EU2B1510SP159030 2LBD\*H

**CANDELA DISTRIBUTION (continued):**

	0°
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







70°		0.0
72.5°		0.0



(END OF REPORT)