

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P264427

Luminaire Tested: **LD2B20D010 EU2B2010SP159040 2LBDC*MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P264427
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1805-787-1)
Test Lab: INNOVATION CENTER(G2)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD2B20D010 EU2B2010SP159040 2LBDC*MW
Description: 2000 Lumen, 2inch Portfolio LED Downlight
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1497.0 lumens
Efficiency: N/A
Efficacy: 71.6 lumens/watt
Spacing Criteria (0/90/45): 0.28 / 0.28 / 0.28
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P264427

CATALOG NUMBER: LD2B20D010 EU2B2010SP159040 2LBDC*MW

Luminous Intensity Polar Plot





TEST NUMBER: P264427

CATALOG NUMBER: LD2B20D010 EU2B2010SP159040 2LBDC*MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	116	114	112	111	113	112	110	109	108	107	106	104	103	102	101	100	100	98			98
2	113	109	107	105	111	108	106	104	105	103	101	102	101	99	99	98	97	96			96
3	110	106	103	100	108	105	102	100	102	100	98	100	98	97	98	96	95	94			94
4	107	103	99	97	106	102	99	96	100	97	95	98	96	94	96	95	93	92			92
5	105	100	97	94	104	99	96	94	98	95	93	96	94	92	95	93	91	90			90
6	103	98	94	92	102	97	94	91	96	93	91	95	92	90	93	91	90	89			89
7	101	95	92	90	100	95	92	89	94	91	89	93	90	89	92	90	88	87			87
8	99	93	90	88	98	93	90	88	92	89	87	91	89	87	91	88	87	86			86
9	97	92	88	86	96	91	88	86	91	88	86	90	87	86	89	87	85	85			85
10	95	90	87	85	95	90	87	85	89	86	85	89	86	84	88	86	84	83			83

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	7063757
5°	5661953
10°	2471198
15°	765842
20°	266975
25°	117909
30°	53379
35°	27765
40°	15843
45°	7535
50°	4682
55°	2666
60°	1480
65°	1751
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P264427

CATALOG NUMBER: LD2B20D010 EU2B2010SP159040 2LBDC*MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	868.2	58.0
10°-20°	475.5	31.8
20°-30°	108.4	7.2
30°-40°	31.2	2.1
40°-50°	9.6	0.6
50°-60°	2.9	0.2
60°-70°	1.3	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1452.0	97.0
0°-40°	1483.2	99.1
0°-60°	1495.7	99.9
0°-90°	1497.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1497.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	14318	
5°	11433	868
15°	1499	475
25°	217	108
35°	46	31
45°	11	10
55°	3	3
65°	2	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P264427

CATALOG NUMBER: LD2B20D010 EU2B2010SP159040 2LBDC*MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	14317.6
1°	14139.4
2°	13769.2
3°	13194.6
4°	12405.0
5°	11432.6
6°	10240.5
7°	8908.6
8°	7518.3
9°	6172.5
10°	4932.8
11°	3883.6
12°	3057.1
13°	2405.7
14°	1900.3
15°	1499.4
16°	1182.9
17°	941.7
18°	757.4
19°	616.0
20°	508.5
22.5°	328.8
25°	216.6
26°	182.8
27°	155.2
28°	130.6
29°	109.1
30°	93.7
32.5°	64.5
35°	46.1
37.5°	33.8
40°	24.6
42.5°	16.9
45°	10.8
47.5°	7.7
50°	6.1
52.5°	4.6
55°	3.1
57.5°	1.5
60°	1.5
62.5°	1.5
65°	1.5
67.5°	1.5



TEST NUMBER: P264427

CATALOG NUMBER: LD2B20D010 EU2B2010SP159040 2LBDC*MW

CANDELA DISTRIBUTION (continued):

	0°
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







70°		0.0
72.5°		0.0



(END OF REPORT)