

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P264846

Luminaire Tested: **LD2B20D010 EU2B2010SP158050 2LBSQLC*MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P264846
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1711-432-2)
Test Lab: INNOVATION CENTER(G3)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD2B20D010 EU2B2010SP158050 2LBSQLC*MW
Description: 2000 Lumen, 2inch Portfolio LED Downlight
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1795.0 lumens
Efficiency: N/A
Efficacy: 85.9 lumens/watt
Spacing Criteria (0/90/45): 0.31 / 0.31 / 0.32
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P264846

CATALOG NUMBER: LD2B20D010 EU2B2010SP158050 2LBSQLC*MW

Luminous Intensity Polar Plot





TEST NUMBER: P264846

CATALOG NUMBER: LD2B20D010 EU2B2010SP158050 2LBSQLC*MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	115	113	111	110	113	111	110	108	107	106	105	104	103	102	100	99	99	97	97	97	97
2	112	108	106	103	110	107	104	102	104	102	100	101	99	98	98	97	96	94	94	94	94
3	109	104	101	98	107	103	100	97	100	98	96	98	96	94	96	94	93	92	92	92	92
4	105	100	97	94	104	99	96	93	97	95	92	96	93	91	94	92	90	89	89	89	89
5	103	97	93	91	101	96	93	90	95	92	89	93	91	89	92	90	88	87	87	87	87
6	100	94	90	88	99	94	90	87	92	89	87	91	88	86	90	88	86	85	85	85	85
7	98	92	88	85	97	91	88	85	90	87	85	89	86	84	88	86	84	83	83	83	83
8	95	89	86	83	94	89	85	83	88	85	82	87	84	82	86	84	82	81	81	81	81
9	93	87	83	81	92	87	83	81	86	83	81	85	82	80	85	82	80	79	79	79	79
10	91	85	82	79	91	85	81	79	84	81	79	84	81	79	83	80	78	78	78	78	78

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	6336739
5°	5157446
10°	2785909
15°	1110813
20°	445431
25°	213282
30°	110576
35°	58482
40°	32395
45°	20094
50°	13816
55°	9290
60°	7104
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P264846

CATALOG NUMBER: LD2B20D010 EU2B2010SP158050 2LBSQLC*MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	837.5	46.7
10°-20°	660.8	36.8
20°-30°	194.9	10.9
30°-40°	64.9	3.6
40°-50°	24.4	1.4
50°-60°	10.8	0.6
60°-70°	1.7	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1693.2	94.3
0°-40°	1758.1	97.9
0°-60°	1793.3	99.9
0°-90°	1795.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1795.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	12844	
5°	10414	837
15°	2175	661
25°	392	195
35°	97	65
45°	29	24
55°	11	11
65°	0	2
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P264846

CATALOG NUMBER: LD2B20D010 EU2B2010SP158050 2LBSQLC*MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	12844.0
2.5°	12326.3
5°	10413.9
7.5°	8023.4
10°	5561.0
12.5°	3558.8
15°	2174.8
17.5°	1326.5
20°	848.4
22.5°	568.0
25°	391.8
27.5°	276.8
30°	194.1
32.5°	136.6
35°	97.1
37.5°	68.3
40°	50.3
42.5°	39.5
45°	28.8
47.5°	25.2
50°	18.0
52.5°	14.4
55°	10.8
57.5°	10.8
60°	7.2
62.5°	3.6
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)