

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P496211

Luminaire Tested: **LDA2B109035R35D010 2LBDL1WH**

Issue Date: 3/9/2021

This test was performed under the Supervised Manufacturer's Testing Program. The results of this test have not been influenced by sources from within Cooper Lighting Solutions or from external interests.



Test Information

Test Method: LM-79-08
Report Number: P496211
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2011-037-29)
Test Lab: INNOVATION CENTER
Issue Date: 3/9/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LDA2B109035R35D010 2LBDL1WH
Description: 1000 LUMEN 2IN ADJUSTABLE LED LUMINAIRE WITH 90 CRI LEDS AND 3500K CCT LEDS
Light Source: -
Ballast/Driver: -

Luminaire Equipment: Sample No. Condition Description

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 845.4 lumens
Efficiency: N/A
Efficacy: 84.5 lumens/watt
Spacing Criteria (0/90/45): 0.54 / 0.54 / 0.51
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct

Input Watts (W): 10
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P496211

CATALOG NUMBER: LDA2B109035R35D010 2LBDL1WH

Luminous Intensity Polar Plot





TEST NUMBER: P496211

CATALOG NUMBER: LDA2B109035R35D010 2LBDL1WH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	115	113	111	109	112	110	109	107	106	105	104		103	102	101		99	99	98	96
2	111	107	104	101	109	105	102	100	102	100	98		99	97	96		97	95	94	92
3	107	102	98	95	105	101	97	94	98	95	93		96	93	91		94	92	90	89
4	103	97	93	90	102	96	92	89	94	91	88		92	90	87		91	88	87	85
5	100	93	89	86	98	93	88	85	91	87	85		89	86	84		88	85	83	82
6	96	90	85	82	95	89	85	82	88	84	81		86	83	81		85	82	80	79
7	93	86	82	79	92	86	82	79	85	81	78		84	80	78		83	80	77	76
8	90	83	79	76	89	83	79	76	82	78	75		81	78	75		80	77	75	74
9	88	81	76	73	87	80	76	73	79	76	73		79	75	73		78	75	72	71
10	85	78	74	71	84	78	73	71	77	73	70		76	73	70		76	72	70	69

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1290338
5°	1247476
10°	1090167
15°	762165
20°	400174
25°	171965
30°	78617
35°	38125
40°	19386
45°	9908
50°	5449
55°	2322
60°	888
65°	467
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P496211

CATALOG NUMBER: LDA2B109035R35D010 2LBDL1WH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	229.6	27.2
10°-20°	398.2	47.1
20°-30°	158.9	18.8
30°-40°	43.3	5.1
40°-50°	12.0	1.4
50°-60°	2.8	0.3
60°-70°	0.5	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	786.7	93.1
0°-40°	830.0	98.2
0°-60°	844.9	99.9
0°-90°	845.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	845.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2615	
5°	2519	230
15°	1492	398
25°	316	159
35°	63	43
45°	14	12
55°	3	3
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P496211

CATALOG NUMBER: LDA2B109035R35D010 2LBDL1WH

CANDELA DISTRIBUTION (FULL):

0°	
0°	2615.4
1°	2604.3
2°	2593.7
3°	2577.8
4°	2553.9
5°	2518.9
6°	2473.4
7°	2416.7
8°	2352.1
9°	2262.8
10°	2176.1
11°	2068.6
12°	1931.0
13°	1792.5
14°	1651.4
15°	1492.2
16°	1335.6
17°	1174.5
18°	1029.9
19°	893.2
20°	762.2
21°	641.9
22.5°	497.7
23°	451.2
24°	378.7
25°	315.9
26°	265.9
27°	222.1
28°	188.0
29°	160.1
30°	138.0
32.5°	92.5
35°	63.3
37.5°	44.2
40°	30.1
42.5°	20.3
45°	14.2
47.5°	10.2
50°	7.1
52.5°	4.9
55°	2.7
57.5°	1.3
60°	0.9
62.5°	0.9
65°	0.4



TEST NUMBER: P496211

CATALOG NUMBER: LDA2B109035R35D010 2LBDL1WH

CANDELA DISTRIBUTION (continued):

	0°
67.5°	0.4
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)