

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P498694

Luminaire Tested: **LDA2B159030R20D010 2LBD1H**

Issue Date: 3/8/2021

This test was performed under the Supervised Manufacturer's Testing Program. The results of this test have not been influenced by sources from within Cooper Lighting Solutions or from external interests.



Test Information

Test Method: LM-79-08
Report Number: P498694
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2011-037-1)
Test Lab: INNOVATION CENTER
Issue Date: 3/8/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LDA2B159030R20D010 2LBD1H
Description: 1500 LUMEN 2IN ADJUSTABLE LED LUMINAIRE WITH 90 CRI LEDS AND 3000K CCT LEDS
Light Source: -
Ballast/Driver: -

Luminaire Equipment: Sample No. Condition Description


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1162.9 lumens
Efficiency: N/A
Efficacy: 82.5 lumens/watt
Spacing Criteria (0/90/45): 0.33 / 0.33 / 0.32
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct

Input Watts (W): 14.1
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P498694
CATALOG NUMBER: LDA2B159030R20D010 2LBD1H

Luminous Intensity Polar Plot





TEST NUMBER: P498694

CATALOG NUMBER: LDA2B159030R20D010 2LBD1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	116	114	112	110	113	111	110	109	108	106	105	104	103	102	101	100	99	98
2	112	109	106	104	110	107	105	103	104	102	101	102	100	99	99	98	97	95
3	109	105	102	100	108	104	101	99	102	99	97	99	97	96	97	96	94	93
4	107	102	99	96	105	101	98	95	99	96	94	97	95	93	96	94	92	91
5	104	99	95	93	103	98	95	92	97	94	92	95	93	91	94	92	90	89
6	102	96	93	90	101	96	92	90	94	92	89	93	91	89	92	90	88	87
7	100	94	91	88	99	94	90	88	92	90	87	92	89	87	91	88	87	86
8	98	92	88	86	97	91	88	86	91	88	86	90	87	85	89	87	85	84
9	96	90	87	84	95	90	86	84	89	86	84	88	86	84	88	85	83	83
10	94	88	85	83	93	88	85	82	87	84	82	87	84	82	86	84	82	81

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	4309811
5°	3590883
10°	2105939
15°	737597
20°	248284
25°	95699
30°	43923
35°	19454
40°	9467
45°	5512
50°	3070
55°	946
60°	592
65°	700
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P498694

CATALOG NUMBER: LDA2B159030R20D010 2LBD1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	593.2	51.0
10°-20°	445.4	38.3
20°-30°	93.6	8.0
30°-40°	22.4	1.9
40°-50°	6.4	0.6
50°-60°	1.4	0.1
60°-70°	0.4	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1132.2	97.4
0°-40°	1154.7	99.3
0°-60°	1162.5	100.0
0°-90°	1162.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1162.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	8736	
5°	7251	593
15°	1444	445
25°	176	94
35°	32	22
45°	8	6
55°	1	1
65°	1	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P498694

CATALOG NUMBER: LDA2B159030R20D010 2LBD1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	8735.6
1°	8629.0
2°	8368.2
3°	8067.7
4°	7731.5
5°	7250.7
6°	6740.4
7°	6174.0
8°	5527.0
9°	4873.8
10°	4203.7
11°	3514.2
12°	2907.0
13°	2314.5
14°	1842.2
15°	1444.1
16°	1132.8
17°	893.6
18°	718.4
19°	582.3
20°	472.9
22.5°	286.9
25°	175.8
27.5°	115.1
30°	77.1
32.5°	47.1
35°	32.3
37.5°	22.1
40°	14.7
42.5°	10.8
45°	7.9
47.5°	5.7
50°	4.0
52.5°	2.3
55°	1.1
57.5°	0.6
60°	0.6
62.5°	0.6
65°	0.6
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0



TEST NUMBER: P498694

CATALOG NUMBER: LDA2B159030R20D010 2LBD1H

CANDELA DISTRIBUTION (continued):

	0°
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)