

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P499364

Luminaire Tested: **LDA2B159050R20D010 2LBDL1GPH**

Issue Date: 3/9/2021

This test was performed under the Supervised Manufacturer's Testing Program. The results of this test have not been influenced by sources from within Cooper Lighting Solutions or from external interests.



**Test Information**

Test Method: LM-79-08  
Report Number: P499364  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2011-037-3)  
Test Lab: INNOVATION CENTER  
Issue Date: 3/9/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LDA2B159050R20D010 2LBDL1GPH  
Description: 1500 LUMEN 2IN ADJUSTABLE LED LUMINAIRE WITH 90 CRI LEDS AND 5000K CCT LEDS  
Light Source: -  
Ballast/Driver: -

Luminaire Equipment: Sample No.    Condition    Description

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 1186.6 lumens  
Efficiency: N/A  
Efficacy: 84.2 lumens/watt  
Spacing Criteria (0/90/45): 0.34 / 0.34 / 0.34  
Luminous Opening: Circular (Dia: 0.17' x H: 0')  
CIE Type: Direct

Input Watts (W): 14.1  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT

TEST NUMBER: P499364

CATALOG NUMBER: LDA2B159050R20D010 2LBDL1GPH

### Luminous Intensity Polar Plot





TEST NUMBER: P499364

CATALOG NUMBER: LDA2B159050R20D010 2LBDL1GPH

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100
1	115	113	112	110	113	111	110	108	107	106	105	104	103	102	100	100	99	97	97	97
2	112	109	106	104	110	107	105	102	104	102	100	101	100	98	98	97	96	95	95	95
3	109	105	101	99	107	103	100	98	101	98	96	99	97	95	97	95	94	92	92	92
4	106	101	98	95	104	100	97	94	98	95	93	96	94	92	95	93	91	90	90	90
5	103	98	94	92	102	97	94	91	96	93	90	94	92	90	93	91	89	88	88	88
6	101	95	91	89	100	95	91	88	93	90	88	92	89	87	91	89	87	86	86	86
7	98	93	89	86	97	92	89	86	91	88	86	90	87	85	89	87	85	84	84	84
8	96	90	87	84	95	90	86	84	89	86	84	88	85	83	87	85	83	82	82	82
9	94	88	85	82	93	88	84	82	87	84	82	86	84	82	86	83	81	81	81	81
10	92	86	83	80	91	86	83	80	85	82	80	85	82	80	84	82	80	79	79	79

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	3922966
5°	3315823
10°	2020373
15°	831169
20°	299264
25°	120032
30°	54519
35°	25657
40°	13525
45°	7326
50°	4298
55°	2150
60°	1184
65°	700
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P499364

CATALOG NUMBER: LDA2B159050R20D010 2LBDL1GPH

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	552.3	46.5
10°-20°	477.7	40.3
20°-30°	115.2	9.7
30°-40°	29.5	2.5
40°-50°	8.9	0.7
50°-60°	2.5	0.2
60°-70°	0.6	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1145.1	96.5
0°-40°	1174.6	99.0
0°-60°	1186.0	100.0
0°-90°	1186.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1186.6	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	7952	
5°	6695	552
15°	1627	478
25°	220	115
35°	43	30
45°	10	9
55°	2	3
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P499364

CATALOG NUMBER: LDA2B159050R20D010 2LBDL1GPH

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	7951.5
1°	7882.3
2°	7717.4
3°	7466.7
4°	7143.7
5°	6695.3
6°	6232.1
7°	5720.7
8°	5189.6
9°	4593.6
10°	4032.9
11°	3446.8
12°	2932.9
13°	2446.9
14°	2001.0
15°	1627.3
16°	1318.6
17°	1064.7
18°	859.1
19°	706.5
20°	570.0
22.5°	351.4
25°	220.5
27.5°	143.3
30°	95.7
32.5°	63.0
35°	42.6
37.5°	29.6
40°	21.0
42.5°	14.8
45°	10.5
47.5°	8.0
50°	5.6
52.5°	3.7
55°	2.5
57.5°	1.9
60°	1.2
62.5°	0.6
65°	0.6
67.5°	0.6
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0



TEST NUMBER: P499364

CATALOG NUMBER: LDA2B159050R20D010 2LBDL1GPH

**CANDELA DISTRIBUTION (continued):**

	0°
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)