

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P279837

Luminaire Tested: **LDA2B159727D010 EU2B15FL409727 2LBALD1B**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P279837  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1811-033-3)  
Test Lab: INNOVATION CENTER(G2)  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LDA2B159727D010 EU2B15FL409727 2LBALD1B  
Description: PORTFOLIO 2IN ADJ 1500 LUMEN LED LUMINAIRE WITH FLOOD OPTIC AND 2in  
ADJ spun Refl w/lens Self-Flanged, B  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1070.4 lumens  
Efficiency: N/A  
Efficacy: 75.9 lumens/watt  
Spacing Criteria (0/90/45): 0.61 / 0.61 / 0.55  
Luminous Opening: Circular (Dia: 0.17' x H: 0')  
CIE Type: Direct


Input Watts (W): 14.1  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P279837

CATALOG NUMBER: LDA2B159727D010 EU2B15FL409727 2LBALD1B

### Luminous Intensity Polar Plot





TEST NUMBER: P279837

CATALOG NUMBER: LDA2B159727D010 EU2B15FL409727 2LBALD1B

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92
3	107	102	98	95	105	101	97	94	98	95	93	96	94	92	94	92	90	89
4	103	98	93	90	102	97	93	90	95	91	89	93	90	88	91	89	87	85
5	100	94	89	86	98	93	89	86	91	88	85	90	87	84	88	86	83	82
6	97	90	85	82	95	89	85	82	88	84	82	87	83	81	85	83	80	79
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74
9	88	81	76	73	87	80	76	73	79	76	73	79	75	73	78	75	73	72
10	85	78	74	71	84	78	74	71	77	73	71	76	73	70	76	72	70	69

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	1471797
5°	1440672
10°	1313049
15°	1025771
20°	607296
25°	225748
30°	70527
35°	31379
40°	14555
45°	6838
50°	3761
55°	2150
60°	987
65°	584
70°	721
75°	0
80°	0
85°	0



TEST NUMBER: P279837

CATALOG NUMBER: LDA2B159727D010 EU2B15FL409727 2LBALD1B

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	268.9	25.1
10°-20°	534.7	50.0
20°-30°	219.0	20.5
30°-40°	36.2	3.4
40°-50°	8.6	0.8
50°-60°	2.3	0.2
60°-70°	0.6	0.1
70°-80°	0.1	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1022.6	95.5
0°-40°	1058.9	98.9
0°-60°	1069.7	99.9
0°-90°	1070.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1070.4	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2983	
5°	2909	269
15°	2008	535
25°	415	219
35°	52	36
45°	10	9
55°	2	2
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P279837

CATALOG NUMBER: LDA2B159727D010 EU2B15FL409727 2LBALD1B

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	2983.2
1°	2972.8
2°	2959.1
3°	2946.8
4°	2930.6
5°	2909.0
6°	2877.0
7°	2835.3
8°	2775.8
9°	2703.6
10°	2621.0
11°	2525.2
12°	2417.1
13°	2293.8
14°	2156.7
15°	2008.3
17.5°	1592.6
20°	1156.7
22.5°	740.5
25°	414.7
27.5°	218.7
30°	123.8
32.5°	78.6
35°	52.1
37.5°	34.4
40°	22.6
42.5°	14.7
45°	9.8
47.5°	6.9
50°	4.9
52.5°	3.4
55°	2.5
57.5°	1.5
60°	1.0
62.5°	0.5
65°	0.5
67.5°	0.5
70°	0.5
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P279837

CATALOG NUMBER: LDA2B159727D010 EU2B15FL409727 2LBALD1B

CANDELA DISTRIBUTION (continued):

0°  
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







85°		0.0
87.5°		0.0



(END OF REPORT)