

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P315120

Luminaire Tested: **LDA2B15NFLD2WD010 PINW1MMS**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P315120
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1811-033-2)
Test Lab: INNOVATION CENTER(G2)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LDA2B15NFLD2WD010 PINW1MMS
Description: PORTFOLIO 2IN ADJ 1500 LUMEN LED LUMINAIRE WITH NARROW FLOOD OPTIC AND 2in Adj PinHole, White oculus, matte metallic silver finish
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 987.7 lumens
Efficiency: N/A
Efficacy: 70.1 lumens/watt
Spacing Criteria (0/90/45): 0.39 / 0.39 / 0.39
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 14.1
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P315120

CATALOG NUMBER: LDA2B15NFLD2WD010 PINW1MMS

Luminous Intensity Polar Plot





TEST NUMBER: P315120

CATALOG NUMBER: LDA2B15NFLD2WD010 PINW1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	115	113	111	110	113	111	109	108	107	106	105	103	102	102	100	99	99	97
2	112	108	105	103	110	107	104	102	103	101	100	101	99	98	98	97	96	94
3	108	104	100	98	107	103	99	97	100	98	95	98	96	94	96	94	93	91
4	105	100	96	94	104	99	96	93	97	94	92	95	93	91	94	92	90	89
5	102	97	93	90	101	96	92	90	94	91	89	93	90	88	92	89	87	86
6	100	94	90	87	98	93	89	87	92	89	86	91	88	86	89	87	85	84
7	97	91	87	84	96	90	87	84	89	86	84	88	85	83	87	85	83	82
8	95	88	85	82	94	88	84	82	87	84	81	86	83	81	85	83	81	80
9	92	86	82	80	92	86	82	80	85	82	79	84	81	79	84	81	79	78
10	90	84	80	78	90	84	80	78	83	80	77	82	79	77	82	79	77	76

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2528084
5°	2331521
10°	1571151
15°	774627
20°	330871
25°	130103
30°	51215
35°	22465
40°	10820
45°	5233
50°	2840
55°	1634
60°	888
65°	584
70°	721
75°	0
80°	0
85°	0



TEST NUMBER: P315120

CATALOG NUMBER: LDA2B15NFLD2WD010 PINW1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	398.8	40.4
10°-20°	429.5	43.5
20°-30°	124.0	12.6
30°-40°	26.2	2.7
40°-50°	6.5	0.7
50°-60°	1.9	0.2
60°-70°	0.6	0.1
70°-80°	0.3	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	952.3	96.4
0°-40°	978.5	99.1
0°-60°	986.8	99.9
0°-90°	987.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	987.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5124	
5°	4708	399
15°	1517	429
25°	239	124
35°	37	26
45°	8	6
55°	2	2
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P315120

CATALOG NUMBER: LDA2B15NFLD2WD010 PINW1MMS

CANDELA DISTRIBUTION (FULL):

	0°
0°	5124.2
1°	5092.1
2°	5037.6
3°	4964.0
4°	4859.6
5°	4707.8
6°	4502.8
7°	4235.5
8°	3906.6
9°	3523.3
10°	3136.2
11°	2744.9
12°	2375.6
13°	2047.6
14°	1759.3
15°	1516.6
17.5°	1002.4
20°	630.2
22.5°	387.5
25°	239.0
27.5°	145.8
30°	89.9
32.5°	56.8
35°	37.3
37.5°	24.7
40°	16.8
42.5°	11.6
45°	7.5
47.5°	4.7
50°	3.7
52.5°	2.8
55°	1.9
57.5°	1.4
60°	0.9
62.5°	0.9
65°	0.5
67.5°	0.5
70°	0.5
72.5°	0.5
75°	0.0
77.5°	0.5
80°	0.0
82.5°	0.0



TEST NUMBER: P315120

CATALOG NUMBER: LDA2B15NFLD2WD010 PINW1MMS

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°		0.0
87.5°		0.0



(END OF REPORT)