

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P279884

Luminaire Tested: **LDA2B208027D010 EU2B20FL408027 2LBALD1MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P279884
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1811-033-3)
Test Lab: INNOVATION CENTER(G2)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LDA2B208027D010 EU2B20FL408027 2LBALD1MW
Description: PORTFOLIO 2IN ADJ 2000 LUMEN LED LUMINAIRE WITH FLOOD OPTIC AND 2in
ADJ spun Refl w/lens Self-Flanged, MW
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2118.4 lumens
Efficiency: N/A
Efficacy: 102.8 lumens/watt
Spacing Criteria (0/90/45): 0.61 / 0.61 / 0.55
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 20.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P279884

CATALOG NUMBER: LDA2B208027D010 EU2B20FL408027 2LBALD1MW

Luminous Intensity Polar Plot





TEST NUMBER: P279884

CATALOG NUMBER: LDA2B208027D010 EU2B20FL408027 2LBALD1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96			
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92			
3	107	102	98	95	105	101	97	94	98	95	93	96	94	92	94	92	90	89			
4	103	98	93	90	102	97	93	90	95	91	89	93	90	88	91	89	87	85			
5	100	94	89	86	98	93	89	86	91	88	85	90	87	84	88	86	83	82			
6	97	90	85	82	95	89	85	82	88	84	82	87	83	81	85	83	80	79			
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77			
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74			
9	88	81	76	73	87	80	76	73	79	76	73	79	75	73	78	75	73	72			
10	85	78	74	71	84	78	74	71	77	73	71	76	73	70	76	72	70	69			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2912907
5°	2851282
10°	2598746
15°	2030140
20°	1201939
25°	446814
30°	139630
35°	62095
40°	28789
45°	13606
50°	7445
55°	4215
60°	1875
65°	1167
70°	1442
75°	0
80°	0
85°	0



TEST NUMBER: P279884

CATALOG NUMBER: LDA2B208027D010 EU2B20FL408027 2LBALD1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	532.2	25.1
10°-20°	1058.3	50.0
20°-30°	433.4	20.5
30°-40°	71.7	3.4
40°-50°	17.0	0.8
50°-60°	4.5	0.2
60°-70°	1.1	0.1
70°-80°	0.1	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2024.0	95.5
0°-40°	2095.7	98.9
0°-60°	2117.2	99.9
0°-90°	2118.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2118.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5904	
5°	5757	532
15°	3975	1058
25°	821	433
35°	103	72
45°	20	17
55°	5	5
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P279884

CATALOG NUMBER: LDA2B208027D010 EU2B20FL408027 2LBALD1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	5904.2
1°	5883.7
2°	5856.5
3°	5832.2
4°	5800.1
5°	5757.3
6°	5694.1
7°	5611.4
8°	5493.8
9°	5350.8
10°	5187.4
11°	4997.8
12°	4783.8
13°	4539.7
14°	4268.4
15°	3974.7
17.5°	3151.9
20°	2289.3
22.5°	1465.6
25°	820.8
27.5°	432.8
30°	245.1
32.5°	155.6
35°	103.1
37.5°	68.1
40°	44.7
42.5°	29.2
45°	19.5
47.5°	13.6
50°	9.7
52.5°	6.8
55°	4.9
57.5°	2.9
60°	1.9
62.5°	1.0
65°	1.0
67.5°	1.0
70°	1.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P279884

CATALOG NUMBER: LDA2B208027D010 EU2B20FL408027 2LBALD1MW

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°		0.0
87.5°		0.0



(END OF REPORT)