

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P315157

Luminaire Tested: **LDA2B20NFL9024D010 PIN1MB**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P315157
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1811-033-2)
Test Lab: INNOVATION CENTER(G2)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LDA2B20NFL9024D010 PIN1MB
Description: PORTFOLIO 2IN ADJ 2000 LUMEN LED LUMINAIRE WITH NARROW FLOOD OPTIC AND 2in Adj PinHole, Black oculus black finish
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1303.7 lumens
Efficiency: N/A
Efficacy: 63.3 lumens/watt
Spacing Criteria (0/90/45): 0.39 / 0.39 / 0.39
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct

Input Watts (W): 20.6
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P315157
CATALOG NUMBER: LDA2B20NFL9024D010 PIN1MB

Luminous Intensity Polar Plot





TEST NUMBER: P315157

CATALOG NUMBER: LDA2B20NFL9024D010 PIN1MB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20					
RC	80				70				50				30				10		0			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	99	99	97
1	115	113	111	110	113	111	109	108	107	106	105	103	102	102	100	99	99	97	97	97	97	97
2	112	108	105	103	110	107	104	102	103	101	100	101	99	98	98	97	96	96	96	96	96	94
3	108	104	100	98	107	103	99	97	100	98	95	98	96	94	96	94	93	91	91	91	91	91
4	105	100	96	94	104	99	96	93	97	94	92	95	93	91	94	92	90	89	89	89	89	89
5	102	97	93	90	101	96	92	90	94	91	89	93	90	88	92	89	87	86	86	86	86	86
6	100	94	90	87	98	93	89	87	92	89	86	91	88	86	89	87	85	84	84	84	84	84
7	97	91	87	84	96	90	87	84	89	86	84	88	85	83	87	85	83	82	82	82	82	82
8	95	88	85	82	94	88	84	82	87	84	81	86	83	81	85	83	81	80	80	80	80	80
9	92	86	82	80	92	86	82	80	85	82	79	84	81	79	84	81	79	78	78	78	78	78
10	90	84	80	78	90	84	80	78	83	80	78	82	79	77	82	79	77	76	76	76	76	76

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	3337099
5°	3077609
10°	2073927
15°	1022553
20°	436768
25°	171693
30°	67622
35°	29632
40°	14233
45°	6838
50°	3761
55°	2150
60°	1184
65°	700
70°	865
75°	0
80°	0
85°	0



TEST NUMBER: P315157

CATALOG NUMBER: LDA2B20NFL9024D010 PIN1MB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	526.4	40.4
10°-20°	566.9	43.5
20°-30°	163.7	12.6
30°-40°	34.6	2.7
40°-50°	8.5	0.7
50°-60°	2.4	0.2
60°-70°	0.8	0.1
70°-80°	0.4	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1257.0	96.4
0°-40°	1291.6	99.1
0°-60°	1302.5	99.9
0°-90°	1303.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1303.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6764	
5°	6214	526
15°	2002	567
25°	315	164
35°	49	35
45°	10	8
55°	2	2
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P315157

CATALOG NUMBER: LDA2B20NFL9024D010 PIN1MB

CANDELA DISTRIBUTION (FULL):

	0°
0°	6764.0
1°	6721.5
2°	6649.6
3°	6552.5
4°	6414.7
5°	6214.3
6°	5943.8
7°	5590.8
8°	5156.7
9°	4650.7
10°	4139.8
11°	3623.3
12°	3135.7
13°	2702.9
14°	2322.3
15°	2002.0
17.5°	1323.2
20°	831.9
22.5°	511.6
25°	315.4
27.5°	192.4
30°	118.7
32.5°	75.0
35°	49.2
37.5°	32.6
40°	22.1
42.5°	15.4
45°	9.8
47.5°	6.1
50°	4.9
52.5°	3.7
55°	2.5
57.5°	1.8
60°	1.2
62.5°	1.2
65°	0.6
67.5°	0.6
70°	0.6
72.5°	0.6
75°	0.0
77.5°	0.6
80°	0.0
82.5°	0.0



TEST NUMBER: P315157

CATALOG NUMBER: LDA2B20NFL9024D010 PIN1MB

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°		0.0
87.5°		0.0



(END OF REPORT)