

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P279395

Luminaire Tested: **LDA2B059730D010 EU2B05FL409730 2LBAD1LI**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P279395  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-1811-033-3)  
Test Lab: INNOVATION CENTER(G2)  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LDA2B059730D010 EU2B05FL409730 2LBAD1LI  
Description: PORTFOLIO 2IN ADJ 500 LUMEN LED LUMINAIRE WITH FLOOD OPTIC AND 2in  
ADJ spun Refl, Self-Flanged, LI  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 639.4 lumens  
Efficiency: N/A  
Efficacy: 91.3 lumens/watt  
Spacing Criteria (0/90/45): 0.61 / 0.61 / 0.55  
Luminous Opening: Circular (Dia: 0.17' x H: 0')  
CIE Type: Direct


Input Watts (W): 7  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P279395

CATALOG NUMBER: LDA2B059730D010 EU2B05FL409730 2LBAD1LI

### Luminous Intensity Polar Plot





TEST NUMBER: P279395

CATALOG NUMBER: LDA2B059730D010 EU2B05FL409730 2LBAD1LI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |    |    |   |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|---|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |    |    |   |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |     | 30  |     |     |     | 10  |     |    | 0  |   |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30 | 10 | 0 |
| RCR |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |    |    |   |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |    |    |   |
| 1   | 115 | 113 | 111 | 109 | 112 | 110 | 109 | 107 | 106 | 105 | 104 | 103 | 102 | 101 | 99  | 99  | 98  | 96  |    |    |   |
| 2   | 111 | 107 | 104 | 101 | 109 | 105 | 102 | 100 | 102 | 100 | 98  | 99  | 97  | 96  | 97  | 95  | 94  | 92  |    |    |   |
| 3   | 107 | 102 | 98  | 95  | 105 | 101 | 97  | 94  | 98  | 95  | 93  | 96  | 94  | 92  | 94  | 92  | 90  | 89  |    |    |   |
| 4   | 103 | 98  | 93  | 90  | 102 | 97  | 93  | 90  | 95  | 91  | 89  | 93  | 90  | 88  | 91  | 89  | 87  | 85  |    |    |   |
| 5   | 100 | 94  | 89  | 86  | 98  | 93  | 89  | 86  | 91  | 88  | 85  | 90  | 87  | 84  | 88  | 86  | 83  | 82  |    |    |   |
| 6   | 97  | 90  | 85  | 82  | 95  | 89  | 85  | 82  | 88  | 84  | 81  | 87  | 83  | 81  | 85  | 83  | 80  | 79  |    |    |   |
| 7   | 94  | 87  | 82  | 79  | 92  | 86  | 82  | 79  | 85  | 81  | 78  | 84  | 81  | 78  | 83  | 80  | 78  | 77  |    |    |   |
| 8   | 91  | 84  | 79  | 76  | 90  | 83  | 79  | 76  | 82  | 78  | 76  | 81  | 78  | 75  | 80  | 77  | 75  | 74  |    |    |   |
| 9   | 88  | 81  | 76  | 73  | 87  | 80  | 76  | 73  | 79  | 76  | 73  | 79  | 75  | 73  | 78  | 75  | 73  | 72  |    |    |   |
| 10  | 85  | 78  | 74  | 71  | 84  | 78  | 74  | 71  | 77  | 73  | 71  | 76  | 73  | 70  | 76  | 72  | 70  | 69  |    |    |   |

**AVERAGE LUMINANCE (cd/sqm):**

|     |        |
|-----|--------|
|     | 0°     |
| 0°  | 879171 |
| 5°  | 860540 |
| 10° | 784323 |
| 15° | 612715 |
| 20° | 362740 |
| 25° | 134839 |
| 30° | 42157  |
| 35° | 18731  |
| 40° | 8695   |
| 45° | 4117   |
| 50° | 2226   |
| 55° | 1290   |
| 60° | 592    |
| 65° | 350    |
| 70° | 433    |
| 75° | 0      |
| 80° | 0      |
| 85° | 0      |



TEST NUMBER: P279395

CATALOG NUMBER: LDA2B059730D010 EU2B05FL409730 2LBAD1LI

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 160.6  | 25.1      |
| 10°-20°   | 319.4  | 50.0      |
| 20°-30°   | 130.8  | 20.5      |
| 30°-40°   | 21.7   | 3.4       |
| 40°-50°   | 5.1    | 0.8       |
| 50°-60°   | 1.4    | 0.2       |
| 60°-70°   | 0.3    | 0.1       |
| 70°-80°   | 0.0    | 0.0       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 610.8  | 95.5      |
| 0°-40°    | 632.5  | 98.9      |
| 0°-60°    | 639.0  | 99.9      |
| 0°-90°    | 639.4  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 639.4  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 1782 |      |
| 5°  | 1738 | 161  |
| 15° | 1200 | 319  |
| 25° | 248  | 131  |
| 35° | 31   | 22   |
| 45° | 6    | 5    |
| 55° | 2    | 1    |
| 65° | 0    | 0    |
| 75° | 0    | 0    |
| 85° | 0    | 0    |
| 90° | 0    |      |



TEST NUMBER: P279395

CATALOG NUMBER: LDA2B059730D010 EU2B05FL409730 2LBAD1LI

**CANDELA DISTRIBUTION (FULL):**

|       | 0°     |
|-------|--------|
| 0°    | 1782.0 |
| 1°    | 1775.8 |
| 2°    | 1767.6 |
| 3°    | 1760.2 |
| 4°    | 1750.6 |
| 5°    | 1737.6 |
| 6°    | 1718.6 |
| 7°    | 1693.6 |
| 8°    | 1658.1 |
| 9°    | 1615.0 |
| 10°   | 1565.6 |
| 11°   | 1508.4 |
| 12°   | 1443.8 |
| 13°   | 1370.2 |
| 14°   | 1288.3 |
| 15°   | 1199.6 |
| 17.5° | 951.3  |
| 20°   | 690.9  |
| 22.5° | 442.3  |
| 25°   | 247.7  |
| 27.5° | 130.6  |
| 30°   | 74.0   |
| 32.5° | 47.0   |
| 35°   | 31.1   |
| 37.5° | 20.5   |
| 40°   | 13.5   |
| 42.5° | 8.8    |
| 45°   | 5.9    |
| 47.5° | 4.1    |
| 50°   | 2.9    |
| 52.5° | 2.1    |
| 55°   | 1.5    |
| 57.5° | 0.9    |
| 60°   | 0.6    |
| 62.5° | 0.3    |
| 65°   | 0.3    |
| 67.5° | 0.3    |
| 70°   | 0.3    |
| 72.5° | 0.0    |
| 75°   | 0.0    |
| 77.5° | 0.0    |
| 80°   | 0.0    |
| 82.5° | 0.0    |



TEST NUMBER: P279395

CATALOG NUMBER: LDA2B059730D010 EU2B05FL409730 2LBAD1LI

**CANDELA DISTRIBUTION (continued):**

0°  
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







|       |  |     |
|-------|--|-----|
| 85°   |  | 0.0 |
| 87.5° |  | 0.0 |



(END OF REPORT)