

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P744659

Luminaire Tested: LD4D20D010-EU4DR6520359027-4LBS1B

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P744659
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D20D010-EU4DR6520359027-4LBS1B
Description: 4 INCH ROUND SHALLOW SPECULAR BLACK TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1529.3 lumens
Efficiency: N/A
Efficacy: 66.2 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96
Luminous Opening: Circular (Dia: 0.48' x H: 0')
CIE Type: Direct

Input Watts (W): 23.1
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P744659
CATALOG NUMBER: LD4D20D010-EU4DR6520359027-4LBS1B

Luminous Intensity Polar Plot





TEST NUMBER: P744659

CATALOG NUMBER: LD4D20D010-EU4DR6520359027-4LBS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100																
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93			93																
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85			85																
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78			78																
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72			72																
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66			66																
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61			61																
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56			56																
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52			52																
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49			49																
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46			46																

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	81100
5°	80893
10°	80827
15°	78337
20°	71313
25°	62147
30°	51685
35°	40954
40°	29559
45°	18675
50°	9731
55°	5173
60°	2722
65°	1493
70°	632
75°	677
80°	471
85°	402

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 18675 cd/sqm



TEST NUMBER: P744659

CATALOG NUMBER: LD4D20D010-EU4DR6520359027-4LBS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	131.3	8.6
10°-20°	359.6	23.5
20°-30°	439.6	28.7
30°-40°	356.6	23.3
40°-50°	177.7	11.6
50°-60°	49.6	3.2
60°-70°	11.3	0.7
70°-80°	2.9	0.2
80°-90°	0.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	930.5	60.8
0°-40°	1287.1	84.2
0°-60°	1514.4	99.0
0°-90°	1529.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1529.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1389	
5°	1380	131
15°	1296	360
25°	964	440
35°	574	357
45°	226	178
55°	51	50
65°	11	11
75°	3	3
85°	1	1
90°	0	



TEST NUMBER: P744659

CATALOG NUMBER: LD4D20D010-EU4DR6520359027-4LBS1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	1388.6
2.5°	1387.6
5°	1379.8
7.5°	1375.3
10°	1362.9
12.5°	1337.6
15°	1295.6
17.5°	1229.8
20°	1147.4
22.5°	1058.4
25°	964.4
27.5°	863.8
30°	766.4
32.5°	670.3
35°	574.4
37.5°	478.7
40°	387.7
42.5°	302.4
45°	226.1
47.5°	157.5
50°	107.1
52.5°	73.9
55°	50.8
57.5°	34.3
60°	23.3
62.5°	16.1
65°	10.8
67.5°	5.5
70°	3.7
72.5°	3.5
75°	3.0
77.5°	2.1
80°	1.4
82.5°	1.0
85°	0.6
87.5°	0.4
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)