

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P750453

Luminaire Tested: LD4D55D010-EU4DR6555659035-4LBDP1B

Issue Date: 2/5/2024

Test Information

Test Method: LM-79-2019
Report Number: P750453
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-59)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/5/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D55D010-EU4DR6555659035-4LBDP1B
Description: 4 INCH ROUND DEEP 45° CUTOFF SPECULAR BLACK TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3608.9 lumens
Efficiency: N/A
Efficacy: 62.0 lumens/watt
Spacing Criteria (0/90/45): 0.98 / 0.98 / 0.92
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 58.2
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P750453

CATALOG NUMBER: LD4D55D010-EU4DR6555659035-4LBDP1B

Luminous Intensity Polar Plot





TEST NUMBER: P750453

CATALOG NUMBER: LD4D55D010-EU4DR6555659035-4LBDP1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	113	111	108	106	111	108	106	104	104	103	101	101	99	98	97	96	95	93		
2	108	103	99	95	106	101	97	94	98	95	92	95	92	90	92	90	88	87		
3	102	96	91	87	100	94	90	86	92	88	85	89	86	83	87	84	82	80		
4	97	89	84	79	95	88	83	79	86	82	78	84	80	77	82	79	76	75		
5	92	83	78	73	90	83	77	73	81	76	72	79	75	72	77	74	71	69		
6	87	78	72	68	86	77	72	68	76	71	67	74	70	67	73	69	66	65		
7	83	73	67	63	81	73	67	63	71	66	62	70	66	62	69	65	62	60		
8	79	69	63	59	77	68	63	59	67	62	58	66	62	58	65	61	58	57		
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	58	54	53		
10	71	61	56	52	70	61	55	52	60	55	51	59	55	51	59	54	51	50		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	388225
5°	388546
10°	402225
15°	402893
20°	370934
25°	316049
30°	241944
35°	170930
40°	100896
45°	40963
50°	14856
55°	8267
60°	4742
65°	2611
70°	2747
75°	2111
80°	2202
85°	1880

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 40963 cd/sqm



TEST NUMBER: P750453

CATALOG NUMBER: LD4D55D010-EU4DR6555659035-4LBDP1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	342.1	9.5
10°-20°	986.9	27.3
20°-30°	1184.1	32.8
30°-40°	795.8	22.1
40°-50°	238.2	6.6
50°-60°	42.0	1.2
60°-70°	11.9	0.3
70°-80°	5.8	0.2
80°-90°	1.8	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2513.2	69.6
0°-40°	3309.0	91.7
0°-60°	3589.3	99.5
0°-90°	3608.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3608.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3553	
5°	3543	342
15°	3562	987
25°	2622	1184
35°	1282	796
45°	265	238
55°	43	42
65°	10	12
75°	5	6
85°	2	2
90°	0	



TEST NUMBER: P750453

CATALOG NUMBER: LD4D55D010-EU4DR6555659035-4LBDP1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	3553.2
2.5°	3568.4
5°	3542.6
7.5°	3596.2
10°	3625.4
12.5°	3618.4
15°	3561.8
17.5°	3423.5
20°	3190.2
22.5°	2915.5
25°	2621.6
27.5°	2289.9
30°	1917.7
32.5°	1580.5
35°	1281.5
37.5°	986.1
40°	707.4
42.5°	462.0
45°	265.1
47.5°	140.4
50°	87.4
52.5°	60.6
55°	43.4
57.5°	31.3
60°	21.7
62.5°	14.1
65°	10.1
67.5°	9.1
70°	8.6
72.5°	6.6
75°	5.0
77.5°	4.5
80°	3.5
82.5°	2.5
85°	1.5
87.5°	1.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)