

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P750472

Luminaire Tested: LD4D55D010-EU4DR6555659040-4LBS1LI

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P750472
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D55D010-EU4DR6555659040-4LBS1LI
Description: 4 INCH ROUND SHALLOW SPECULAR CLEAR TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5605.2 lumens
Efficiency: N/A
Efficacy: 96.3 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96
Luminous Opening: Circular (Dia: 0.48' x H: 0')
CIE Type: Direct


Input Watts (W): 58.2
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



Downlight

TEST NUMBER: P750472
CATALOG NUMBER: LD4D55D010-EU4DR6555659040-4LBS1LI

Luminous Intensity Polar Plot





TEST NUMBER: P750472

CATALOG NUMBER: LD4D55D010-EU4DR6555659040-4LBS1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93			93
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85			85
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78			78
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72			72
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66			66
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61			61
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56			56
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52			52
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49			49
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46			46

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	297241
5°	296494
10°	296240
15°	287108
20°	261374
25°	227769
30°	189443
35°	150104
40°	108338
45°	68447
50°	35672
55°	18960
60°	9964
65°	5473
70°	2305
75°	2527
80°	1749
85°	1474

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 68447 cd/sqm



TEST NUMBER: P750472

CATALOG NUMBER: LD4D55D010-EU4DR6555659040-4LBS1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	481.3	8.6
10°-20°	1318.0	23.5
20°-30°	1611.0	28.7
30°-40°	1307.1	23.3
40°-50°	651.4	11.6
50°-60°	181.7	3.2
60°-70°	41.3	0.7
70°-80°	10.7	0.2
80°-90°	2.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3410.3	60.8
0°-40°	4717.4	84.2
0°-60°	5550.5	99.0
0°-90°	5605.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5605.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5089	
5°	5057	481
15°	4748	1318
25°	3534	1611
35°	2105	1307
45°	829	651
55°	186	182
65°	40	41
75°	11	11
85°	2	3
90°	0	



TEST NUMBER: P750472

CATALOG NUMBER: LD4D55D010-EU4DR6555659040-4LBS1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	5089.4
2.5°	5085.7
5°	5057.3
7.5°	5040.8
10°	4995.2
12.5°	4902.4
15°	4748.4
17.5°	4507.6
20°	4205.4
22.5°	3879.3
25°	3534.5
27.5°	3165.8
30°	2809.1
32.5°	2456.8
35°	2105.3
37.5°	1754.6
40°	1421.0
42.5°	1108.4
45°	828.7
47.5°	577.4
50°	392.6
52.5°	270.7
55°	186.2
57.5°	125.6
60°	85.3
62.5°	59.1
65°	39.6
67.5°	20.2
70°	13.5
72.5°	12.7
75°	11.2
77.5°	7.5
80°	5.2
82.5°	3.7
85°	2.2
87.5°	1.5
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)