

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P752105

Luminaire Tested: LD4D65D010-EU4DR7055659040-4LBDP1H

Issue Date: 2/5/2024

Test Information

Test Method: LM-79-2019
Report Number: P752105
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-73)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/5/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D65D010-EU4DR7055659040-4LBDP1H
Description: 4 INCH ROUND DEEP 45° CUTOFF SEMI-SPECULAR CLEAR TRIM, WITH 70° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 7105.0 lumens
Efficiency: N/A
Efficacy: 97.6 lumens/watt
Spacing Criteria (0/90/45): 0.88 / 0.88 / 0.82
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct


Input Watts (W): 72.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



Downlight

TEST NUMBER: P752105
CATALOG NUMBER: LD4D65D010-EU4DR7055659040-4LBDP1H

Luminous Intensity Polar Plot





TEST NUMBER: P752105

CATALOG NUMBER: LD4D65D010-EU4DR7055659040-4LBDP1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	112	109	106	103	110	107	104	102	103	101	99	99	97	96	95	94	93	91																			
2	106	100	95	91	103	98	94	90	95	91	88	92	89	86	89	87	85	83																			
3	100	92	87	82	98	91	86	81	88	84	80	86	82	79	83	80	78	76																			
4	94	86	80	75	92	85	79	74	82	77	73	80	76	73	78	75	72	70																			
5	89	80	74	69	87	79	73	69	77	72	68	75	71	67	74	70	67	65																			
6	85	75	68	64	83	74	68	64	73	67	63	71	66	63	70	66	62	61																			
7	80	70	64	59	79	70	64	59	68	63	59	67	62	59	66	62	58	57																			
8	77	66	60	56	75	66	60	56	65	59	55	64	59	55	63	58	55	53																			
9	73	63	57	52	72	62	56	52	61	56	52	60	55	52	60	55	52	50																			
10	70	59	53	49	69	59	53	49	58	53	49	57	52	49	57	52	49	48																			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	872797
5°	846858
10°	823255
15°	812449
20°	758669
25°	569940
30°	402903
35°	142720
40°	75038
45°	79932
50°	82763
55°	84330
60°	84852
65°	83041
70°	78395
75°	72610
80°	64431
85°	52276

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 57.5°
 Luminance: 84879 cd/sqm



TEST NUMBER: P752105

CATALOG NUMBER: LD4D65D010-EU4DR7055659040-4LBDP1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	728.3	10.3
10°-20°	1997.7	28.1
20°-30°	2200.1	31.0
30°-40°	840.6	11.8
40°-50°	396.9	5.6
50°-60°	394.6	5.6
60°-70°	315.9	4.4
70°-80°	181.6	2.6
80°-90°	49.3	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4926.1	69.3
0°-40°	5766.7	81.2
0°-60°	6558.2	92.3
0°-90°	7105.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	7105.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	7988	
5°	7721	728
15°	7182	1998
25°	4728	2200
35°	1070	841
45°	517	397
55°	443	395
65°	321	316
75°	172	182
85°	42	49
90°	0	



TEST NUMBER: P752105
CATALOG NUMBER: LD4D65D010-EU4DR7055659040-4LBDP1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	7988.2
2.5°	7904.7
5°	7721.3
7.5°	7568.3
10°	7420.3
12.5°	7295.1
15°	7182.5
17.5°	6910.6
20°	6524.9
22.5°	5692.6
25°	4727.6
27.5°	4115.5
30°	3193.5
32.5°	2062.8
35°	1070.0
37.5°	578.0
40°	526.1
42.5°	522.3
45°	517.3
47.5°	505.9
50°	486.9
52.5°	465.4
55°	442.7
57.5°	417.4
60°	388.3
62.5°	355.4
65°	321.2
67.5°	283.3
70°	245.4
72.5°	207.4
75°	172.0
77.5°	135.3
80°	102.4
82.5°	72.1
85°	41.7
87.5°	16.4
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)