

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P753382

Luminaire Tested: LD4D75BD010-EU4DR5570959024-4LBS1B

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P753382
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-52)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D75BD010-EU4DR5570959024-4LBS1B
Description: 4 INCH ROUND SHALLOW SPECULAR BLACK TRIM, WITH 55° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2400K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6205.9 lumens
Efficiency: N/A
Efficacy: 85.7 lumens/watt
Spacing Criteria (0/90/45): 0.89 / 0.89 / 0.87
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 72.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P753382

CATALOG NUMBER: LD4D75BD010-EU4DR5570959024-4LBS1B

Luminous Intensity Polar Plot





TEST NUMBER: P753382

CATALOG NUMBER: LD4D75BD010-EU4DR5570959024-4LBS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	108	106	111	109	106	104	105	103	101		101	99	98		97
2	108	103	99	96	106	101	98	95	98	95	92		95	93	90		92
3	102	96	91	87	100	95	90	86	92	88	85		90	86	84		87
4	97	90	84	80	95	88	83	79	86	82	78		84	81	78		82
5	92	84	78	74	91	83	77	73	81	76	73		79	75	72		78
6	88	79	73	68	86	78	72	68	76	71	68		75	70	67		74
7	83	74	68	64	82	73	67	63	72	67	63		71	66	63		70
8	79	69	63	59	78	69	63	59	68	63	59		67	62	59		66
9	75	66	60	56	74	65	59	55	64	59	55		63	58	55		62
10	72	62	56	52	71	61	56	52	61	56	52		60	55	52		59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	760346
5°	730149
10°	727397
15°	706494
20°	633478
25°	523538
30°	395472
35°	286746
40°	183507
45°	83811
50°	27418
55°	11829
60°	5092
65°	672
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 83811 cd/sqm



TEST NUMBER: P753382

CATALOG NUMBER: LD4D75BD010-EU4DR5570959024-4LBS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	633.5	10.2
10°-20°	1728.8	27.9
20°-30°	1970.2	31.7
30°-40°	1341.2	21.6
40°-50°	462.2	7.4
50°-60°	63.9	1.0
60°-70°	6.2	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4332.5	69.8
0°-40°	5673.7	91.4
0°-60°	6199.8	99.9
0°-90°	6205.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6205.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6959	
5°	6657	633
15°	6246	1729
25°	4343	1970
35°	2150	1341
45°	542	462
55°	62	64
65°	3	6
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P753382

CATALOG NUMBER: LD4D75BD010-EU4DR5570959024-4LBS1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	6959.0
2.5°	6799.5
5°	6657.2
7.5°	6587.3
10°	6556.3
12.5°	6452.8
15°	6245.8
17.5°	5917.3
20°	5448.2
22.5°	4906.6
25°	4342.7
27.5°	3755.4
30°	3134.6
32.5°	2608.5
35°	2149.8
37.5°	1713.4
40°	1286.6
42.5°	891.6
45°	542.4
47.5°	292.3
50°	161.3
52.5°	95.7
55°	62.1
57.5°	39.7
60°	23.3
62.5°	10.3
65°	2.6
67.5°	0.9
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)