

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P753083

Luminaire Tested: LD4D75BD010-EU4DR3570959027-4LBS1B

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P753083
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-20)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D75BD010-EU4DR3570959027-4LBS1B
Description: 4 INCH ROUND SHALLOW SPECULAR BLACK TRIM, WITH 35° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6509.4 lumens
Efficiency: N/A
Efficacy: 89.9 lumens/watt
Spacing Criteria (0/90/45): 0.6 / 0.6 / 0.54
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 72.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P753083

CATALOG NUMBER: LD4D75BD010-EU4DR3570959027-4LBS1B

Luminous Intensity Polar Plot





TEST NUMBER: P753083

CATALOG NUMBER: LD4D75BD010-EU4DR3570959027-4LBS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	115	112	110	108	112	110	108	107	106	105	103	103	101	100	99	98	98	96		
2	110	106	103	101	108	105	102	99	102	99	97	99	97	95	96	95	93	92		
3	106	101	97	94	105	100	96	93	97	95	92	95	93	91	93	91	89	88		
4	103	97	92	89	101	96	92	89	94	90	88	92	89	87	90	88	86	84		
5	99	93	88	85	98	92	87	84	90	86	84	89	85	83	87	84	82	81		
6	96	89	84	81	94	88	84	81	87	83	80	85	82	80	84	81	79	78		
7	93	85	81	78	91	85	80	77	84	80	77	83	79	77	82	79	76	75		
8	90	82	78	74	88	82	77	74	81	77	74	80	76	74	79	76	73	72		
9	87	79	75	72	86	79	75	72	78	74	71	77	74	71	77	73	71	70		
10	84	77	72	69	83	76	72	69	76	72	69	75	71	69	74	71	69	68		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1956904
5°	1910922
10°	1722241
15°	1336737
20°	758180
25°	294964
30°	110040
35°	60316
40°	39423
45°	23997
50°	15281
55°	10801
60°	7889
65°	4292
70°	319
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 23997 cd/sqm



TEST NUMBER: P753083

CATALOG NUMBER: LD4D75BD010-EU4DR3570959027-4LBS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1602.4	24.6
10°-20°	3128.6	48.1
20°-30°	1276.0	19.6
30°-40°	305.3	4.7
40°-50°	127.2	2.0
50°-60°	52.7	0.8
60°-70°	16.5	0.3
70°-80°	0.4	0.0
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	6006.9	92.3
0°-40°	6312.3	97.0
0°-60°	6492.2	99.7
0°-90°	6509.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6509.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	17910	
5°	17423	###
15°	11818	3129
25°	2447	1276
35°	452	305
45°	155	127
55°	57	53
65°	17	17
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P753083

CATALOG NUMBER: LD4D75BD010-EU4DR3570959027-4LBS1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	17910.4
2.5°	17802.9
5°	17423.0
7.5°	16665.1
10°	15523.2
12.5°	13915.5
15°	11817.5
17.5°	9251.6
20°	6520.7
22.5°	4158.0
25°	2446.7
27.5°	1383.1
30°	872.2
32.5°	612.4
35°	452.2
37.5°	349.7
40°	276.4
42.5°	212.9
45°	155.3
47.5°	116.2
50°	89.9
52.5°	71.3
55°	56.7
57.5°	45.9
60°	36.1
62.5°	26.4
65°	16.6
67.5°	5.9
70°	1.0
72.5°	1.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	1.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180°







(END OF REPORT)