

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P754360

Luminaire Tested: LD4D80BD010-EU4DR6570959035-4LBS1MW

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P754360
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D80BD010-EU4DR6570959035-4LBS1MW
Description: 4 INCH ROUND SHALLOW MATTE WHITE TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6740.5 lumens
Efficiency: N/A
Efficacy: 85.4 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96
Luminous Opening: Circular (Dia: 0.48' x H: 0')
CIE Type: Direct

Input Watts (W): 78.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P754360

CATALOG NUMBER: LD4D80BD010-EU4DR6570959035-4LBS1MW

Luminous Intensity Polar Plot





TEST NUMBER: P754360

CATALOG NUMBER: LD4D80BD010-EU4DR6570959035-4LBS1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100																
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93			93																
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85			85																
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78			78																
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72			72																
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66			66																
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61			61																
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56			56																
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52			52																
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49			49																
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46			46																

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	357443
5°	356540
10°	356238
15°	345256
20°	314309
25°	273902
30°	227809
35°	180505
40°	130280
45°	82306
50°	42904
55°	22798
60°	11973
65°	6592
70°	2766
75°	3046
80°	2119
85°	1809

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 82306 cd/sqm



TEST NUMBER: P754360

CATALOG NUMBER: LD4D80BD010-EU4DR6570959035-4LBS1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	578.8	8.6
10°-20°	1584.9	23.5
20°-30°	1937.3	28.7
30°-40°	1571.9	23.3
40°-50°	783.3	11.6
50°-60°	218.5	3.2
60°-70°	49.7	0.7
70°-80°	12.9	0.2
80°-90°	3.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4101.0	60.8
0°-40°	5672.8	84.2
0°-60°	6674.6	99.0
0°-90°	6740.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6740.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6120	
5°	6082	579
15°	5710	1585
25°	4250	1937
35°	2532	1572
45°	996	783
55°	224	218
65°	48	50
75°	14	13
85°	3	3
90°	0	



TEST NUMBER: P754360

CATALOG NUMBER: LD4D80BD010-EU4DR6570959035-4LBS1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	6120.2
2.5°	6115.7
5°	6081.5
7.5°	6061.7
10°	6006.9
12.5°	5895.4
15°	5710.1
17.5°	5420.5
20°	5057.1
22.5°	4665.0
25°	4250.4
27.5°	3807.0
30°	3378.0
32.5°	2954.4
35°	2531.7
37.5°	2109.9
40°	1708.8
42.5°	1332.9
45°	996.5
47.5°	694.3
50°	472.2
52.5°	325.6
55°	223.9
57.5°	151.1
60°	102.5
62.5°	71.1
65°	47.7
67.5°	24.3
70°	16.2
72.5°	15.3
75°	13.5
77.5°	9.0
80°	6.3
82.5°	4.5
85°	2.7
87.5°	1.8
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)