

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P740668

Luminaire Tested: LD4D05D010-EU4DR650210IC9040-4LBCSSQMMS

Issue Date: 2/2/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P740668  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/2/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD4D05D010-EU4DR650210IC9040-4LBCSSQMMS  
Description: 4 INCH SQAURE SHALLOW CAST MATTE METALLIC SILVER TRIM, WITH 65° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 606.6 lumens  
Efficiency: N/A  
Efficacy: 80.9 lumens/watt  
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96  
Luminous Opening: Circular (Dia: 0.48' x H: 0')  
CIE Type: Direct

Input Watts (W): 7.5  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT




Downlight



TEST NUMBER: P740668

CATALOG NUMBER: LD4D05D010-EU4DR650210IC9040-4LBCSSQMMS

### Luminous Intensity Polar Plot





TEST NUMBER: P740668  
 CATALOG NUMBER: LD4D05D010-EU4DR650210IC9040-4LBCSSQMMS

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93				
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85				
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78				
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72				
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66				
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61				
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56				
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52				
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49				
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46				

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	32169
5°	32087
10°	32060
15°	31073
20°	28285
25°	24649
30°	20501
35°	16242
40°	11726
45°	7409
50°	3862
55°	2057
60°	1075
65°	594
70°	239
75°	271
80°	202
85°	134

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 7409 cd/sqm



TEST NUMBER: P740668

CATALOG NUMBER: LD4D05D010-EU4DR650210IC9040-4LBCSSQMMS

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	52.1	8.6
10°-20°	142.6	23.5
20°-30°	174.3	28.7
30°-40°	141.4	23.3
40°-50°	70.5	11.6
50°-60°	19.7	3.2
60°-70°	4.5	0.7
70°-80°	1.2	0.2
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	369.1	60.8
0°-40°	510.5	84.2
0°-60°	600.7	99.0
0°-90°	606.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	606.6	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	551	
5°	547	52
15°	514	143
25°	382	174
35°	228	141
45°	90	70
55°	20	20
65°	4	4
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P740668

CATALOG NUMBER: LD4D05D010-EU4DR650210IC9040-4LBCSSQMMS

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	550.8
2.5°	550.4
5°	547.3
7.5°	545.5
10°	540.6
12.5°	530.6
15°	513.9
17.5°	487.8
20°	455.1
22.5°	419.8
25°	382.5
27.5°	342.6
30°	304.0
32.5°	265.8
35°	227.8
37.5°	189.9
40°	153.8
42.5°	119.9
45°	89.7
47.5°	62.5
50°	42.5
52.5°	29.3
55°	20.2
57.5°	13.6
60°	9.2
62.5°	6.4
65°	4.3
67.5°	2.2
70°	1.4
72.5°	1.4
75°	1.2
77.5°	0.8
80°	0.6
82.5°	0.4
85°	0.2
87.5°	0.2
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)